



Sep 10, 2024

LOCKE J

2845 N NEWCASTLE AVE, Chicago IL 60634.

Dear **LOCKE J** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LOCKE J

2845 N NEWCASTLE AVE, Chicago IL 60634.

Estimadas familias de **LOCKE J:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51095	51095-1-W-144-S01	1st Floor, West End, Room 144	Flush180	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-S01	1st Floor, West End, Room 144	Flush180	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-S01	1st Floor, West End, Room 144	Flush180	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-F08	1st Floor, West End, Room 144	Flush180	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-F08	1st Floor, West End, Room 144	Flush180	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-F08	1st Floor, West End, Room 144	Flush180	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-F08	1st Floor, West End, Room 144	Flush180	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-S01	1st Floor, West End, Room 144	Flush180	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-F08	1st Floor, West End, Room 144	Initial	30-AUG-19	1.000	ug/L
51095	51095-1-W-144-S01	1st Floor, West End, Room 144	Initial	30-AUG-19	1.000	ug/L
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Flush180	22-JUN-16	1.000	ppb
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Flush180	22-JUN-16	1.000	ppb
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Flush180	22-JUN-16	1.000	ppb
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Flush180	22-JUN-16	1.000	ppb
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Initial	22-JUN-16	1.000	ppb
51095	51095-1-N-136-S01	Addition- Inside Room 136, Left Sink	Initial	04-DEC-19	1.420	ug/L
51095	51095-1-N-136-S02	Addition- Inside Room 136, Right Sink	Flush180	26-MAY-16	1.000	ppb
51095	51095-1-N-136-S02	Addition- Inside Room 136, Right Sink	Flush180	26-MAY-16	1.000	ppb
51095	51095-1-N-136-S02	Addition- Inside Room 136, Right Sink	Flush180	26-MAY-16	1.000	ppb
51095	51095-1-N-136-S02	Addition- Inside Room 136, Right Sink	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-S02	Addition- Inside Room 136, Right Sink	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-S02	Addition- Inside Room 136, Right Sink	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-S02	Addition- Inside Room 136, Right Sink	Initial	26-MAY-16	1.000	ppb
51095	51095-1-N-136-S02	Addition- Inside Room 136, Right Sink	Initial	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Flush180	26-MAY-16	0.263	ppb
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Flush180	26-MAY-16	0.380	ppb
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Flush180	26-MAY-16	0.124	ppb
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Flush180	26-MAY-16	0.241	ppb
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Flush180	04-DEC-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Flush180	04-DEC-19	1.210	ug/L
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Initial	26-MAY-16	0.176	ppb
51095	51095-1-N-136-F01	Addition- Inside Room 136, Fountain	Initial	04-DEC-19	1.000	ug/L
51095	51095-1-138-F06	Addition- Inside Room 138, Fountain - First Floor	Flush180	26-MAY-16	1.370	ppb
51095	51095-1-138-F06	Addition- Inside Room 138, Fountain - First Floor	Flush180	26-MAY-16	1.680	ppb
51095	51095-1-138-F06	Addition- Inside Room 138, Fountain - First Floor	Flush180	26-MAY-16	1.220	ppb
51095	51095-1-138-F06	Addition- Inside Room 138, Fountain - First Floor	Flush180	26-MAY-16	0.649	ppb
51095	51095-1-138-F06	Addition- Inside Room 138, Fountain - First Floor	Initial	26-MAY-16	5.310	ppb
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Flush180	26-MAY-16	0.144	ppb
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Flush180	26-MAY-16	0.250	ppb
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Flush180	26-MAY-16	0.249	ppb
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Flush180	26-MAY-16	0.139	ppb
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Flush180	30-SEP-20	1.000	ug/L
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Initial	26-MAY-16	0.120	ppb
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Initial	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS01	Addition- Kitchen, Sink 1 - First Floor	Initial	30-SEP-20	1.000	ug/L
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Flush180	26-MAY-16	0.174	ppb
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Flush180	26-MAY-16	0.176	ppb
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Flush180	26-MAY-16	0.231	ppb
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Flush180	26-MAY-16	0.142	ppb
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Initial	26-MAY-16	0.120	ppb
51095	51095-1-N-KIT-KS02	Addition- Kitchen, Sink 2 -First Floor	Initial	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Flush180	26-MAY-16	3.700	ppb
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Flush180	26-MAY-16	2.010	ppb
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Flush180	26-MAY-16	2.700	ppb
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Flush180	26-MAY-16	2.260	ppb
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Flush180	04-DEC-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Initial	26-MAY-16	2.860	ppb
51095	51095-1-N-KIT-KS03	Addition- Kitchen, Sink 3 -First Floor	Initial	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS04	Addition- Kitchen, Sink 4 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS04	Addition- Kitchen, Sink 4 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS04	Addition- Kitchen, Sink 4 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS04	Addition- Kitchen, Sink 4 -First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-N-KIT-KS04	Addition- Kitchen, Sink 4 -First Floor	Initial	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	03-AUG-16	1.000	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	03-AUG-16	2.500	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	03-AUG-16	1.000	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	03-AUG-16	1.000	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	26-MAY-16	2.750	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	26-MAY-16	3.000	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	26-MAY-16	4.130	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	26-MAY-16	3.330	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Flush180	04-DEC-19	1.050	ug/L
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Initial	03-AUG-16	1.000	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Initial	26-MAY-16	19.600	ppb
51095	51095-1-S-128-S01	Inside Rm 128 Middle Sink - First Floor	Initial	04-DEC-19	1.550	ug/L
51095	51095-1-S-128-F01	Inside Room 128, Fountain	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-F01	Inside Room 128, Fountain	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-F01	Inside Room 128, Fountain	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-F01	Inside Room 128, Fountain	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-F01	Inside Room 128, Fountain	Initial	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Flush180	26-MAY-16	1.910	ppb
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Flush180	26-MAY-16	2.020	ppb
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Flush180	26-MAY-16	5.200	ppb
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Flush180	26-MAY-16	3.370	ppb
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Flush180	04-DEC-19	1.000	ug/L
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Flush180	04-DEC-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	128-S02	Floor				
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Initial	26-MAY-16	2.640	ppb
51095	51095-1-S-128-S02	Inside Room 128, Right Sink - First Floor	Initial	04-DEC-19	2.260	ug/L
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	26-MAY-16	0.120	ppb
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	26-MAY-16	0.120	ppb
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	26-MAY-16	0.120	ppb
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	26-MAY-16	0.120	ppb
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Flush180	30-SEP-20	1.000	ug/L
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Initial	26-MAY-16	0.120	ppb
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Initial	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F01	New Addition, 1st Floor Elevator Lobby, Fountain 1	Initial	30-SEP-20	1.000	ug/L
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Flush180	26-MAY-16	0.269	ppb
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Flush180	26-MAY-16	0.255	ppb
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Flush180	26-MAY-16	0.210	ppb
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Flush180	26-MAY-16	0.274	ppb
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Flush180	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Flush180	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Flush180	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Flush180	27-NOV-19	1.000	ug/L
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Initial	26-MAY-16	0.120	ppb
51095	51095-1-S-HAL-F02	New Addition, 1st Floor Elevator Lobby, Fountain 2	Initial	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	22-JUN-16	0.421	ppb
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	22-JUN-16	0.519	ppb
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	22-JUN-16	0.208	ppb
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	22-JUN-16	0.515	ppb
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Flush180	30-SEP-20	2.110	ug/L
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Initial	22-JUN-16	0.367	ppb
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Initial	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F05	Main- Across From Room 110, Fountain (Left)	Initial	30-SEP-20	2.370	ug/L
51697	51697-1-E-	Main- Across From Room 110,	Flush180	27-NOV-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F06	Fountain (Right)				
51697	51697-1-E-HAL-F06	Main- Across From Room 110, Fountain (Right)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F06	Main- Across From Room 110, Fountain (Right)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F06	Main- Across From Room 110, Fountain (Right)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-E-HAL-F06	Main- Across From Room 110, Fountain (Right)	Initial	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Flush180	22-JUN-16	0.792	ppb
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Flush180	22-JUN-16	0.941	ppb
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Flush180	22-JUN-16	0.966	ppb
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Flush180	22-JUN-16	0.663	ppb
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Initial	22-JUN-16	0.602	ppb
51697	51697-1-S-HAL-F07	Main- Across From Room 124, Fountain (Left)	Initial	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F08	Main- Across From Room 124, Fountain (Right)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F08	Main- Across From Room 124, Fountain (Right)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F08	Main- Across From Room 124, Fountain (Right)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F08	Main- Across From Room 124, Fountain (Right)	Initial	27-NOV-19	1.000	ug/L
51697	51697-2-HAL-F03	Main- Across From Room 210, Fountain	Flush180	22-JUN-16	0.897	ppb
51697	51697-2-HAL-F03	Main- Across From Room 210, Fountain	Flush180	22-JUN-16	0.780	ppb
51697	51697-2-HAL-F03	Main- Across From Room 210, Fountain	Flush180	22-JUN-16	0.859	ppb
51697	51697-2-HAL-F03	Main- Across From Room 210, Fountain	Flush180	22-JUN-16	0.768	ppb
51697	51697-2-HAL-F03	Main- Across From Room 210, Fountain	Initial	22-JUN-16	0.565	ppb
51697	51697-2-HAL-F04	Main- Across From Room 222, Fountain	Flush180	22-JUN-16	0.809	ppb
51697	51697-2-HAL-F04	Main- Across From Room 222, Fountain	Flush180	22-JUN-16	0.838	ppb
51697	51697-2-HAL-F04	Main- Across From Room 222, Fountain	Flush180	22-JUN-16	0.736	ppb
51697	51697-2-HAL-F04	Main- Across From Room 222, Fountain	Flush180	22-JUN-16	0.803	ppb
51697	51697-2-HAL-F04	Main- Across From Room 222, Fountain	Initial	22-JUN-16	0.715	ppb
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Flush180	22-JUN-16	0.553	ppb
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Flush180	22-JUN-16	0.662	ppb
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Flush180	22-JUN-16	0.570	ppb
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Flush180	22-JUN-16	0.583	ppb
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Initial	22-JUN-16	1.210	ppb
51697	51697-1-S-HAL-F01	Main- Outside Room 107, East Fountain 1 (Left Bubbler)	Initial	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F02	Main- Outside Room 107, East Fountain 1 (Right Bubbler)	Flush180	27-NOV-19	1.310	ug/L
51697	51697-1-S-HAL-F02	Main- Outside Room 107, East Fountain 1 (Right Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F02	Main- Outside Room 107, East Fountain 1 (Right Bubbler)	Flush180	27-NOV-19	1.310	ug/L
51697	51697-1-S-HAL-F02	Main- Outside Room 107, East Fountain 1 (Right Bubbler)	Flush180	27-NOV-19	2.130	ug/L
51697	51697-1-S-HAL-F02	Main- Outside Room 107, East Fountain 1 (Right Bubbler)	Initial	27-NOV-19	1.150	ug/L
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Flush180	22-JUN-16	1.220	ppb
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Flush180	22-JUN-16	0.506	ppb
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Flush180	22-JUN-16	0.546	ppb
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Flush180	22-JUN-16	1.240	ppb
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Flush180	27-NOV-19	1.030	ug/L
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Initial	22-JUN-16	2.670	ppb
51697	51697-1-S-HAL-F03	Main- Outside Room 107, West Fountain 2(Left Bubbler)	Initial	27-NOV-19	1.590	ug/L
51697	51697-1-S-HAL-F04	Main- Outside Room 107, West Fountain 2(Right Bubbler)	Flush180	27-NOV-19	1.340	ug/L
51697	51697-1-S-HAL-F04	Main- Outside Room 107, West Fountain 2(Right Bubbler)	Flush180	27-NOV-19	1.080	ug/L
51697	51697-1-S-HAL-F04	Main- Outside Room 107, West Fountain 2(Right Bubbler)	Flush180	27-NOV-19	1.010	ug/L
51697	51697-1-S-HAL-F04	Main- Outside Room 107, West Fountain 2(Right Bubbler)	Flush180	27-NOV-19	1.030	ug/L
51697	51697-1-S-HAL-F04	Main- Outside Room 107, West Fountain 2(Right Bubbler)	Initial	27-NOV-19	2.120	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	26-JUL-23	1.900	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	26-JUL-23	1.820	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	26-JUL-23	1.880	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	26-JUL-23	1.860	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	22-JUN-16	0.759	ppb
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	22-JUN-16	0.522	ppb
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	22-JUN-16	0.527	ppb
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	22-JUN-16	0.498	ppb
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	22-OCT-20	1.390	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	22-OCT-20	1.530	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubbler)	Flush180	22-OCT-20	2.120	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubblers)	Flush180	22-OCT-20	2.020	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubblers)	Flush180	30-SEP-20	3.490	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubblers)	Initial	26-JUL-23	2.210	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubblers)	Initial	22-JUN-16	0.690	ppb
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubblers)	Initial	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubblers)	Initial	22-OCT-20	2.090	ug/L
51697	51697-2-S-HAL-F01	Main- Outside Room 207, East Fountain 1 (Left Bubblers)	Initial	30-SEP-20	8.980	ug/L
51697	51697-2-S-HAL-F02	Main- Outside Room 207, East Fountain 1 (Right Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F02	Main- Outside Room 207, East Fountain 1 (Right Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F02	Main- Outside Room 207, East Fountain 1 (Right Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F02	Main- Outside Room 207, East Fountain 1 (Right Bubblers)	Initial	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Flush180	22-JUN-16	0.646	ppb
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Flush180	22-JUN-16	0.642	ppb
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Flush180	22-JUN-16	1.190	ppb
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Flush180	22-JUN-16	0.705	ppb
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Initial	22-JUN-16	1.950	ppb
51697	51697-2-S-HAL-F03	Main- Outside Room 207, West Fountain 2 (Left Bubblers)	Initial	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F04	Main- Outside Room 207, West Fountain 2 (Right Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F04	Main- Outside Room 207, West Fountain 2 (Right Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F04	Main- Outside Room 207, West Fountain 2 (Right Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F04	Main- Outside Room 207, West Fountain 2 (Right Bubblers)	Flush180	27-NOV-19	1.000	ug/L
51697	51697-2-S-HAL-F04	Main- Outside Room 207, West Fountain 2 (Right Bubblers)	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F01	1st Floor, East End, Room 142	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F01	1st Floor, East End, Room 142	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F01	1st Floor, East End, Room 142	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F01	1st Floor, East End, Room 142	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S02	1st Floor, East End, Room 142	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S02	1st Floor, East End, Room 142	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S02	1st Floor, East End, Room 142	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S02	1st Floor, East End, Room 142	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F01	1st Floor, East End, Room 142	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S02	1st Floor, East End, Room 142	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-N-	Modular 3- Corridor, East Fountain	Flush180	22-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F06	1				
56497	56497-1-N-HAL-F06	Modular 3- Corridor, East Fountain 1	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-N-HAL-F06	Modular 3- Corridor, East Fountain 1	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-N-HAL-F06	Modular 3- Corridor, East Fountain 1	Flush180	22-JUN-16	0.141	ppb
56497	56497-1-N-HAL-F06	Modular 3- Corridor, East Fountain 1	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-N-HAL-F06	Modular 3- Corridor, East Fountain 1	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-N-HAL-F06	Modular 3- Corridor, East Fountain 1	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-N-HAL-F06	Modular 3- Corridor, East Fountain 1	Initial	22-JUN-16	0.167	ppb
56497	56497-1-N-HAL-F06	Modular 3- Corridor, East Fountain 1	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Flush180	22-JUN-16	0.126	ppb
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Initial	22-JUN-16	0.207	ppb
56497	56497-1-N-HAL-F05	Modular 3- Corridor, West Fountain 2	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Flush180	22-JUN-16	0.127	ppb
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Flush180	22-JUN-16	0.163	ppb
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Flush180	22-JUN-16	0.246	ppb
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Initial	22-JUN-16	0.396	ppb
56497	56497-1-E-142-S03	Modular 3- Insdie Room 142, Sink	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-E-	Modular 3- Inside Room 142,	Flush180	27-NOV-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	142-F04	Fountain				
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Flush180	30-SEP-20	1.000	ug/L
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Initial	22-JUN-16	1.000	ppb
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-E-142-F04	Modular 3- Inside Room 142, Fountain	Initial	30-SEP-20	1.000	ug/L
56497	56497-1-E-143-F04	Modular 3- Inside Room 143, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-E-143-F04	Modular 3- Inside Room 143, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-E-143-F04	Modular 3- Inside Room 143, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-E-143-F04	Modular 3- Inside Room 143, Fountain	Initial	22-JUN-16	2.840	ppb
56497	56497-1-E-143-S03	Modular 3- Inside Room 143, Sink	Flush180	22-JUN-16	0.196	ppb
56497	56497-1-E-143-S03	Modular 3- Inside Room 143, Sink	Flush180	22-JUN-16	0.188	ppb
56497	56497-1-E-143-S03	Modular 3- Inside Room 143, Sink	Flush180	22-JUN-16	0.245	ppb
56497	56497-1-E-143-S03	Modular 3- Inside Room 143, Sink	Flush180	22-JUN-16	0.286	ppb
56497	56497-1-E-143-S03	Modular 3- Inside Room 143, Sink	Initial	22-JUN-16	1.070	ppb
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Initial	22-JUN-16	1.000	ppb
56497	56497-1-W-144-F08	Modular 3- Inside Room 144, Fountain	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Flush180	22-JUN-16	0.161	ppb
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Flush180	22-JUN-16	0.190	ppb
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Flush180	22-JUN-16	0.327	ppb
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Flush180	22-JUN-16	0.155	ppb
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Initial	22-JUN-16	0.488	ppb
56497	56497-1-W-144-S07	Modular 3- Inside Room 144, Sink	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	22-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	22-JUN-16	1.000	ppb
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Flush180	30-SEP-20	1.000	ug/L
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Initial	22-JUN-16	1.000	ppb
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Initial	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-F10	Modular 3- Inside Room 145, Fountain	Initial	30-SEP-20	1.000	ug/L
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Flush180	22-JUN-16	1.080	ppb
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Flush180	22-JUN-16	0.538	ppb
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Flush180	22-JUN-16	0.238	ppb
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Flush180	22-JUN-16	0.312	ppb
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Flush180	27-NOV-19	1.000	ug/L
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Initial	22-JUN-16	0.420	ppb
56497	56497-1-W-145-S09	Modular 3- Inside Room 145, Sink	Initial	27-NOV-19	1.000	ug/L