



Sep 10, 2024

LORCA

3231 N SPRINGFIELD AVE, Chicago IL 60618.

Dear **LORCA** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LORCA

3231 N SPRINGFIELD AVE, Chicago IL 60618.

Estimadas familias de **LORCA**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Initial	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF07	2nd FL outside gym Left Fountain Bottle Filler	Initial	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Initial	08-JAN-19	1.000	ppb
54765	54765-2-HAL-BF08	2nd FI outside rm 224 right fountain bottle filler	Initial	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Initial	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF08	3rd FL outside rm 324 Right Fountain Bottle Filler	Initial	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF07	3rd FI outside Library Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF07	3rd FI outside Library Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF07	3rd FI outside Library Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF07	3rd FI outside Library Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-BF07	3rd FI outside Library Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54765	54765-3-HAL-BF07	3rd Fl outside Library Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF07	3rd Fl outside Library Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF07	3rd Fl outside Library Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF07	3rd Fl outside Library Left Fountain Bottle Filler	Initial	08-JAN-19	1.000	ppb
54765	54765-3-HAL-BF07	3rd Fl outside Library Left Fountain Bottle Filler	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Initial	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF26	Corridor Left Fountain Bottle Filler	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Initial	08-JAN-19	1.000	ppb
54765	54765-1-HAL-BF27	Corridor across rm 122 Left Fountain - Bottle Fill	Initial	31-OCT-2023	1.000	ug/L
54765	54765-2-TL-S24	Main - Teachers Pantry, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-TL-S24	Main - Teachers Pantry, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-TL-S24	Main - Teachers Pantry, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-TL-S24	Main - Teachers Pantry, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-TL-S24	Main - Teachers Pantry, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Flush180	28-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F05	Main- 2nd Floor Outside Gym, Center Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Initial	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F04	Main- 2nd Floor Outside Gym, Left Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F06	Main- 2nd Floor Outside Gym, Right Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F05	Main- 3rd Floor Outside Library, Center Fountain	Initial	31-OCT-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Center Fountain				
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Initial	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F04	Main- 3rd Floor Outside Library, Left Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Flush180	28-SEP-16	0.175	ppb
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Flush180	28-SEP-16	0.135	ppb
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Flush180	28-SEP-16	0.173	ppb
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Flush180	28-SEP-16	0.152	ppb
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Initial	28-SEP-16	0.121	ppb
54765	54765-3-HAL-F06	Main- 3rd Floor Outside Library, Right Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Flush180	28-SEP-16	0.122	ppb
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F04	Main- Across From Main Office, Center Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-	Main- Across From Main Office,	Flush	31-OCT-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Left Fountain				
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	28-SEP-16	0.128	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Flush180	19-AUG-20	1.000	ug/L
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Initial	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Initial	18-AUG-20	1.000	ug/L
54765	54765-1-HAL-F03	Main- Across From Main Office, Left Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F05	Main- Across From Main Office, Right Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Flush180	28-SEP-16	0.155	ppb
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Initial	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F18	Main- Across From Room 122, Center Foutnain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush	31-OCT-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush180	28-SEP-16	0.184	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush180	28-SEP-16	0.304	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Flush180	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Initial	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Initial	08-JAN-19	1.000	ppb
54765	54765-1-HAL-F19	Main- Across From Room 122, Left Foutnain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Flush180	28-SEP-16	0.135	ppb
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Flush180	28-SEP-16	0.126	ppb
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Flush180	28-SEP-16	0.133	ppb
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Initial	28-SEP-16	0.243	ppb
54765	54765-1-HAL-F17	Main- Across From Room 122, Right Foutnain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Flush180	28-SEP-16	0.541	ppb
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Flush180	28-SEP-16	0.393	ppb
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Flush180	28-SEP-16	0.624	ppb
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Flush180	28-SEP-16	0.347	ppb
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Initial	28-SEP-16	0.560	ppb
54765	54765-1-114-S10	Main- Inside Room 114, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Flush	31-OCT-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-1-115-F06	Main- Inside Room 115, Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Flush180	28-SEP-16	0.249	ppb
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Flush180	28-SEP-16	0.303	ppb
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Flush180	28-SEP-16	0.252	ppb
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Flush180	28-SEP-16	0.240	ppb
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Initial	28-SEP-16	0.960	ppb
54765	54765-1-115-S07	Main- Inside Room 115, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-116-F08	Main- Inside Room 116, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-116-F08	Main- Inside Room 116, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-116-F08	Main- Inside Room 116, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-116-F08	Main- Inside Room 116, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-116-F08	Main- Inside Room 116, Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-116-S09	Main- Inside Room 116, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-116-S09	Main- Inside Room 116, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-116-S09	Main- Inside Room 116, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-116-S09	Main- Inside Room 116, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-116-S09	Main- Inside Room 116, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-116A-F08	Main- Inside Room 116A, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-116A-F08	Main- Inside Room 116A, Fountain	Flush180	28-SEP-16	0.145	ppb
54765	54765-1-116A-F08	Main- Inside Room 116A, Fountain	Flush180	28-SEP-16	0.126	ppb
54765	54765-1-116A-F08	Main- Inside Room 116A, Fountain	Flush180	28-SEP-16	0.125	ppb
54765	54765-1-116A-F08	Main- Inside Room 116A, Fountain	Initial	28-SEP-16	0.157	ppb
54765	54765-1-116A-S09	Main- Inside Room 116A, Sink	Flush180	28-SEP-16	0.340	ppb
54765	54765-1-116A-S09	Main- Inside Room 116A, Sink	Flush180	28-SEP-16	0.188	ppb
54765	54765-1-116A-S09	Main- Inside Room 116A, Sink	Flush180	28-SEP-16	0.253	ppb
54765	54765-1-116A-S09	Main- Inside Room 116A, Sink	Flush180	28-SEP-16	0.223	ppb
54765	54765-1-116A-S09	Main- Inside Room 116A, Sink	Initial	28-SEP-16	0.290	ppb
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-117-	Main- Inside Room 117, Fountain	Flush	31-OCT-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F11					
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Flush180	28-SEP-16	0.160	ppb
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-1-117-F11	Main- Inside Room 117, Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Flush180	28-SEP-16	1.940	ppb
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Flush180	28-SEP-16	1.590	ppb
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Flush180	28-SEP-16	2.100	ppb
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Flush180	28-SEP-16	1.330	ppb
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Initial	28-SEP-16	0.755	ppb
54765	54765-1-117-S12	Main- Inside Room 117, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Flush	31-OCT-2023	1.020	ug/L
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Flush	31-OCT-2023	1.590	ug/L
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Flush	31-OCT-2023	1.250	ug/L
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Flush	31-OCT-2023	3.100	ug/L
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Flush180	28-SEP-16	1.270	ppb
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Flush180	28-SEP-16	0.480	ppb
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Flush180	28-SEP-16	0.431	ppb
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Flush180	28-SEP-16	0.801	ppb
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Initial	28-SEP-16	0.648	ppb
54765	54765-1-118-S13	Main- Inside Room 118, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Flush180	28-SEP-16	1.180	ppb
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Flush180	28-SEP-16	1.730	ppb
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Flush180	28-SEP-16	1.570	ppb
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Flush180	28-SEP-16	2.510	ppb
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Initial	28-SEP-16	6.690	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S14					
54765	54765-1-120-S14	Main- Inside Room 120, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Initial	28-SEP-16	1.000	ppb
54765	54765-1-122-F15	Main- Inside Room 122, FountMain- Inside Room 122,	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Flush	31-OCT-2023	1.120	ug/L
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Flush180	28-SEP-16	2.510	ppb
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Flush180	28-SEP-16	0.915	ppb
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Flush180	28-SEP-16	0.935	ppb
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Flush180	28-SEP-16	2.410	ppb
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Initial	28-SEP-16	0.665	ppb
54765	54765-1-122-S16	Main- Inside Room 122, Sink	Initial	31-OCT-2023	1.370	ug/L
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Flush180	28-SEP-16	0.340	ppb
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Flush180	28-SEP-16	0.334	ppb
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Flush180	28-SEP-16	0.462	ppb
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Initial	28-SEP-16	1.350	ppb
54765	54765-1-123-F22	Main- Inside Room 123, Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Flush180	28-SEP-16	1.190	ppb
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Flush180	28-SEP-16	0.767	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Flush180	28-SEP-16	1.210	ppb
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Flush180	28-SEP-16	0.563	ppb
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Initial	28-SEP-16	1.800	ppb
54765	54765-1-123-S23	Main- Inside Room 123, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-1-124-F20	Main- Inside Room 124, Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-124-S21	Main- Inside Room 124, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-124-S21	Main- Inside Room 124, Sink	Flush	31-OCT-2023	1.300	ug/L
54765	54765-1-124-S21	Main- Inside Room 124, Sink	Flush	31-OCT-2023	1.950	ug/L
54765	54765-1-124-S21	Main- Inside Room 124, Sink	Flush	31-OCT-2023	1.230	ug/L
54765	54765-1-124-F21	Main- Inside Room 124, Sink	Flush180	28-SEP-16	0.258	ppb
54765	54765-1-124-F21	Main- Inside Room 124, Sink	Flush180	28-SEP-16	0.299	ppb
54765	54765-1-124-F21	Main- Inside Room 124, Sink	Flush180	28-SEP-16	0.272	ppb
54765	54765-1-124-F21	Main- Inside Room 124, Sink	Flush180	28-SEP-16	0.274	ppb
54765	54765-1-124-F21	Main- Inside Room 124, Sink	Initial	28-SEP-16	0.289	ppb
54765	54765-1-124-S21	Main- Inside Room 124, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Flush180	28-SEP-16	0.136	ppb
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Flush180	28-SEP-16	0.314	ppb
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Flush180	28-SEP-16	0.326	ppb
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Flush180	28-SEP-16	0.307	ppb
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Initial	28-SEP-16	1.000	ppb
54765	54765-1-KIT-KS01	Main- Kitchen, Left Sprayer Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS02	Main- Kitchen, Right Faucet	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-KIT-KS02	Main- Kitchen, Right Faucet	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-KIT-KS02	Main- Kitchen, Right Faucet	Flush180	28-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54765	54765-1-KIT-KS02	Main- Kitchen, Right Faucet	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-KIT-KS02	Main- Kitchen, Right Faucet	Initial	28-SEP-16	0.156	ppb
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Flush	31-OCT-2023	1.000	ug/L
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Flush180	28-SEP-16	0.131	ppb
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Flush180	28-SEP-16	1.000	ppb
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Flush180	28-SEP-16	0.177	ppb
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Flush180	28-SEP-16	0.465	ppb
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Initial	28-SEP-16	0.230	ppb
54765	54765-1-KIT-KS25	Main- Kitchen, South Wall, Sink	Initial	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F02	Main- Outside Room 224, Center Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F01	Main- Outside Room 224, Left Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush180	28-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Initial	08-JAN-19	1.000	ppb
54765	54765-2-HAL-F03	Main- Outside Room 224, Right Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F02	Main- Outside Room 324, Center Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F01	Main- Outside Room 324, Left Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush	31-OCT-2023	1.000	ug/L
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54765	54765-3-HAL-	Main- Outside Room 324, Right	Flush180	28-SEP-16	1.000	ppb

**Water Quality Assessment
Federico Garcia Lorca Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush180	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Flush180	19-AUG-20	1.000	ug/L
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Initial	28-SEP-16	1.000	ppb
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Initial	08-JAN-19	1.000	ppb
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Initial	18-AUG-20	1.000	ug/L
54765	54765-3-HAL-F03	Main- Outside Room 324, Right Fountain	Initial	31-OCT-2023	1.000	ug/L
54765	54765-1-TL-S24	Main- Teachers Pantry, Sink	Flush180	28-SEP-16	0.264	ppb
54765	54765-1-TL-S24	Main- Teachers Pantry, Sink	Flush180	28-SEP-16	1.350	ppb
54765	54765-1-TL-S24	Main- Teachers Pantry, Sink	Flush180	28-SEP-16	0.447	ppb
54765	54765-1-TL-S24	Main- Teachers Pantry, Sink	Flush180	28-SEP-16	0.838	ppb
54765	54765-1-TL-S24	Main- Teachers Pantry, Sink	Initial	28-SEP-16	0.870	ppb