



Sep 10, 2024

LOVETT

6333 W BLOOMINGDALE AVE, Chicago IL 60639.

Dear **LOVETT** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LOVETT

6333 W BLOOMINGDALE AVE, Chicago IL 60639.

Estimadas familias de **LOVETT**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51096	51096-1-BR-S01	Main - Boiler Room	Flush180	31-JUL-20	13.300	ug/L
51096	51096-1-BR-S01	Main - Boiler Room	Flush180	03-DEC-20	1.000	ug/L
51096	51096-1-BR-S01	Main - Boiler Room	Flush180	03-DEC-20	1.000	ug/L
51096	51096-1-BR-S01	Main - Boiler Room	Flush180	03-DEC-20	1.000	ug/L
51096	51096-1-BR-S01	Main - Boiler Room	Flush180	03-DEC-20	1.000	ug/L
51096	51096-1-BR-S01	Main - Boiler Room	Initial	31-JUL-20	3.980	ug/L
51096	51096-1-BR-S01	Main - Boiler Room	Initial	03-DEC-20	1.000	ug/L
51096	51096-1-HAL-F09	Main - Corridor across room 101 - Fountain 1	Flush180	09-JUN-16	0.750	ppb
51096	51096-1-HAL-F09	Main - Corridor across room 101 - Fountain 1	Flush180	09-JUN-16	0.591	ppb
51096	51096-1-HAL-F09	Main - Corridor across room 101 - Fountain 1	Flush180	09-JUN-16	0.445	ppb
51096	51096-1-HAL-F09	Main - Corridor across room 101 - Fountain 1	Flush180	09-JUN-16	0.803	ppb
51096	51096-1-HAL-F09	Main - Corridor across room 101 - Fountain 1	Initial	09-JUN-16	0.268	ppb
51096	51096-1-HAL-F10	Main - Corridor across room 101 - Fountain 2	Flush180	09-JUN-16	0.202	ppb
51096	51096-1-HAL-F10	Main - Corridor across room 101 - Fountain 2	Flush180	09-JUN-16	0.227	ppb
51096	51096-1-HAL-F10	Main - Corridor across room 101 - Fountain 2	Flush180	09-JUN-16	0.193	ppb
51096	51096-1-HAL-F10	Main - Corridor across room 101 - Fountain 2	Flush180	09-JUN-16	0.267	ppb
51096	51096-1-HAL-F10	Main - Corridor across room 101 - Fountain 2	Initial	09-JUN-16	0.294	ppb
51096	51096-1-HAL-F02	Main - Corridor across room 115 - Fountain 1	Flush180	09-JUN-16	0.352	ppb
51096	51096-1-HAL-F02	Main - Corridor across room 115 - Fountain 1	Flush180	09-JUN-16	0.291	ppb
51096	51096-1-HAL-F02	Main - Corridor across room 115 - Fountain 1	Flush180	09-JUN-16	0.370	ppb
51096	51096-1-HAL-F02	Main - Corridor across room 115 - Fountain 1	Flush180	09-JUN-16	0.336	ppb
51096	51096-1-HAL-F02	Main - Corridor across room 115 - Fountain 1	Initial	09-JUN-16	0.364	ppb
51096	51096-1-HAL-F04	Main - Corridor across room 115 - Fountain 2	Flush180	09-JUN-16	1.000	ppb
51096	51096-1-HAL-F04	Main - Corridor across room 115 - Fountain 2	Flush180	09-JUN-16	0.137	ppb
51096	51096-1-HAL-F04	Main - Corridor across room 115 - Fountain 2	Flush180	09-JUN-16	1.000	ppb
51096	51096-1-HAL-F04	Main - Corridor across room 115 - Fountain 2	Flush180	09-JUN-16	1.000	ppb
51096	51096-1-HAL-F04	Main - Corridor across room 115 - Fountain 2	Initial	09-JUN-16	0.304	ppb
51096	51096-2-HAL-F01	Main - Corridor across room 201 - Fountain 1	Flush180	09-JUN-16	0.640	ppb
51096	51096-2-HAL-F01	Main - Corridor across room 201 - Fountain 1	Flush180	09-JUN-16	0.548	ppb
51096	51096-2-HAL-F01	Main - Corridor across room 201 - Fountain 1	Flush180	09-JUN-16	0.458	ppb
51096	51096-2-HAL-F01	Main - Corridor across room 201 - Fountain 1	Flush180	09-JUN-16	0.387	ppb
51096	51096-2-HAL-F01	Main - Corridor across room 201 - Fountain 1	Flush180	31-JUL-20	1.770	ug/L
51096	51096-2-HAL-F01	Main - Corridor across room 201 - Fountain 1	Initial	09-JUN-16	0.738	ppb
51096	51096-2-HAL-F01	Main - Corridor across room 201 - Fountain 1	Initial	31-JUL-20	2.800	ug/L
51096	51096-2-HAL-F02	Main - Corridor across room 201 - Fountain 2	Flush180	09-JUN-16	1.030	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51096	51096-2-HAL-F02	Main - Corridor across room 201 - Fountain 2	Flush180	09-JUN-16	1.400	ppb
51096	51096-2-HAL-F02	Main - Corridor across room 201 - Fountain 2	Flush180	09-JUN-16	1.010	ppb
51096	51096-2-HAL-F02	Main - Corridor across room 201 - Fountain 2	Flush180	09-JUN-16	1.200	ppb
51096	51096-2-HAL-F02	Main - Corridor across room 201 - Fountain 2	Initial	09-JUN-16	3.810	ppb
51096	51096-2-HAL-F03	Main - Corridor across room 201 - Fountain 3	Flush180	09-JUN-16	0.682	ppb
51096	51096-2-HAL-F03	Main - Corridor across room 201 - Fountain 3	Flush180	09-JUN-16	0.680	ppb
51096	51096-2-HAL-F03	Main - Corridor across room 201 - Fountain 3	Flush180	09-JUN-16	0.386	ppb
51096	51096-2-HAL-F03	Main - Corridor across room 201 - Fountain 3	Flush180	09-JUN-16	0.532	ppb
51096	51096-2-HAL-F03	Main - Corridor across room 201 - Fountain 3	Initial	09-JUN-16	0.831	ppb
51096	51096-2-HAL-F04	Main - Corridor across room 217 - Fountain 1	Flush180	09-JUN-16	0.376	ppb
51096	51096-2-HAL-F04	Main - Corridor across room 217 - Fountain 1	Flush180	09-JUN-16	0.338	ppb
51096	51096-2-HAL-F04	Main - Corridor across room 217 - Fountain 1	Flush180	09-JUN-16	0.351	ppb
51096	51096-2-HAL-F04	Main - Corridor across room 217 - Fountain 1	Flush180	09-JUN-16	0.457	ppb
51096	51096-2-HAL-F04	Main - Corridor across room 217 - Fountain 1	Initial	09-JUN-16	0.886	ppb
51096	51096-2-HAL-F05	Main - Corridor across room 217 - Fountain 2	Flush180	09-JUN-16	0.531	ppb
51096	51096-2-HAL-F05	Main - Corridor across room 217 - Fountain 2	Flush180	09-JUN-16	0.448	ppb
51096	51096-2-HAL-F05	Main - Corridor across room 217 - Fountain 2	Flush180	09-JUN-16	0.781	ppb
51096	51096-2-HAL-F05	Main - Corridor across room 217 - Fountain 2	Flush180	09-JUN-16	0.635	ppb
51096	51096-2-HAL-F05	Main - Corridor across room 217 - Fountain 2	Initial	09-JUN-16	1.010	ppb
51096	51096-2-HAL-F06	Main - Corridor across room 217 - Fountain 3	Flush180	09-JUN-16	1.450	ppb
51096	51096-2-HAL-F06	Main - Corridor across room 217 - Fountain 3	Flush180	09-JUN-16	1.520	ppb
51096	51096-2-HAL-F06	Main - Corridor across room 217 - Fountain 3	Flush180	09-JUN-16	1.470	ppb
51096	51096-2-HAL-F06	Main - Corridor across room 217 - Fountain 3	Flush180	09-JUN-16	1.380	ppb
51096	51096-2-HAL-F06	Main - Corridor across room 217 - Fountain 3	Initial	09-JUN-16	1.260	ppb
51096	51096-2-HAL-F07	Main - Corridor across room 217 - Fountain 4	Flush180	09-JUN-16	1.280	ppb
51096	51096-2-HAL-F07	Main - Corridor across room 217 - Fountain 4	Flush180	09-JUN-16	0.738	ppb
51096	51096-2-HAL-F07	Main - Corridor across room 217 - Fountain 4	Flush180	09-JUN-16	1.360	ppb
51096	51096-2-HAL-F07	Main - Corridor across room 217 - Fountain 4	Flush180	09-JUN-16	0.880	ppb
51096	51096-2-HAL-F07	Main - Corridor across room 217 - Fountain 4	Initial	09-JUN-16	1.230	ppb
51096	51096-1-102-F07	Main - Floor Kindergarten room 102 - Fountain	Flush180	09-JUN-16	0.135	ppb
51096	51096-1-102-F07	Main - Floor Kindergarten room 102 - Fountain	Flush180	09-JUN-16	0.122	ppb
51096	51096-1-102-F07	Main - Floor Kindergarten room 102 - Fountain	Flush180	09-JUN-16	0.132	ppb
51096	51096-1-102-F07	Main - Floor Kindergarten room 102 - Fountain	Flush180	09-JUN-16	0.141	ppb
51096	51096-1-102-F07	Main - Floor Kindergarten room 102 - Fountain	Initial	09-JUN-16	0.150	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Flush180	28-JUL-16	1.000	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Flush180	28-JUL-16	1.000	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Flush180	28-JUL-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Flush180	28-JUL-16	1.000	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Flush180	09-JUN-16	36.800	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Flush180	09-JUN-16	24.100	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Flush180	09-JUN-16	10.100	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Flush180	09-JUN-16	33.900	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Initial	28-JUL-16	1.000	ppb
51096	51096-1-105-S08	Main - Floor Pre-K room 105 - Sink	Initial	09-JUN-16	11.000	ppb
51096	51096-1-109-S06	Main - Floor Pre-K room 109 - Sink	Flush180	09-JUN-16	0.782	ppb
51096	51096-1-109-S06	Main - Floor Pre-K room 109 - Sink	Flush180	09-JUN-16	0.671	ppb
51096	51096-1-109-S06	Main - Floor Pre-K room 109 - Sink	Flush180	09-JUN-16	0.759	ppb
51096	51096-1-109-S06	Main - Floor Pre-K room 109 - Sink	Flush180	09-JUN-16	0.772	ppb
51096	51096-1-109-S06	Main - Floor Pre-K room 109 - Sink	Initial	09-JUN-16	1.040	ppb
51096	51096-1-KIT-KS01	Main - Kitchen 108 (North wall), Sink	Flush180	09-JUN-16	0.375	ppb
51096	51096-1-KIT-KS01	Main - Kitchen 108 (North wall), Sink	Flush180	09-JUN-16	0.356	ppb
51096	51096-1-KIT-KS01	Main - Kitchen 108 (North wall), Sink	Flush180	09-JUN-16	0.343	ppb
51096	51096-1-KIT-KS01	Main - Kitchen 108 (North wall), Sink	Flush180	09-JUN-16	0.405	ppb
51096	51096-1-KIT-KS01	Main - Kitchen 108 (North wall), Sink	Initial	09-JUN-16	0.829	ppb
52490	52490-1-HAL-F01	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F02	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F02	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F02	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F02	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F01	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F01	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F01	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F02	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	31-JUL-20	1.000	ug/L
52490	52490-1-HAL-F01	Annex - 1st Fl. Corridor across electrical RM.(W.	Flush180	31-JUL-20	1.000	ug/L
52490	52490-1-HAL-F02	Annex - 1st Fl. Corridor across electrical RM.(W.	Initial	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F01	Annex - 1st Fl. Corridor across electrical RM.(W.	Initial	09-JUN-16	1.000	ppb
52490	52490-1-HAL-F02	Annex - 1st Fl. Corridor across electrical RM.(W.	Initial	31-JUL-20	1.800	ug/L
52490	52490-1-HAL-F01	Annex - 1st Fl. Corridor across electrical RM.(W.	Initial	31-JUL-20	1.000	ug/L