



Sep 10, 2024

LOWELL

3320 W HIRSCH ST, Chicago IL 60651.

Dear **LOWELL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LOWELL

3320 W HIRSCH ST, Chicago IL 60651.

Estimadas familias de **LOWELL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Flush180	28-MAY-16	0.920	ppb
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Flush180	28-MAY-16	1.000	ppb
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Flush180	28-MAY-16	1.000	ppb
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Flush180	28-MAY-16	1.000	ppb
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Initial	28-MAY-16	1.000	ppb
51119	51119-1-108-F03	Main- 1st floor Inside Room 108 Fountain	Initial	24-MAY-23	1.000	ug/L
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Flush180	28-MAY-16	1.630	ppb
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Flush180	28-MAY-16	1.790	ppb
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Flush180	28-MAY-16	0.563	ppb
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Flush180	28-MAY-16	0.581	ppb
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Initial	28-MAY-16	0.588	ppb
51119	51119-1-110-F02	Main- 1st floor Inside Room 110 Fountain	Initial	24-MAY-23	1.000	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	07-JUL-23	2.570	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	07-JUL-23	1.830	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	07-JUL-23	1.000	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	07-JUL-23	1.600	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	16-JUN-23	3.270	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	16-JUN-23	3.720	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	16-JUN-23	4.520	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	16-JUN-23	3.400	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	28-MAY-16	0.386	ppb
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	28-MAY-16	1.000	ppb
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	28-MAY-16	0.185	ppb
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Flush180	28-MAY-16	0.237	ppb
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Initial	07-JUL-23	2.810	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Initial	16-JUN-23	6.620	ug/L
51119	51119-1-KIT-KS04	Main- 1st floor Kitchen Sink	Initial	28-MAY-16	0.258	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Flush180	24-MAY-23	1.020	ug/L
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Flush180	17-AUG-16	1.000	ppb
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Flush180	17-AUG-16	1.000	ppb
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Flush180	17-AUG-16	1.000	ppb
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Flush180	17-AUG-16	1.000	ppb
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Initial	24-MAY-23	1.010	ug/L
51119	51119-2-HAL-F05	Main- 2nd Fl Outside Library, Fountain	Initial	17-AUG-16	1.000	ppb
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Flush180	28-MAY-16	1.540	ppb
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Flush180	28-MAY-16	2.160	ppb
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Flush180	28-MAY-16	2.860	ppb
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Flush180	28-MAY-16	1.890	ppb
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Initial	28-MAY-16	2.040	ppb
51119	51119-2-HAL-F03	Main- 2nd floor Outside Room 210 Fountain 1	Initial	24-MAY-23	1.010	ug/L
51119	51119-2-HAL-F04	Main- 2nd floor Outside Room 210 Fountain 2	Flush180	28-MAY-16	0.474	ppb
51119	51119-2-HAL-F04	Main- 2nd floor Outside Room 210 Fountain 2	Flush180	28-MAY-16	0.432	ppb
51119	51119-2-HAL-F04	Main- 2nd floor Outside Room 210 Fountain 2	Flush180	28-MAY-16	0.269	ppb
51119	51119-2-HAL-F04	Main- 2nd floor Outside Room 210 Fountain 2	Flush180	28-MAY-16	0.243	ppb
51119	51119-2-HAL-F04	Main- 2nd floor Outside Room 210 Fountain 2	Initial	28-MAY-16	0.281	ppb
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Flush180	24-MAY-23	1.090	ug/L
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Flush180	24-MAY-23	1.090	ug/L
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Flush180	28-MAY-16	0.333	ppb
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Flush180	28-MAY-16	0.305	ppb
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Flush180	28-MAY-16	0.462	ppb
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Flush180	28-MAY-16	0.344	ppb
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Initial	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F04	Main- 3rd floor Outside Room 318 Fountain 1	Initial	28-MAY-16	0.321	ppb
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Flush180	24-MAY-23	1.260	ug/L
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Flush180	24-MAY-23	1.410	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Flush180	24-MAY-23	1.810	ug/L
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Flush180	24-MAY-23	1.420	ug/L
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Flush180	28-MAY-16	0.516	ppb
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Flush180	28-MAY-16	0.575	ppb
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Flush180	28-MAY-16	0.605	ppb
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Flush180	28-MAY-16	0.676	ppb
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Initial	24-MAY-23	2.340	ug/L
51119	51119-3-HAL-F05	Main- 3rd floor Outside Room 318 Fountain 2	Initial	28-MAY-16	1.060	ppb
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Flush180	24-MAY-23	1.580	ug/L
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Flush180	24-MAY-23	1.340	ug/L
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Flush180	24-MAY-23	1.410	ug/L
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Flush180	24-MAY-23	1.490	ug/L
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Flush180	28-MAY-16	0.809	ppb
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Flush180	28-MAY-16	0.891	ppb
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Flush180	28-MAY-16	0.897	ppb
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Flush180	28-MAY-16	1.370	ppb
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Initial	24-MAY-23	1.300	ug/L
51119	51119-3-HAL-F06	Main- E. 3rd floor Outside Room 320 Fountain	Initial	28-MAY-16	1.340	ppb
51119	51119-1-KIT-KS05	Main- Kitchen Pot Filler, Sink	Flush180	17-AUG-16	1.700	ppb
51119	51119-1-KIT-KS05	Main- Kitchen Pot Filler, Sink	Flush180	17-AUG-16	1.000	ppb
51119	51119-1-KIT-KS05	Main- Kitchen Pot Filler, Sink	Flush180	17-AUG-16	1.400	ppb
51119	51119-1-KIT-KS05	Main- Kitchen Pot Filler, Sink	Flush180	17-AUG-16	1.000	ppb
51119	51119-1-KIT-KS05	Main- Kitchen Pot Filler, Sink	Initial	17-AUG-16	1.100	ppb
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Flush180	24-MAY-23	1.270	ug/L
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Flush180	24-MAY-23	1.170	ug/L
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Flush180	24-MAY-23	1.090	ug/L
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Flush180	24-MAY-23	1.230	ug/L
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Flush180	17-AUG-16	1.000	ppb
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Flush180	17-AUG-16	1.000	ppb
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Flush180	17-AUG-16	1.000	ppb
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Flush180	17-AUG-16	1.200	ppb
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Initial	24-MAY-23	1.310	ug/L
51119	51119-2-HAL-F06	Main- Outside Room 221, Fountain 2	Initial	17-AUG-16	1.000	ppb
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Flush180	28-MAY-16	0.608	ppb
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Flush180	28-MAY-16	1.020	ppb
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Flush180	28-MAY-16	0.785	ppb
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Flush180	28-MAY-16	0.750	ppb
51119	51119-1-HAL-	Main- W. 1st floor Hallway	Flush180	18-AUG-20	2.430	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Fountain				
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Flush180	24-MAY-23	1.070	ug/L
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Flush180	24-MAY-23	1.150	ug/L
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Initial	28-MAY-16	0.603	ppb
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Initial	18-AUG-20	3.700	ug/L
51119	51119-1-HAL-F01	Main- W. 1st floor Hallway Fountain	Initial	24-MAY-23	1.340	ug/L
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Flush180	28-MAY-16	0.360	ppb
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Flush180	28-MAY-16	0.683	ppb
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Flush180	28-MAY-16	0.497	ppb
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Flush180	28-MAY-16	0.417	ppb
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Initial	28-MAY-16	0.397	ppb
51119	51119-2-HAL-F01	Main- W. 2nd floor Outside Room 215 Fountain 1	Initial	24-MAY-23	1.230	ug/L
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Flush180	28-MAY-16	0.394	ppb
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Flush180	28-MAY-16	0.396	ppb
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Flush180	28-MAY-16	0.389	ppb
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Flush180	28-MAY-16	0.415	ppb
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Flush180	24-MAY-23	1.000	ug/L
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Initial	28-MAY-16	0.473	ppb
51119	51119-2-HAL-F02	Main- W. 2nd floor Outside Room 215 Fountain 2	Initial	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Flush180	28-MAY-16	0.582	ppb
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Flush180	28-MAY-16	0.549	ppb
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Flush180	28-MAY-16	0.522	ppb
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Flush180	28-MAY-16	0.507	ppb
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Initial	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F03	Main- W. 3rd floor Outside Room 310 Fountain	Initial	28-MAY-16	0.451	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	310 Fountain				
51119	51119-3-HAL-RBF01	Main- W. 3rd floor Outside Room 310 Retrofit BF	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-RBF01	Main- W. 3rd floor Outside Room 310 Retrofit BF	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-RBF01	Main- W. 3rd floor Outside Room 310 Retrofit BF	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-RBF01	Main- W. 3rd floor Outside Room 310 Retrofit BF	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-RBF01	Main- W. 3rd floor Outside Room 310 Retrofit BF	Initial	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	28-MAY-16	0.326	ppb
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	28-MAY-16	0.328	ppb
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	28-MAY-16	0.350	ppb
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	28-MAY-16	0.347	ppb
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Flush180	18-AUG-20	2.120	ug/L
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Initial	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Initial	28-MAY-16	0.462	ppb
51119	51119-3-HAL-F01	Main- W. 3rd floor Outside Room 313 Fountain 1	Initial	18-AUG-20	3.380	ug/L
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Flush180	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Flush180	28-MAY-16	0.315	ppb
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Flush180	28-MAY-16	0.372	ppb
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Flush180	28-MAY-16	0.304	ppb
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Flush180	28-MAY-16	0.316	ppb
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Initial	24-MAY-23	1.000	ug/L
51119	51119-3-HAL-F02	Main- W. 3rd floor Outside Room 313 Fountain 2	Initial	28-MAY-16	0.327	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	16-JUN-23	1.480	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	16-JUN-23	1.030	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	16-JUN-23	1.000	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	16-JUN-23	1.000	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	24-MAY-23	3.270	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	24-MAY-23	8.480	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	24-MAY-23	41.000	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	24-MAY-23	5.360	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	17-AUG-16	11.000	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	17-AUG-16	15.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	17-AUG-16	14.000	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	17-AUG-16	15.000	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	31-AUG-16	5.200	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	31-AUG-16	4.100	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	31-AUG-16	4.900	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	31-AUG-16	7.300	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Flush180	17-AUG-16	17.000	ppb
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Initial	16-JUN-23	3.190	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Initial	24-MAY-23	4.500	ug/L
52316	52316-1-403-F05	Branch- Inside Room 403, Fountain	Initial	31-AUG-16	9.500	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	16-JUN-23	1.620	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	16-JUN-23	1.040	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	16-JUN-23	1.000	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	16-JUN-23	1.000	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	24-MAY-23	2.990	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	24-MAY-23	2.660	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	24-MAY-23	2.590	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	24-MAY-23	2.710	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	17-AUG-16	41.000	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	17-AUG-16	19.000	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	17-AUG-16	5.100	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	17-AUG-16	90.000	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	31-AUG-16	2.200	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	31-AUG-16	2.300	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	31-AUG-16	2.500	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Flush180	31-AUG-16	2.800	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Initial	16-JUN-23	2.820	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Initial	24-MAY-23	6.140	ug/L
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Initial	17-AUG-16	42.000	ppb
52316	52316-1-408-F02	Branch- Inside Room 408 East, Fountain	Initial	31-AUG-16	3.800	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush	18-OCT-2023	2.070	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush	18-OCT-2023	2.010	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush	18-OCT-2023	2.090	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush	18-OCT-2023	1.780	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	07-JUL-23	128.000	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	07-JUL-23	67.500	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	07-JUL-23	42.400	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	07-JUL-23	51.100	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	16-JUN-23	3.590	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	16-JUN-23	9.380	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	16-JUN-23	3.260	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	16-JUN-23	3.470	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	24-MAY-23	12.000	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	24-MAY-23	13.800	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	24-MAY-23	11.400	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	24-MAY-23	8.640	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	21-JUN-16	5.570	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	21-JUN-16	6.660	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	31-AUG-16	3.200	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	21-JUN-16	9.950	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	21-JUN-16	27.300	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	17-AUG-16	32.000	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	17-AUG-16	22.000	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	17-AUG-16	19.000	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	17-AUG-16	64.000	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	31-AUG-16	3.400	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	31-AUG-16	3.200	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Flush180	31-AUG-16	3.300	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Initial	07-JUL-23	70.300	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Initial	16-JUN-23	2.770	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Initial	24-MAY-23	10.800	ug/L
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Initial	21-JUN-16	74.100	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Initial	17-AUG-16	32.000	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Initial	31-AUG-16	6.400	ppb
52316	52316-1-408-F01	Branch- Inside Room 408 West, Fountain	Initial	18-OCT-2023	2.260	ug/L
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	17-AUG-16	4.100	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	17-AUG-16	23.000	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	17-AUG-16	4.300	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	17-AUG-16	5.800	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	17-AUG-16	4.500	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	31-AUG-16	3.700	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	31-AUG-16	6.400	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	31-AUG-16	3.100	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	31-AUG-16	4.100	ppb
52316	52316-1-409-F03	Branch- Inside Room 409, Fountain	Flush180	31-AUG-16	3.900	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	31-AUG-16	2.200	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	17-AUG-16	38.000	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	17-AUG-16	73.000	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	17-AUG-16	53.000	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	31-AUG-16	2.400	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	31-AUG-16	2.500	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	31-AUG-16	1.000	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	31-AUG-16	2.500	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	17-AUG-16	32.000	ppb
52316	52316-1-410-S07	Branch- Inside Room 410, Sink	Flush180	17-AUG-16	35.000	ppb
52316	52316-1-HAL-F04	Branch- Outside Room 409, Fountain	Flush180	17-AUG-16	3.800	ppb
52316	52316-1-HAL-F04	Branch- Outside Room 409, Fountain	Flush180	17-AUG-16	5.800	ppb
52316	52316-1-HAL-F04	Branch- Outside Room 409, Fountain	Flush180	17-AUG-16	3.700	ppb
52316	52316-1-HAL-F04	Branch- Outside Room 409, Fountain	Flush180	17-AUG-16	3.500	ppb
52316	52316-1-HAL-F04	Branch- Outside Room 409, Fountain	Flush180	17-AUG-16	3.400	ppb
52316	52316-1-HAL-F02	Corridor Outside 404	Flush	18-OCT-2023	4.590	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush	18-OCT-2023	5.500	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush	18-OCT-2023	4.030	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush	18-OCT-2023	3.870	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	07-JUL-23	22.300	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	16-JUN-23	4.000	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	16-JUN-23	2.330	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	07-JUL-23	10.900	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	16-JUN-23	3.370	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	16-JUN-23	2.490	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	07-JUL-23	12.600	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	07-JUL-23	9.520	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	24-MAY-23	20.200	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	24-MAY-23	8.040	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	24-MAY-23	6.460	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	24-MAY-23	10.700	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F02	Corridor Outside 404	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F02	Corridor Outside 404	Initial	07-JUL-23	32.300	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Initial	16-JUN-23	6.580	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
52316	52316-1-HAL-F02	Corridor Outside 404	Initial	24-MAY-23	31.600	ug/L
52316	52316-1-HAL-F02	Corridor Outside 404	Initial	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F02	Corridor Outside 404	Initial	18-OCT-2023	4.710	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	24-MAY-23	24.300	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	24-MAY-23	13.700	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	24-MAY-23	16.400	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	24-MAY-23	25.600	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	16-JUN-23	2.070	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	16-JUN-23	1.900	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	16-JUN-23	1.740	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	16-JUN-23	1.000	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F01	Hallway Outside Room 406	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-HAL-F01	Hallway Outside Room 406	Initial	24-MAY-23	31.500	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Initial	16-JUN-23	1.600	ug/L
52316	52316-1-HAL-F01	Hallway Outside Room 406	Initial	21-JUN-16	1.000	ppb
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	16-JUN-23	1.030	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	16-JUN-23	1.060	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	16-JUN-23	1.000	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	16-JUN-23	1.000	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	24-MAY-23	12.300	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	24-MAY-23	8.920	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	24-MAY-23	5.720	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	24-MAY-23	5.270	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Initial	16-JUN-23	3.070	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Initial	24-MAY-23	6.460	ug/L
52316	52316-1-KIT-KS01	Kitchen Sink Lunchroom	Initial	21-JUN-16	1.000	ppb
52316	52316-1-401-F01	Room 401 Fountain	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-401-F01	Room 401 Fountain	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-401-F01	Room 401 Fountain	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-401-F01	Room 401 Fountain	Flush180	21-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52316	52316-1-401-F01	Room 401 Fountain	Initial	21-JUN-16	1.000	ppb
52316	52316-1-405-S01	Room 405 Sink	Flush180	16-JUN-23	1.800	ug/L
52316	52316-1-405-S01	Room 405 Sink	Flush180	16-JUN-23	2.320	ug/L
52316	52316-1-405-S01	Room 405 Sink	Flush180	16-JUN-23	2.540	ug/L
52316	52316-1-405-S01	Room 405 Sink	Flush180	16-JUN-23	2.030	ug/L
52316	52316-1-405-S01	Room 405 Sink	Flush180	24-MAY-23	4.010	ug/L
52316	52316-1-405-S01	Room 405 Sink	Flush180	24-MAY-23	2.430	ug/L
52316	52316-1-405-S01	Room 405 Sink	Flush180	24-MAY-23	2.760	ug/L
52316	52316-1-405-S01	Room 405 Sink	Flush180	24-MAY-23	3.450	ug/L
52316	52316-1-405-S01	Room 405 Sink	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-405-S01	Room 405 Sink	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-405-S01	Room 405 Sink	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-405-S01	Room 405 Sink	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-405-S01	Room 405 Sink	Initial	16-JUN-23	1.600	ug/L
52316	52316-1-405-S01	Room 405 Sink	Initial	24-MAY-23	10.100	ug/L
52316	52316-1-405-S01	Room 405 Sink	Initial	21-JUN-16	1.000	ppb
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush	05-OCT-2023	14.600	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush	05-OCT-2023	15.000	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush	05-OCT-2023	14.300	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush	05-OCT-2023	7.680	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush	18-OCT-2023	2.340	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush	18-OCT-2023	2.500	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush	18-OCT-2023	7.440	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush	18-OCT-2023	12.800	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	07-JUL-23	45.000	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	07-JUL-23	53.300	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	07-JUL-23	67.000	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	07-JUL-23	4.840	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	16-JUN-23	13.100	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	16-JUN-23	12.000	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	16-JUN-23	15.000	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	24-MAY-23	36.300	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	24-MAY-23	22.600	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	24-MAY-23	34.700	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	24-MAY-23	70.100	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	21-JUN-16	1.000	ppb

**Water Quality Assessment
James Russell Lowell Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	21-JUN-16	1.000	ppb
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Flush180	16-JUN-23	19.900	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Initial	07-JUL-23	14.400	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Initial	16-JUN-23	6.540	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Initial	24-MAY-23	45.100	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Initial	21-JUN-16	1.000	ppb
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Initial	05-OCT-2023	40.200	ug/L
52316	52316-1-411-S01	Room 411 - Teachers' Lounge	Initial	18-OCT-2023	4.760	ug/L