



Sep 10, 2024

LOZANO

1501 N GREENVIEW AVE, Chicago IL 60642.

Dear **LOZANO** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LOZANO

1501 N GREENVIEW AVE, Chicago IL 60642.

Estimadas familias de **LOZANO**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51686	51686-1-S-HAL-F05	1st Floor Outside Boys Bathroom, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F05	1st Floor Outside Boys Bathroom, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F05	1st Floor Outside Boys Bathroom, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F05	1st Floor Outside Boys Bathroom, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F05	1st Floor Outside Boys Bathroom, Center Fountain 2	Initial	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F06	1st Floor Outside Boys Bathroom, East Fountain 1	Flush180	21-JUN-16	1.500	ppb
51686	51686-1-S-HAL-F06	1st Floor Outside Boys Bathroom, East Fountain 1	Flush180	21-JUN-16	1.370	ppb
51686	51686-1-S-HAL-F06	1st Floor Outside Boys Bathroom, East Fountain 1	Flush180	21-JUN-16	1.710	ppb
51686	51686-1-S-HAL-F06	1st Floor Outside Boys Bathroom, East Fountain 1	Flush180	21-JUN-16	1.380	ppb
51686	51686-1-S-HAL-F06	1st Floor Outside Boys Bathroom, East Fountain 1	Initial	21-JUN-16	7.020	ppb
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Flush180	11-MAR-20	1.310	ug/L
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Flush180	11-MAR-20	1.020	ug/L
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Flush180	11-MAR-20	1.000	ug/L
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Flush180	11-MAR-20	1.000	ug/L
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Initial	21-JUN-16	1.000	ppb
51686	51686-1-S-HAL-F04	1st Floor Outside Boys Bathroom, West Fountain 3	Initial	11-MAR-20	2.670	ug/L
51686	51686-1-E-HAL-F02	1st Floor Outside Girls Bathroom, Center Fountain	Flush180	21-JUN-16	0.140	ppb
51686	51686-1-E-HAL-F02	1st Floor Outside Girls Bathroom, Center Fountain	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-E-HAL-F02	1st Floor Outside Girls Bathroom, Center Fountain	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-E-HAL-F02	1st Floor Outside Girls Bathroom, Center Fountain	Initial	21-JUN-16	0.196	ppb
51686	51686-1-E-HAL-F01	1st Floor Outside Girls Bathroom, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-E-HAL-F01	1st Floor Outside Girls Bathroom, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-E-HAL-F01	1st Floor Outside Girls Bathroom, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-E-HAL-F01	1st Floor Outside Girls Bathroom, North Fountain 1	Initial	21-JUN-16	0.141	ppb
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Flush180	21-JUN-16	0.247	ppb
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Flush180	21-JUN-16	0.193	ppb
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Flush180	21-JUN-16	0.256	ppb
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Flush180	21-JUN-16	0.177	ppb
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Flush180	11-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Flush180	11-MAR-20	1.000	ug/L
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Flush180	11-MAR-20	1.000	ug/L
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Flush180	11-MAR-20	1.000	ug/L
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Initial	21-JUN-16	0.313	ppb
51686	51686-1-E-HAL-F03	1st Floor Outside Girls Bathroom, South Fountain 3	Initial	11-MAR-20	1.000	ug/L
51686	51686-1-W-118-S1	1st Floor, West End, Room 118	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-118-S1	1st Floor, West End, Room 118	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-118-S1	1st Floor, West End, Room 118	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-118-S1	1st Floor, West End, Room 118	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-118-S1	1st Floor, West End, Room 118	Initial	31-AUG-19	4.300	ug/L
51686	51686-2-E-HAL-F02	Across From Room 203, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F02	Across From Room 203, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F02	Across From Room 203, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F02	Across From Room 203, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F02	Across From Room 203, Center Fountain 2	Initial	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F01	Across From Room 203, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F01	Across From Room 203, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F01	Across From Room 203, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F01	Across From Room 203, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F01	Across From Room 203, North Fountain 1	Initial	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F03	Across From Room 203, South Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F03	Across From Room 203, South Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F03	Across From Room 203, South Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F03	Across From Room 203, South Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-E-HAL-F03	Across From Room 203, South Fountain 3	Initial	21-JUN-16	1.000	ppb
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Flush180	04-AUG-20	1.000	ug/L
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Flush180	11-MAR-20	1.000	ug/L
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Flush180	11-MAR-20	1.000	ug/L
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Flush180	11-MAR-20	1.000	ug/L
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Initial	21-JUN-16	1.000	ppb
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Initial	04-AUG-20	1.000	ug/L
51686	51686-3-E-HAL-F02	Across From Room 303, Center Fountain 2	Initial	11-MAR-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51686	51686-3-N-HAL-F01	Across From Room 303, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F01	Across From Room 303, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F01	Across From Room 303, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F01	Across From Room 303, North Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F01	Across From Room 303, North Fountain 1	Initial	21-JUN-16	1.000	ppb
51686	51686-3-E-HAL-F03	Across From Room 303, South Fountain 3	Flush180	21-JUN-16	0.121	ppb
51686	51686-3-E-HAL-F03	Across From Room 303, South Fountain 3	Flush180	21-JUN-16	0.268	ppb
51686	51686-3-E-HAL-F03	Across From Room 303, South Fountain 3	Flush180	21-JUN-16	0.145	ppb
51686	51686-3-E-HAL-F03	Across From Room 303, South Fountain 3	Flush180	21-JUN-16	0.180	ppb
51686	51686-3-E-HAL-F03	Across From Room 303, South Fountain 3	Initial	21-JUN-16	0.427	ppb
51686	51686-3-HAL-F04	Across From Room 314, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-HAL-F04	Across From Room 314, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-HAL-F04	Across From Room 314, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-HAL-F04	Across From Room 314, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-HAL-F04	Across From Room 314, Center Fountain 2	Initial	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F05	Across From Room 314, East Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F05	Across From Room 314, East Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F05	Across From Room 314, East Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F05	Across From Room 314, East Fountain 1	Flush180	21-JUN-16	1.000	ppb
51686	51686-3-N-HAL-F05	Across From Room 314, East Fountain 1	Initial	21-JUN-16	1.000	ppb
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Flush180	31-AUG-19	1.330	ug/L
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Flush180	31-AUG-19	1.120	ug/L
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Flush180	31-AUG-19	1.040	ug/L
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Flush180	11-MAR-20	1.000	ug/L
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Flush180	11-MAR-20	1.000	ug/L
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Flush180	11-MAR-20	1.000	ug/L
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Initial	31-AUG-19	6.980	ug/L
51686	51686-1-W-116-S01	First Floor, West End, Room 116	Initial	11-MAR-20	1.000	ug/L
51686	51686-1-W-117-S1	First Floor, West end, Room 117	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-117-S1	First Floor, West end, Room 117	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-117-S1	First Floor, West end, Room 117	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-117-S1	First Floor, West end, Room 117	Flush180	31-AUG-19	1.000	ug/L
51686	51686-1-W-117-S1	First Floor, West end, Room 117	Initial	31-AUG-19	4.890	ug/L
51686	51686-1-W-118-F01	Fountain in Room 118	Flush180	04-AUG-20	1.000	ug/L
51686	51686-1-W-118-F01	Fountain in Room 118	Initial	04-AUG-20	1.000	ug/L
51686	51686-1-E-	Inside Room 116, Sink	Flush180	21-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	116-S01					
51686	51686-1-E-116-S01	Inside Room 116, Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-E-116-S01	Inside Room 116, Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-E-116-S01	Inside Room 116, Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-E-116-S01	Inside Room 116, Sink	Initial	21-JUN-16	0.563	ppb
51686	51686-1-S-KIT-KS01	Kitchen Stove Sink	Flush180	21-JUN-16	14.900	ppb
51686	51686-1-S-KIT-KS01	Kitchen Stove Sink	Flush180	21-JUN-16	16.500	ppb
51686	51686-1-S-KIT-KS01	Kitchen Stove Sink	Flush180	21-JUN-16	23.100	ppb
51686	51686-1-S-KIT-KS01	Kitchen Stove Sink	Flush180	21-JUN-16	29.600	ppb
51686	51686-1-S-KIT-KS01	Kitchen Stove Sink	Initial	21-JUN-16	41.600	ppb
51686	51686-1-W-KIT-KS03	Kitchen, Center Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-W-KIT-KS03	Kitchen, Center Sink	Flush180	21-JUN-16	0.127	ppb
51686	51686-1-W-KIT-KS03	Kitchen, Center Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-W-KIT-KS03	Kitchen, Center Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-W-KIT-KS03	Kitchen, Center Sink	Initial	21-JUN-16	0.623	ppb
51686	51686-1-S-KIT-KS02	Kitchen, Northeast Corner, Sink	Flush180	21-JUN-16	0.616	ppb
51686	51686-1-S-KIT-KS02	Kitchen, Northeast Corner, Sink	Flush180	21-JUN-16	0.787	ppb
51686	51686-1-S-KIT-KS02	Kitchen, Northeast Corner, Sink	Flush180	21-JUN-16	0.464	ppb
51686	51686-1-S-KIT-KS02	Kitchen, Northeast Corner, Sink	Flush180	21-JUN-16	0.659	ppb
51686	51686-1-S-KIT-KS02	Kitchen, Northeast Corner, Sink	Initial	21-JUN-16	3.670	ppb
51686	51686-1-N-KIT-KS04	Kitchen, South Wall Sink	Flush180	21-JUN-16	0.322	ppb
51686	51686-1-N-KIT-KS04	Kitchen, South Wall Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-N-KIT-KS04	Kitchen, South Wall Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-N-KIT-KS04	Kitchen, South Wall Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-N-KIT-KS04	Kitchen, South Wall Sink	Initial	21-JUN-16	0.238	ppb
51686	51686-1-KIT-KS05	Kitchen, South Wall Sprayer Sink	Flush180	21-JUN-16	1.000	ppb
51686	51686-1-KIT-KS05	Kitchen, South Wall Sprayer Sink	Flush180	21-JUN-16	0.320	ppb
51686	51686-1-KIT-KS05	Kitchen, South Wall Sprayer Sink	Flush180	21-JUN-16	0.132	ppb
51686	51686-1-KIT-KS05	Kitchen, South Wall Sprayer Sink	Flush180	21-JUN-16	0.130	ppb
51686	51686-1-KIT-KS05	Kitchen, South Wall Sprayer Sink	Initial	21-JUN-16	1.280	ppb
51686	51686-2-N-HAL-F05	Outside Gym, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-N-HAL-F05	Outside Gym, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-N-HAL-F05	Outside Gym, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-N-HAL-F05	Outside Gym, Center Fountain 2	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-N-HAL-F05	Outside Gym, Center Fountain 2	Initial	21-JUN-16	1.000	ppb
51686	51686-2-N-HAL-F04	Outside Gym, Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-N-HAL-F04	Outside Gym, Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-N-	Outside Gym, Fountain 3	Flush180	21-JUN-16	1.000	ppb

Water Quality Assessment
Rodolfo Lozano Bilingual & International Ctr ES

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51686	HAL-F04					
51686	51686-2-N-HAL-F04	Outside Gym, Fountain 3	Flush180	21-JUN-16	1.000	ppb
51686	51686-2-N-HAL-F04	Outside Gym, Fountain 3	Initial	21-JUN-16	1.000	ppb