



Sep 10, 2024

LYON

2941 N MCVICKER AVE, Chicago IL 60634.

Dear **LYON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

LYON

2941 N MCVICKER AVE, Chicago IL 60634.

Estimadas familias de **LYON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52617	52617-2-HAL-BF02	ACROSS FROM 205	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Flush180	08-JAN-21	1.200	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Flush180	08-JAN-21	1.860	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Flush180	08-JAN-21	2.180	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Flush180	08-JAN-21	2.240	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Initial	08-JAN-21	2.760	ug/L
52617	52617-2-HAL-BF02	ACROSS FROM 205	Initial	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-RBF01	Main - Fountain (Right) Outside Room 111	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-RBF01	Main - Fountain (Right) Outside Room 111	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-RBF01	Main - Fountain (Right) Outside Room 111	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-RBF01	Main - Fountain (Right) Outside Room 111	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-RBF01	Main - Fountain (Right) Outside Room 111	Initial	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	30-NOV-2023	4.700	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	30-NOV-2023	5.040	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	30-NOV-2023	4.230	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	30-NOV-2023	3.250	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	08-MAR-2024	1.000	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	08-MAR-2024	1.000	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	08-MAR-2024	1.000	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	08-MAR-2024	1.000	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	15-FEB-2024	19.700	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	15-FEB-2024	7.590	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	15-FEB-2024	10.600	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Flush	15-FEB-2024	7.260	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Initial	30-NOV-2023	2.990	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Initial	08-MAR-2024	1.000	ug/L
52617	52617-2-HAL-F06	Main - Fountain Outside Room 215, Right Fountain	Initial	15-FEB-2024	156.000	ug/L
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Flush180	16-SEP-16	2.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Initial	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC02	Main- Fountain (Left) Across Rm. 105	Initial	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Initial	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Initial	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC04	Main- Fountain (Left) Across Rm. 111	Initial	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush	30-NOV-2023	2.090	ug/L
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush	30-NOV-2023	1.700	ug/L
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush	30-NOV-2023	1.760	ug/L
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush	30-NOV-2023	1.690	ug/L
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Initial	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Initial	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC06	Main- Fountain (Left) Across Rm. 115	Initial	30-NOV-2023	1.750	ug/L
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush	30-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Initial	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Initial	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC01	Main- Fountain (Left) Across Rm. 205	Initial	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Initial	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Initial	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC03	Main- Fountain (Left) Across Rm. 211	Initial	30-NOV-2023	1.000	ug/L
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush	30-NOV-2023	2.540	ug/L
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush	30-NOV-2023	1.580	ug/L
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush	30-NOV-2023	1.750	ug/L
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush	30-NOV-2023	1.760	ug/L
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush180	16-SEP-16	2.600	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush180	16-SEP-16	3.200	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush180	16-SEP-16	2.400	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush180	16-SEP-16	3.200	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush180	16-SEP-16	2.400	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush180	16-SEP-16	2.600	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC05	215				
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush180	16-SEP-16	2.400	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Flush180	16-SEP-16	2.400	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Initial	16-SEP-16	5.700	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Initial	16-SEP-16	5.700	ppb
52617	52617-2-HAL-WC05	Main- Fountain (Left) Outside Rm. 215	Initial	30-NOV-2023	2.720	ug/L
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Flush180	19-AUG-20	1.020	ug/L
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Initial	16-SEP-16	2.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Initial	16-SEP-16	1.000	ppb
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Initial	19-AUG-20	3.400	ug/L
52617	52617-1-HAL-F01	Main- Fountain (Right) Across Rm. 105	Initial	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Flush180	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Flush180	16-SEP-16	1.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Initial	16-SEP-16	2.000	ppb
52617	52617-1-HAL-WC03	Main- Fountain (Right) Across Rm. 111	Initial	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Flush180	16-SEP-16	2.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC02	205				
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Initial	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC02	Main- Fountain (Right) Across Rm. 205	Initial	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Initial	16-SEP-16	2.000	ppb
52617	52617-2-HAL-WC04	Main- Fountain (Right) Across Rm. 211	Initial	16-SEP-16	1.000	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	19-AUG-20	5.440	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	13-OCT-20	5.600	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	13-OCT-20	6.950	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	13-OCT-20	7.870	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	13-OCT-20	6.920	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	03-DEC-20	2.620	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	03-DEC-20	1.010	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	03-DEC-20	1.050	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	03-DEC-20	1.330	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	16-SEP-16	2.100	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	16-SEP-16	2.100	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	16-SEP-16	1.000	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Flush180	16-SEP-16	2.000	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Initial	19-AUG-20	5.680	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Initial	13-OCT-20	19.100	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Initial	03-DEC-20	4.610	ug/L
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Initial	16-SEP-16	5.300	ppb
52617	52617-2-HAL-F06	Main- Fountain (Right) Outside Rm. 215	Initial	16-SEP-16	5.300	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush	30-NOV-2023	1.000	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush180	04-FEB-21	1.730	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush180	08-JAN-21	1.830	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush180	08-JAN-21	5.350	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush180	08-JAN-21	2.830	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush180	08-JAN-21	2.910	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush180	04-FEB-21	1.140	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush180	04-FEB-21	1.190	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Flush180	04-FEB-21	1.470	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Initial	08-JAN-21	1.210	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Initial	04-FEB-21	1.820	ug/L
52617	52617-1-HAL-BF01	OUTSIDE ROOM 105	Initial	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Initial	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F01	Annex- Across From Room 222, Left Fountain	Initial	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Initial	16-SEP-16	2.000	ppb
54674	54674-2-HAL-F02	Annex- Across From Room 222, Right Fountain	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F03	Annex- Across From Room 120, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F03	Annex- Across From Room 120, Left Fountain	Flush	30-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54674	54674-1-HAL-F03	Annex- Across Froom Room 120, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F03	Annex- Across Froom Room 120, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F03	Annex- Across Froom Room 120, Left Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F03	Annex- Across Froom Room 120, Left Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F03	Annex- Across Froom Room 120, Left Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F03	Annex- Across Froom Room 120, Left Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F03	Annex- Across Froom Room 120, Left Fountain	Initial	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F03	Annex- Across Froom Room 120, Left Fountain	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Initial	16-SEP-16	2.000	ppb
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Initial	19-AUG-20	1.000	ug/L
54674	54674-1-HAL-F04	Annex- Across Froom Room 120, Right Fountain	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-131-F06	Annex- Inside Room 131	Flush180	19-AUG-20	1.000	ug/L
54674	54674-1-131-F06	Annex- Inside Room 131	Initial	19-AUG-20	1.000	ug/L
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Initial	16-SEP-16	2.000	ppb
54674	54674-1-133-S06	Annex- Inside Room 133, Center Sink	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-133-F05	Annex- Inside Room 133, East Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-F05	Annex- Inside Room 133, East Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-F05	Annex- Inside Room 133, East Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-F05	Annex- Inside Room 133, East Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-	Annex- Inside Room 133, East	Flush180	16-SEP-16	2.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Fountain				
54674	54674-1-133-F05	Annex- Inside Room 133, East Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-F05	Annex- Inside Room 133, East Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-F05	Annex- Inside Room 133, East Fountain	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-133-F05	Annex- Inside Room 133, East Fountain	Initial	16-SEP-16	2.000	ppb
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Initial	16-SEP-16	2.000	ppb
54674	54674-1-133-S07	Annex- Inside Room 133, West Sink	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Initial	16-SEP-16	2.000	ppb
54674	54674-1-134-S09	Annex- Inside Room 134, Center Sink	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Initial	16-SEP-16	2.000	ppb
54674	54674-1-134-F08	Annex- Inside Room 134, East Fountain	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-	Annex- Inside Room 134, West	Flush	30-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S10	Sink				
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Initial	16-SEP-16	2.000	ppb
54674	54674-1-134-S10	Annex- Inside Room 134, West Sink	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Initial	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS02	Annex- Kitchen, Center Sink	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-KIT-KS01	Annex- Kitchen, North Wall Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS01	Annex- Kitchen, North Wall Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS01	Annex- Kitchen, North Wall Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS01	Annex- Kitchen, North Wall Sink	Flush180	16-SEP-16	2.000	ppb
54674	54674-1-KIT-KS01	Annex- Kitchen, North Wall Sink	Initial	16-SEP-16	2.400	ppb
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush180	13-SEP-22	1.300	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Flush180	17-NOV-22	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Initial	13-SEP-22	8.670	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Initial	17-NOV-22	1.000	ug/L
54674	54674-1-131-BF01	Room 131 Bottle Filler	Initial	30-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54674	54674-1-131-F01	Room 131 Drinking Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Initial	13-SEP-22	1.030	ug/L
54674	54674-1-131-F01	Room 131 Drinking Fountain	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Initial	13-SEP-22	1.000	ug/L
54674	54674-1-131-S01	Room 131 Left Sink	Initial	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Flush	30-NOV-2023	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Flush180	13-SEP-22	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Initial	13-SEP-22	1.000	ug/L
54674	54674-1-131-S02	Room 131 Right Sink	Initial	30-NOV-2023	1.000	ug/L
55617	52617-1-HAL-WC07	Main - Fountain (Right) Outside Room 115	Flush	30-NOV-2023	3.810	ug/L
55617	52617-1-HAL-WC07	Main - Fountain (Right) Outside Room 115	Flush	30-NOV-2023	2.650	ug/L
55617	52617-1-HAL-WC07	Main - Fountain (Right) Outside Room 115	Flush	30-NOV-2023	2.830	ug/L
55617	52617-1-HAL-WC07	Main - Fountain (Right) Outside Room 115	Flush	30-NOV-2023	2.730	ug/L
55617	52617-1-HAL-WC07	Main - Fountain (Right) Outside Room 115	Initial	30-NOV-2023	3.520	ug/L
55617	52617-2-HAL-RBF02	Main - Fountain (Right) Outside Room 211	Flush	30-NOV-2023	1.000	ug/L
55617	52617-2-HAL-RBF02	Main - Fountain (Right) Outside Room 211	Flush	30-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
55617	52617-2-HAL-RBF02	Main - Fountain (Right) Outside Room 211	Flush	30-NOV-2023	1.000	ug/L
55617	52617-2-HAL-RBF02	Main - Fountain (Right) Outside Room 211	Flush	30-NOV-2023	1.000	ug/L
55617	52617-2-HAL-RBF02	Main - Fountain (Right) Outside Room 211	Initial	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-F03	Modular - Inside Room 135 Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-F03	Modular - Inside Room 135 Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-F03	Modular - Inside Room 135 Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-F03	Modular - Inside Room 135 Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-F03	Modular - Inside Room 135 Left Fountain	Initial	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-S04	Modular - Inside Room 135 Right Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-S04	Modular - Inside Room 135 Right Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-S04	Modular - Inside Room 135 Right Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-S04	Modular - Inside Room 135 Right Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M135-S04	Modular - Inside Room 135 Right Sink	Initial	30-NOV-2023	1.000	ug/L
55617	55617-1-HAL-RBF01	Modular - Outside Room 136	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-HAL-RBF01	Modular - Outside Room 136	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-HAL-RBF01	Modular - Outside Room 136	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-HAL-RBF01	Modular - Outside Room 136	Initial	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-F03	Modular- Inside Room M135, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F03	Modular- Inside Room M135, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F03	Modular- Inside Room M135, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F03	Modular- Inside Room M135, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F03	Modular- Inside Room M135, Left Fountain	Initial	16-SEP-16	2.000	ppb
55617	55617-1-M136-S04	Modular- Inside Room M135, Right Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-S04	Modular- Inside Room M135, Right Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-S04	Modular- Inside Room M135, Right Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-S04	Modular- Inside Room M135, Right Sink	Initial	16-SEP-16	2.900	ppb
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Initial	16-SEP-16	2.000	ppb
55617	55617-1-HAL-F06	Modular- Inside Room M136, Left Fountain	Initial	30-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	Fountain				
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Initial	16-SEP-16	2.000	ppb
55617	55617-1-M136-S01	Modular- Inside Room M136, Left Sink	Initial	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	1.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	1.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	1.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	1.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	21-OCT-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-HAL-F05	Modular- Inside Room M136, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-HAL-F05	Modular- Inside Room M136, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-HAL-F05	Modular- Inside Room M136, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Flush180	19-AUG-20	1.000	ug/L
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Initial	21-OCT-16	1.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Initial	21-OCT-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Initial	16-SEP-16	17.000	ppb
55617	55617-1-HAL-F05	Modular- Inside Room M136, Right Fountain	Initial	16-SEP-16	2.000	ppb
55617	55617-1-M136-F02	Modular- Inside Room M136, Right Fountain	Initial	19-AUG-20	1.000	ug/L
55617	55617-1-	Modular- Inside Room M136, Right	Initial	30-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	M136-F02	Fountain				
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Initial	16-SEP-16	2.000	ppb
55617	55617-1-M137-S08	Modular- Inside Room M137, Left Sink	Initial	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Flush180	19-AUG-20	1.000	ug/L
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Initial	16-SEP-16	2.000	ppb
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Initial	19-AUG-20	1.000	ug/L
55617	55617-1-M137-F07	Modular- Inside Room M137, Right Fountain	Initial	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Flush180	16-SEP-16	2.300	ppb
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Initial	16-SEP-16	2.000	ppb
55617	55617-1-M138-F10	Modular- Inside Room M138, Left Fountain	Initial	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Flush	30-NOV-2023	1.000	ug/L
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Flush180	16-SEP-16	2.100	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Flush180	16-SEP-16	2.000	ppb
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Initial	16-SEP-16	2.000	ppb
55617	55617-1-M138-S09	Modular- Inside Room M138, Right Sink	Initial	30-NOV-2023	1.000	ug/L