



Sep 10, 2024

MANIERRE

1420 N HUDSON AVE, Chicago IL 60610.

Dear **MANIERRE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

MANIERRE

1420 N HUDSON AVE, Chicago IL 60610.

Estimadas familias de **MANIERRE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	18-JUN-19	1.760	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	18-JUN-19	88.500	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	27-FEB-20	1.170	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	27-FEB-20	1.070	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	27-FEB-20	2.330	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	27-FEB-20	6.250	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Initial	18-JUN-19	17.300	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Initial	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Initial	27-FEB-20	1.000	ug/L
51167	51167-1-W-KIT-KS01	Main- Kitchen, Sink	Initial	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	18-JUN-19	3.850	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	18-JUN-19	4.410	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	18-JUN-19	4.250	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	18-JUN-19	2.420	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	27-FEB-20	9.550	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	27-FEB-20	4.010	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	27-FEB-20	1.310	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	27-FEB-20	1.000	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Flush180	02-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Initial	18-JUN-19	5.520	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Initial	07-APR-20	1.000	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Initial	27-FEB-20	5.860	ug/L
51167	51167-1-W-KIT-KS02	Main- Kitchen, Sink 2 Middle	Initial	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Flush180	18-JUN-19	4.460	ug/L
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Flush180	18-JUN-19	3.190	ug/L
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Flush180	18-JUN-19	1.590	ug/L
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Flush180	18-JUN-19	1.580	ug/L
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Initial	18-JUN-19	2.810	ug/L
51167	51167-1-W-KIT-KS03	Main- Kitchen, Sink 3	Initial	02-JUN-16	1.000	ppb
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Flush180	18-JUN-19	3.050	ug/L
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Initial	18-JUN-19	1.000	ug/L
51167	51167-1-W-HAL-F01	Main- Outside Room 106, Fountain	Initial	02-JUN-16	1.000	ppb
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Initial	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F03	Main- Outside Room 117, Fountain	Initial	02-JUN-16	1.000	ppb
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Flush180	02-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Initial	02-JUN-16	1.000	ppb
51167	51167-2-W-HAL-F01	Main- Outside Room 207, Fountain	Initial	18-JUN-19	1.000	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	15-SEP-17	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	15-SEP-17	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	15-SEP-17	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	02-JUN-16	23.500	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	28-JUL-16	33.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	18-JUN-19	3.850	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	18-JUN-19	3.820	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	18-JUN-19	4.600	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	18-JUN-19	9.440	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	27-FEB-20	1.200	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	27-FEB-20	2.930	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	27-FEB-20	3.440	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	27-FEB-20	2.610	ug/L
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	28-JUL-16	35.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	16-NOV-16	1.610	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	28-JUL-16	18.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	28-JUL-16	13.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	01-SEP-16	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	01-SEP-16	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	01-SEP-16	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	16-NOV-16	1.650	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	16-NOV-16	1.290	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	16-NOV-16	1.220	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Flush180	15-SEP-17	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Initial	15-SEP-17	7.200	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Initial	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Initial	18-JUN-19	7.010	ug/L
51167	51167-2-E-	Main- Outside Room 213, Fountain	Initial	27-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Fountain				
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Initial	28-JUL-16	10.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Initial	01-SEP-16	1.000	ppb
51167	51167-2-E-HAL-F02	Main- Outside Room 213, Fountain	Initial	16-NOV-16	2.300	ppb
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Flush180	04-AUG-20	1.000	ug/L
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Initial	02-JUN-16	1.000	ppb
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Initial	18-JUN-19	1.000	ug/L
51167	51167-2-E-HAL-F03	Main- Outside Room 217, Fountain	Initial	04-AUG-20	1.000	ug/L
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Flush180	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Flush180	04-AUG-20	1.000	ug/L
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Flush180	15-SEP-17	1.000	ppb
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Flush180	15-SEP-17	1.000	ppb
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Flush180	15-SEP-17	1.000	ppb
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Initial	18-JUN-19	1.000	ug/L
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Initial	04-AUG-20	1.000	ug/L
51167	51167-1-E-HAL-F02	Outside Main Office Fountain	Initial	15-SEP-17	4.060	ppb
54205	54205-2-W-HAL-F01	CPC- Inbetween Kitchen and Parent Room, Fountain	Flush180	04-AUG-20	1.000	ug/L
54205	54205-2-W-HAL-F01	CPC- Inbetween Kitchen and Parent Room, Fountain	Initial	04-AUG-20	1.000	ug/L
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-	CPC- Inside Room 001, Fountain	Flush180	18-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	001-F01					
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-001-F01	CPC- Inside Room 001, Fountain	Initial	18-JUN-19	1.150	ug/L
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S01	CPC- Inside Room 001, Sink	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-001-S02	CPC- Inside Room 001, Sink 2	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-002-F04	CPC- Inside Room 002, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-002-F04	CPC- Inside Room 002, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-002-F04	CPC- Inside Room 002, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-002-F04	CPC- Inside Room 002, Fountain	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	12-SEP-23	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	12-SEP-23	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	12-SEP-23	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	12-SEP-23	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	18-JUN-19	2.420	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	18-JUN-19	1.310	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	18-JUN-19	1.270	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	27-FEB-20	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	27-FEB-20	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	27-FEB-20	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	27-FEB-20	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	27-MAY-20	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	27-MAY-20	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	27-MAY-20	6.950	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Flush180	27-MAY-20	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Initial	12-SEP-23	1.000	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Initial	18-JUN-19	7.530	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Initial	27-FEB-20	6.050	ug/L
54205	54205-1-S-002-S01	CPC- Inside Room 002, Sink	Initial	27-MAY-20	2.770	ug/L
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-002-S02	CPC- Inside Room 002, Sink 2	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Flush180	04-AUG-20	1.000	ug/L
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-F01	CPC- Inside Room 003, Fountain	Initial	04-AUG-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-003-S01	CPC- Inside Room 003, Sink	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-004-F01	CPC- Inside Room 004, Fountain	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Flush180	01-JUN-16	7.210	ppb
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S01	CPC- Inside Room 004, Sink	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Flush180	18-JUN-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	004-S02					
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-004-S02	CPC- Inside Room 004, Sink 2	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-005-F01	CPC- Inside Room 005, Fountain	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S01	CPC- Inside Room 005, Sink	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-005-S02	CPC- Inside Room 005, Sink 2	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-F01	CPC- Inside Room 006, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-F01	CPC- Inside Room 006, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-F01	CPC- Inside Room 006, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-	CPC- Inside Room 006, Fountain	Flush180	18-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	006-F01					
54205	54205-1-S-006-F01	CPC- Inside Room 006, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-F01	CPC- Inside Room 006, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-F01	CPC- Inside Room 006, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-F01	CPC- Inside Room 006, Fountain	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-006-F01	CPC- Inside Room 006, Fountain	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S01	CPC- Inside Room 006, Sink	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-006-S02	CPC- Inside Room 006, Sink 2	Initial	18-JUN-19	1.400	ug/L
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-007-F01	CPC- Inside Room 007, Fountain	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Flush180	01-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Flush180	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S01	CPC- Inside Room 007, Sink	Initial	18-JUN-19	1.000	ug/L
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Flush180	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Flush180	18-JUN-19	1.010	ug/L
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Flush180	18-JUN-19	1.100	ug/L
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Flush180	18-JUN-19	1.880	ug/L
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Flush180	18-JUN-19	1.990	ug/L
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Initial	01-JUN-16	1.000	ppb
54205	54205-1-S-007-S02	CPC- Inside Room 007, Sink 2	Initial	18-JUN-19	2.320	ug/L