



**Sep 10, 2024**

**MARQUETTE**

**6550 S RICHMOND ST, Chicago IL 60629.**

Dear **MARQUETTE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**MARQUETTE**

**6550 S RICHMOND ST, Chicago IL 60629.**

Estimadas familias de **MARQUETTE:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51300	51300-1-110-S01	Main- Inside Room 110, East Sink 1	Flush180	22-JUN-16	1.000	ppb
51300	51300-1-110-S01	Main- Inside Room 110, East Sink 1	Flush180	22-JUN-16	0.980	ppb
51300	51300-1-110-S01	Main- Inside Room 110, East Sink 1	Flush180	22-JUN-16	0.818	ppb
51300	51300-1-110-S01	Main- Inside Room 110, East Sink 1	Flush180	22-JUN-16	1.230	ppb
51300	51300-1-110-S01	Main- Inside Room 110, East Sink 1	Initial	22-JUN-16	2.610	ppb
51300	51300-1-110-S02	Main- Inside Room 110, West Sink 2	Flush180	22-JUN-16	0.874	ppb
51300	51300-1-110-S02	Main- Inside Room 110, West Sink 2	Flush180	22-JUN-16	1.040	ppb
51300	51300-1-110-S02	Main- Inside Room 110, West Sink 2	Flush180	22-JUN-16	0.989	ppb
51300	51300-1-110-S02	Main- Inside Room 110, West Sink 2	Flush180	22-JUN-16	1.340	ppb
51300	51300-1-110-S02	Main- Inside Room 110, West Sink 2	Initial	22-JUN-16	3.000	ppb
51300	51300-1-110-S03	Main- Inside Room 110, Work Room Sink 3	Flush180	22-JUN-16	0.420	ppb
51300	51300-1-110-S03	Main- Inside Room 110, Work Room Sink 3	Flush180	22-JUN-16	1.110	ppb
51300	51300-1-110-S03	Main- Inside Room 110, Work Room Sink 3	Flush180	22-JUN-16	2.730	ppb
51300	51300-1-110-S03	Main- Inside Room 110, Work Room Sink 3	Flush180	22-JUN-16	0.609	ppb
51300	51300-1-110-S03	Main- Inside Room 110, Work Room Sink 3	Initial	22-JUN-16	2.910	ppb
51300	51300-1-115-F01	Main- Inside Room 115, Fountain	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-F01	Main- Inside Room 115, Fountain	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-F01	Main- Inside Room 115, Fountain	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-F01	Main- Inside Room 115, Fountain	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-F01	Main- Inside Room 115, Fountain	Initial	16-SEP-22	1.000	ug/L
51300	51300-1-115-S01	Main- Inside Room 115, Left Sink	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-S01	Main- Inside Room 115, Left Sink	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-S01	Main- Inside Room 115, Left Sink	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-S01	Main- Inside Room 115, Left Sink	Initial	16-SEP-22	1.720	ug/L
51300	51300-1-115-S02	Main- Inside Room 115, Right Sink	Flush180	16-SEP-22	1.420	ug/L
51300	51300-1-115-S02	Main- Inside Room 115, Right Sink	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-S02	Main- Inside Room 115, Right Sink	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-S02	Main- Inside Room 115, Right Sink	Flush180	16-SEP-22	1.000	ug/L
51300	51300-1-115-S02	Main- Inside Room 115, Right Sink	Initial	16-SEP-22	2.340	ug/L
51300	51300-2-HAL-F06	Main- Outside Boys Room, Fountain 1	Flush180	28-MAY-16	1.470	ppb
51300	51300-2-HAL-F06	Main- Outside Boys Room, Fountain 1	Flush180	28-MAY-16	1.330	ppb
51300	51300-2-HAL-F06	Main- Outside Boys Room, Fountain 1	Flush180	28-MAY-16	1.270	ppb
51300	51300-2-HAL-F06	Main- Outside Boys Room, Fountain 1	Flush180	28-MAY-16	1.090	ppb
51300	51300-2-HAL-F06	Main- Outside Boys Room, Fountain 1	Initial	28-MAY-16	0.929	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51300	51300-2-HAL-F07	Main- Outside Boys Room, Fountain 2	Flush180	28-MAY-16	0.954	ppb
51300	51300-2-HAL-F07	Main- Outside Boys Room, Fountain 2	Flush180	28-MAY-16	0.605	ppb
51300	51300-2-HAL-F07	Main- Outside Boys Room, Fountain 2	Flush180	28-MAY-16	0.798	ppb
51300	51300-2-HAL-F07	Main- Outside Boys Room, Fountain 2	Flush180	28-MAY-16	0.910	ppb
51300	51300-2-HAL-F07	Main- Outside Boys Room, Fountain 2	Initial	28-MAY-16	0.970	ppb
51300	51300-2-HAL-F08	Main- Outside Boys Room, Fountain 3	Flush180	28-MAY-16	0.997	ppb
51300	51300-2-HAL-F08	Main- Outside Boys Room, Fountain 3	Flush180	28-MAY-16	0.944	ppb
51300	51300-2-HAL-F08	Main- Outside Boys Room, Fountain 3	Flush180	28-MAY-16	0.916	ppb
51300	51300-2-HAL-F08	Main- Outside Boys Room, Fountain 3	Flush180	28-MAY-16	0.966	ppb
51300	51300-2-HAL-F08	Main- Outside Boys Room, Fountain 3	Initial	28-MAY-16	1.050	ppb
51300	51300-1-HAL-F07	Main- Outside Room 103, Fountain 1	Flush180	28-MAY-16	0.997	ppb
51300	51300-1-HAL-F07	Main- Outside Room 103, Fountain 1	Flush180	28-MAY-16	0.944	ppb
51300	51300-1-HAL-F07	Main- Outside Room 103, Fountain 1	Flush180	28-MAY-16	1.130	ppb
51300	51300-1-HAL-F07	Main- Outside Room 103, Fountain 1	Flush180	28-MAY-16	0.751	ppb
51300	51300-1-HAL-F07	Main- Outside Room 103, Fountain 1	Initial	28-MAY-16	0.713	ppb
51300	51300-1-HAL-F08	Main- Outside Room 103, Fountain 2	Flush180	28-MAY-16	1.190	ppb
51300	51300-1-HAL-F08	Main- Outside Room 103, Fountain 2	Flush180	28-MAY-16	1.150	ppb
51300	51300-1-HAL-F08	Main- Outside Room 103, Fountain 2	Flush180	28-MAY-16	1.180	ppb
51300	51300-1-HAL-F08	Main- Outside Room 103, Fountain 2	Flush180	28-MAY-16	1.180	ppb
51300	51300-1-HAL-F08	Main- Outside Room 103, Fountain 2	Initial	28-MAY-16	1.070	ppb
51300	51300-1-HAL-F05	Main- Outside Room 107, Fountain	Flush180	28-MAY-16	0.787	ppb
51300	51300-1-HAL-F05	Main- Outside Room 107, Fountain	Flush180	28-MAY-16	0.378	ppb
51300	51300-1-HAL-F05	Main- Outside Room 107, Fountain	Flush180	28-MAY-16	0.444	ppb
51300	51300-1-HAL-F05	Main- Outside Room 107, Fountain	Flush180	28-MAY-16	0.447	ppb
51300	51300-1-HAL-F05	Main- Outside Room 107, Fountain	Initial	28-MAY-16	1.150	ppb
51300	51300-1-HAL-F02	Main- Outside Room 115, Fountain 1	Flush180	28-MAY-16	0.367	ppb
51300	51300-1-HAL-F02	Main- Outside Room 115, Fountain 1	Flush180	28-MAY-16	0.384	ppb
51300	51300-1-HAL-F02	Main- Outside Room 115, Fountain 1	Flush180	28-MAY-16	0.422	ppb
51300	51300-1-HAL-F02	Main- Outside Room 115, Fountain 1	Flush180	28-MAY-16	0.366	ppb
51300	51300-1-HAL-F02	Main- Outside Room 115, Fountain 1	Initial	28-MAY-16	0.321	ppb
51300	51300-1-HAL-F03	Main- Outside Room 115, Fountain 2	Flush180	28-MAY-16	0.319	ppb
51300	51300-1-HAL-F03	Main- Outside Room 115, Fountain 2	Flush180	28-MAY-16	0.304	ppb
51300	51300-1-HAL-F03	Main- Outside Room 115, Fountain 2	Flush180	28-MAY-16	0.320	ppb
51300	51300-1-HAL-F03	Main- Outside Room 115, Fountain 2	Flush180	28-MAY-16	0.324	ppb
51300	51300-1-HAL-F03	Main- Outside Room 115, Fountain 2	Initial	28-MAY-16	0.429	ppb
51300	51300-1-HAL-F04	Main- Outside Room 115, Fountain 3	Flush180	28-MAY-16	0.601	ppb
51300	51300-1-HAL-F04	Main- Outside Room 115, Fountain 3	Flush180	28-MAY-16	0.558	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51300	51300-1-HAL-F04	Main- Outside Room 115, Fountain 3	Flush180	28-MAY-16	0.538	ppb
51300	51300-1-HAL-F04	Main- Outside Room 115, Fountain 3	Flush180	28-MAY-16	1.020	ppb
51300	51300-1-HAL-F04	Main- Outside Room 115, Fountain 3	Initial	28-MAY-16	1.750	ppb
51300	51300-1-HAL-F01	Main- Outside Room 117, Fountain	Flush180	28-MAY-16	0.996	ppb
51300	51300-1-HAL-F01	Main- Outside Room 117, Fountain	Flush180	28-MAY-16	0.691	ppb
51300	51300-1-HAL-F01	Main- Outside Room 117, Fountain	Flush180	28-MAY-16	0.881	ppb
51300	51300-1-HAL-F01	Main- Outside Room 117, Fountain	Flush180	28-MAY-16	0.659	ppb
51300	51300-1-HAL-F01	Main- Outside Room 117, Fountain	Flush180	05-AUG-20	1.000	ug/L
51300	51300-1-HAL-F01	Main- Outside Room 117, Fountain	Initial	28-MAY-16	0.900	ppb
51300	51300-1-HAL-F01	Main- Outside Room 117, Fountain	Initial	05-AUG-20	1.780	ug/L
51300	51300-2-HAL-F02	Main- Outsode Room 215, Fountain 1	Flush180	28-MAY-16	0.867	ppb
51300	51300-2-HAL-F02	Main- Outsode Room 215, Fountain 1	Flush180	28-MAY-16	0.972	ppb
51300	51300-2-HAL-F02	Main- Outsode Room 215, Fountain 1	Flush180	28-MAY-16	0.702	ppb
51300	51300-2-HAL-F02	Main- Outsode Room 215, Fountain 1	Flush180	28-MAY-16	0.758	ppb
51300	51300-2-HAL-F02	Main- Outsode Room 215, Fountain 1	Initial	28-MAY-16	0.946	ppb
51300	51300-2-HAL-F03	Main- Outsode Room 215, Fountain 2	Flush180	28-MAY-16	0.524	ppb
51300	51300-2-HAL-F03	Main- Outsode Room 215, Fountain 2	Flush180	28-MAY-16	0.392	ppb
51300	51300-2-HAL-F03	Main- Outsode Room 215, Fountain 2	Flush180	28-MAY-16	0.393	ppb
51300	51300-2-HAL-F03	Main- Outsode Room 215, Fountain 2	Flush180	28-MAY-16	0.413	ppb
51300	51300-2-HAL-F03	Main- Outsode Room 215, Fountain 2	Initial	28-MAY-16	0.639	ppb
51300	51300-2-HAL-F04	Main- Outsode Room 215, Fountain 3	Flush180	28-MAY-16	0.329	ppb
51300	51300-2-HAL-F04	Main- Outsode Room 215, Fountain 3	Flush180	28-MAY-16	0.304	ppb
51300	51300-2-HAL-F04	Main- Outsode Room 215, Fountain 3	Flush180	28-MAY-16	0.287	ppb
51300	51300-2-HAL-F04	Main- Outsode Room 215, Fountain 3	Flush180	28-MAY-16	0.304	ppb
51300	51300-2-HAL-F04	Main- Outsode Room 215, Fountain 3	Initial	28-MAY-16	0.204	ppb
51300	51300-2-HAL-F01	Main- Outsode Room 217, Fountain	Flush180	28-MAY-16	0.607	ppb
51300	51300-2-HAL-F01	Main- Outsode Room 217, Fountain	Flush180	28-MAY-16	0.614	ppb
51300	51300-2-HAL-F01	Main- Outsode Room 217, Fountain	Flush180	28-MAY-16	0.655	ppb
51300	51300-2-HAL-F01	Main- Outsode Room 217, Fountain	Flush180	28-MAY-16	0.654	ppb
51300	51300-2-HAL-F01	Main- Outsode Room 217, Fountain	Initial	28-MAY-16	0.866	ppb
51300	51300-2-HAL-F05	Main- Outsode room 205, Fountain	Flush180	28-MAY-16	1.140	ppb
51300	51300-2-HAL-F05	Main- Outsode room 205, Fountain	Flush180	28-MAY-16	1.150	ppb
51300	51300-2-HAL-F05	Main- Outsode room 205, Fountain	Flush180	28-MAY-16	0.975	ppb
51300	51300-2-HAL-F05	Main- Outsode room 205, Fountain	Flush180	28-MAY-16	1.350	ppb
51300	51300-2-HAL-F05	Main- Outsode room 205, Fountain	Flush180	05-AUG-20	1.070	ug/L
51300	51300-2-HAL-F05	Main- Outsode room 205, Fountain	Initial	28-MAY-16	1.430	ppb
51300	51300-2-HAL-F05	Main- Outsode room 205, Fountain	Initial	05-AUG-20	1.490	ug/L
52497	52497-1-HAL-	Annex- Inside Main Entrance,	Flush180	28-MAY-16	0.181	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Fountain				
52497	52497-1-HAL-F02	Annex- Inside Main Entrance, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-HAL-F02	Annex- Inside Main Entrance, Fountain	Flush180	28-MAY-16	0.271	ppb
52497	52497-1-HAL-F02	Annex- Inside Main Entrance, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-HAL-F02	Annex- Inside Main Entrance, Fountain	Initial	28-MAY-16	1.000	ppb
52497	52497-1-CAF-F04	Annex- North Lunchroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-CAF-F04	Annex- North Lunchroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-CAF-F04	Annex- North Lunchroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-CAF-F04	Annex- North Lunchroom, Fountain	Initial	28-MAY-16	1.000	ppb
52497	52497-1-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-2-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-2-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-2-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-2-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-HAL-F01	Annex- Outside Boys Restroom, Fountain	Flush180	05-AUG-20	1.000	ug/L
52497	52497-1-HAL-F01	Annex- Outside Boys Restroom, Fountain	Initial	28-MAY-16	1.000	ppb
52497	52497-2-HAL-F01	Annex- Outside Boys Restroom, Fountain	Initial	28-MAY-16	1.000	ppb
52497	52497-1-HAL-F01	Annex- Outside Boys Restroom, Fountain	Initial	05-AUG-20	1.000	ug/L
52497	52497-2-HAL-F02	Annex- Outside Boys Restroom, Fountain 2	Flush180	05-AUG-20	1.000	ug/L
52497	52497-2-HAL-F02	Annex- Outside Boys Restroom, Fountain 2	Initial	28-MAY-16	1.000	ppb
52497	52497-2-HAL-F02	Annex- Outside Boys Restroom, Fountain 2	Initial	05-AUG-20	1.000	ug/L
52497	52497-1-CAF-F05	Annex- South Lunchroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-CAF-F05	Annex- South Lunchroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-CAF-F05	Annex- South Lunchroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-CAF-F05	Annex- South Lunchroom, Fountain	Flush180	28-MAY-16	1.000	ppb
52497	52497-1-CAF-F05	Annex- South Lunchroom, Fountain	Initial	28-MAY-16	1.000	ppb