



**Sep 10, 2024**

**MARSHALL HS**

**3250 W ADAMS ST, Chicago IL 60624.**

Dear **MARSHALL HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**MARSHALL HS**

**3250 W ADAMS ST, Chicago IL 60624.**

Estimadas familias de **MARSHALL HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Initial	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC12	Main- 1st Floor Next to Womens Staff Toilets, Nort	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC13	Main- 1st Floor Next to Womens Staff Toilets, Sout	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC13	Main- 1st Floor Next to Womens Staff Toilets, Sout	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC13	Main- 1st Floor Next to Womens Staff Toilets, Sout	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC13	Main- 1st Floor Next to Womens Staff Toilets, Sout	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC13	Main- 1st Floor Next to Womens Staff Toilets, Sout	Initial	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Flush180	22-SEP-23	1.110	ug/L
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Initial	22-SEP-23	2.020	ug/L
51566	51566-3-HAL-F02	Main- Across From Room 324, Left Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-3-HAL-RBF01	Main- Across From Room 331, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-RBF01	Main- Across From Room 331, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-RBF01	Main- Across From Room 331, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-RBF01	Main- Across From Room 331, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F03	Main- Across From Room 331, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F03	Main- Across From Room 331, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F03	Main- Across From Room 331, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F03	Main- Across From Room 331, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-RBF01	Main- Across From Room 331, Left Fountain	Initial	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F03	Main- Across From Room 331, Left Fountain	Initial	26-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Initial	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F04	Main- Across From Room 331, Right Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush	07-NOV-2023	1.450	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush	07-NOV-2023	1.680	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush	07-NOV-2023	2.090	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush	07-NOV-2023	2.230	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush	13-OCT-2023	3.930	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush	13-OCT-2023	3.600	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush	13-OCT-2023	4.020	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush	13-OCT-2023	4.570	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush180	22-SEP-23	3.900	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush180	22-SEP-23	4.630	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush180	22-SEP-23	5.100	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush180	22-SEP-23	6.450	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Initial	22-SEP-23	6.180	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Initial	26-OCT-16	2.300	ppb
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Initial	07-NOV-2023	1.170	ug/L
51566	51566-3-HAL-F01	Main- Across From Room324, Right Fountain	Initial	13-OCT-2023	5.270	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush	29-NOV-2023	1.000	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush	29-NOV-2023	1.000	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush	29-NOV-2023	1.680	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush	29-NOV-2023	1.700	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush	13-OCT-2023	66.600	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush	13-OCT-2023	27.800	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush	13-OCT-2023	21.100	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush	13-OCT-2023	14.600	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush180	26-OCT-16	3.200	ppb
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush180	22-SEP-23	1.530	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush180	22-SEP-23	2.990	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush180	22-SEP-23	2.130	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Flush180	22-SEP-23	5.930	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Initial	26-OCT-16	11.000	ppb
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Initial	22-SEP-23	18.100	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Initial	29-NOV-2023	3.060	ug/L
51566	51566-1-CAF-F09	Main- Cafeteria, North Wall, West Fountain	Initial	13-OCT-2023	75.100	ug/L
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Flush180	26-OCT-16	2.200	ppb
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Flush180	26-OCT-16	3.000	ppb
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Flush180	26-OCT-16	4.400	ppb
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Initial	26-OCT-16	2.500	ppb
51566	51566-1-147-S34	Main- Culinary Arts Room 147, East Wall Sink	Initial	22-SEP-23	1.970	ug/L
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Initial	26-OCT-16	1.000	ppb
51566	51566-1-147-S32	Main- Culinary Arts Room 147, South Wall, Left Fau	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Flush180	22-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S33	South Wall, Right Fa				
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Initial	26-OCT-16	1.000	ppb
51566	51566-1-147-S33	Main- Culinary Arts Room 147, South Wall, Right Fa	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-135-S27	Main- Inside Class D, Northern North Wall, Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S27	Main- Inside Class D, Northern North Wall, Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S27	Main- Inside Class D, Northern North Wall, Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S27	Main- Inside Class D, Northern North Wall, Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S27	Main- Inside Class D, Northern North Wall, Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-135-S28	Main- Inside Class D, Sothern North Wall, Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S28	Main- Inside Class D, Sothern North Wall, Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S28	Main- Inside Class D, Sothern North Wall, Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S28	Main- Inside Class D, Sothern North Wall, Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S28	Main- Inside Class D, Sothern North Wall, Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Flush180	22-SEP-23	2.120	ug/L
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Flush180	22-SEP-23	1.110	ug/L
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Flush180	22-SEP-23	1.150	ug/L
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Flush180	26-OCT-16	2.400	ppb
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Flush180	26-OCT-16	2.400	ppb
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Flush180	26-OCT-16	2.100	ppb
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Initial	22-SEP-23	1.610	ug/L
51566	51566-2-GYM-F07	Main- Inside Gym 233, Fountain	Initial	26-OCT-16	3.200	ppb
51566	51566-1-135-S20	Main- Inside Room 135 Class B, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S20	Main- Inside Room 135 Class B, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S20	Main- Inside Room 135 Class B, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S20	Main- Inside Room 135 Class B, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S20	Main- Inside Room 135 Class B, North Wall Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-135-S21	Main- Inside Room 135 Class B, West Wall, North Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S21	Main- Inside Room 135 Class B, West Wall, North Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S21	Main- Inside Room 135 Class B, West Wall, North Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S21	Main- Inside Room 135 Class B, West Wall, North Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S21	Main- Inside Room 135 Class B, West Wall, North Si	Initial	26-OCT-16	1.000	ppb
51566	51566-1-135-S22	Main- Inside Room 135 Class B, West Wall, South Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-	Main- Inside Room 135 Class B,	Flush180	26-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S22	West Wall, South Si				
51566	51566-1-135-S22	Main- Inside Room 135 Class B, West Wall, South Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S22	Main- Inside Room 135 Class B, West Wall, South Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S22	Main- Inside Room 135 Class B, West Wall, South Si	Initial	26-OCT-16	1.000	ppb
51566	51566-1-135-S24	Main- Inside Room 135 Class C, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S24	Main- Inside Room 135 Class C, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S24	Main- Inside Room 135 Class C, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S24	Main- Inside Room 135 Class C, North Wall Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-135-S23	Main- Inside Room 135 Class C, South Wall Single S	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S23	Main- Inside Room 135 Class C, South Wall Single S	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S23	Main- Inside Room 135 Class C, South Wall Single S	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S23	Main- Inside Room 135 Class C, South Wall Single S	Initial	26-OCT-16	1.000	ppb
51566	51566-1-135-S25	Main- Inside Room 135 Class C, South Wall, East Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S25	Main- Inside Room 135 Class C, South Wall, East Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S25	Main- Inside Room 135 Class C, South Wall, East Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S25	Main- Inside Room 135 Class C, South Wall, East Si	Initial	26-OCT-16	1.000	ppb
51566	51566-1-135-S26	Main- Inside Room 135 Class C, South Wall, West Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S26	Main- Inside Room 135 Class C, South Wall, West Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S26	Main- Inside Room 135 Class C, South Wall, West Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-135-S26	Main- Inside Room 135 Class C, South Wall, West Si	Initial	26-OCT-16	1.000	ppb
51566	51566-1-137-S17	Main- Inside Room 137 Class A, South Wall, East Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-137-S17	Main- Inside Room 137 Class A, South Wall, East Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-137-S17	Main- Inside Room 137 Class A, South Wall, East Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-137-S17	Main- Inside Room 137 Class A, South Wall, East Si	Initial	26-OCT-16	1.000	ppb
51566	51566-1-137-S16	Main- Inside Room 137 Class A, South Wall, West Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-137-S16	Main- Inside Room 137 Class A, South Wall, West Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-137-S16	Main- Inside Room 137 Class A, South Wall, West Si	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-137-S16	Main- Inside Room 137 Class A, South Wall, West Si	Initial	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS03	Main- Kitchen, East Wall, Center Sink	Initial	22-SEP-23	1.260	ug/L
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Flush180	22-SEP-23	2.430	ug/L
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS02	Main- Kitchen, East Wall, North Sink	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS04	Main- Kitchen, East Wall, South Sink	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	26-OCT-16	2.300	ppb
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	26-OCT-16	4.000	ppb
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Initial	26-OCT-16	3.100	ppb
51566	51566-1-KIT-KS01	Main- Kitchen, North Wall Sink	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush	13-OCT-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush180	22-SEP-23	5.200	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush180	22-SEP-23	44.000	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Flush180	22-SEP-23	1.150	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Initial	22-SEP-23	1.940	ug/L
51566	51566-1-KIT-KS06	Main- Kitchen, South Wall, Center Sink	Initial	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS05-0051566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush180	22-SEP-23	15.700	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Flush180	22-SEP-23	1.950	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS05	Main- Kitchen, South Wall, East Sink	Initial	13-OCT-2023	1.000	ug/L
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Flush180	22-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS07	Sink				
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Initial	26-OCT-16	2.100	ppb
51566	51566-1-KIT-KS07	Main- Kitchen, South Wall, West Sink	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	22-SEP-23	1.460	ug/L
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	22-SEP-23	1.650	ug/L
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	22-SEP-23	1.530	ug/L
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC14	Main- Next to Office 125, East Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC15	Main- Next to Office 125, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC15	Main- Next to Office 125, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC15	Main- Next to Office 125, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC15	Main- Next to Office 125, West Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F09	Main- Next to Room 230, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F09	Main- Next to Room 230, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F09	Main- Next to Room 230, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F09	Main- Next to Room 230, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F09	Main- Next to Room 230, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F09	Main- Next to Room 230, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F09	Main- Next to Room 230, Left Fountain	Initial	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F09	Main- Next to Room 230, Left Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-2-HAL-RBF01	Main- Next to Room 230, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-RBF01	Main- Next to Room 230, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-RBF01	Main- Next to Room 230, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-RBF01	Main- Next to Room 230, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F08	Main- Next to Room 230, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F08	Main- Next to Room 230, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F08	Main- Next to Room 230, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F08	Main- Next to Room 230, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-RBF01	Main- Next to Room 230, Right Fountain	Initial	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-	Main- Next to Room 230, Right	Initial	26-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F08	Fountain				
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Initial	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F04	Main- Next to Room 235, Left Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Flush180	22-SEP-23	1.100	ug/L
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Initial	22-SEP-23	1.200	ug/L
51566	51566-2-HAL-F03	Main- Next to Room 235, Right Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	29-NOV-2023	1.100	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	29-NOV-2023	1.000	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	29-NOV-2023	2.100	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	29-NOV-2023	1.110	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	07-NOV-2023	5.520	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	07-NOV-2023	4.210	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	07-NOV-2023	4.230	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	07-NOV-2023	14.000	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	13-OCT-2023	13.900	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	13-OCT-2023	16.400	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	13-OCT-2023	16.600	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush	13-OCT-2023	12.600	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush180	22-SEP-23	38.200	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush180	22-SEP-23	51.900	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush180	22-SEP-23	33.000	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush180	22-SEP-23	19.300	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush180	26-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Initial	22-SEP-23	5.710	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Initial	26-OCT-16	2.600	ppb
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Initial	29-NOV-2023	1.130	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Initial	07-NOV-2023	5.620	ug/L
51566	51566-2-HAL-F02	Main- Next to Room 252, Left Fountain	Initial	13-OCT-2023	14.900	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	07-NOV-2023	39.500	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	07-NOV-2023	31.700	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	07-NOV-2023	25.000	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	07-NOV-2023	16.500	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	29-NOV-2023	4.400	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	29-NOV-2023	4.560	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	29-NOV-2023	4.690	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	29-NOV-2023	5.230	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	13-OCT-2023	11.000	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	13-OCT-2023	11.400	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	13-OCT-2023	10.200	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	13-OCT-2023	9.760	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	02-MAY-2024	7.910	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	02-MAY-2024	8.140	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	02-MAY-2024	7.330	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush	02-MAY-2024	6.420	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush180	22-SEP-23	14.100	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush180	22-SEP-23	16.300	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush180	22-SEP-23	23.600	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush180	22-SEP-23	27.000	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Flush180	26-OCT-16	2.400	ppb
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Initial	22-SEP-23	8.760	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Initial	26-OCT-16	3.700	ppb
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Initial	07-NOV-2023	33.100	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Initial	29-NOV-2023	3.640	ug/L
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Initial	13-OCT-2023	11.400	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51566	51566-2-HAL-F01	Main- Next to Room 252, Right Fountain	Initial	02-MAY-2024	6.410	ug/L
51566	51566-3-HAL-F05	Main- Next to Room 337, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F05	Main- Next to Room 337, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F05	Main- Next to Room 337, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F05	Main- Next to Room 337, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F05	Main- Next to Room 337, Left Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Initial	22-SEP-23	1.200	ug/L
51566	51566-3-HAL-F06	Main- Next to Room 337, Right Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Flush180	22-SEP-23	2.100	ug/L
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Flush180	22-SEP-23	1.770	ug/L
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Flush180	22-SEP-23	1.720	ug/L
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Flush180	22-SEP-23	1.620	ug/L
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Flush180	26-OCT-16	2.600	ppb
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Flush180	26-OCT-16	2.400	ppb
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Flush180	26-OCT-16	2.700	ppb
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Flush180	26-OCT-16	2.200	ppb
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Initial	22-SEP-23	2.180	ug/L
51566	51566-3-HAL-F07	Main- Next to Room 352, Left Fountain	Initial	26-OCT-16	3.500	ppb
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Flush180	22-SEP-23	3.240	ug/L
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Flush180	22-SEP-23	2.730	ug/L
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Flush180	22-SEP-23	2.630	ug/L
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Flush180	22-SEP-23	2.370	ug/L
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Flush180	26-OCT-16	3.100	ppb
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Flush180	26-OCT-16	2.700	ppb
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Flush180	26-OCT-16	2.800	ppb
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Flush180	26-OCT-16	2.500	ppb
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Initial	22-SEP-23	3.830	ug/L
51566	51566-3-HAL-F08	Main- Next to Room 352, Right Fountain	Initial	26-OCT-16	3.300	ppb
51566	51566-1-HAL-WC10	Main- Outside Cafeteria, North Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-	Main- Outside Cafeteria, North	Flush180	26-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC10	Fountain				
51566	51566-1-HAL-WC10	Main- Outside Cafeteria, North Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC10	Main- Outside Cafeteria, North Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC10	Main- Outside Cafeteria, North Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC10	Main- Outside Cafeteria, North Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC10	Main- Outside Cafeteria, North Fountain	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-WC10	Main- Outside Cafeteria, North Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-1-HAL-WC10	Main- Outside Cafeteria, North Fountain	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-HAL-F18	Main- Outside Class B, North Wall, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-F18	Main- Outside Class B, North Wall, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-F18	Main- Outside Class B, North Wall, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-F18	Main- Outside Class B, North Wall, East Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-F18	Main- Outside Class B, North Wall, East Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-1-HAL-F19	Main- Outside Class B, North Wall, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-F19	Main- Outside Class B, North Wall, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-F19	Main- Outside Class B, North Wall, West Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-HAL-F19	Main- Outside Class B, North Wall, West Fountain	Initial	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F11	Main- Outside Room 223, Left Fountain	Flush180	26-OCT-16	2.700	ppb
51566	51566-2-HAL-F11	Main- Outside Room 223, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F11	Main- Outside Room 223, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F11	Main- Outside Room 223, Left Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F11	Main- Outside Room 223, Left Fountain	Initial	26-OCT-16	2.300	ppb
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	29-NOV-2023	1.380	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	29-NOV-2023	1.000	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	29-NOV-2023	2.230	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	07-NOV-2023	6.120	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	07-NOV-2023	2.330	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	07-NOV-2023	4.120	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	07-NOV-2023	2.670	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	13-OCT-2023	11.900	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	13-OCT-2023	8.740	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	13-OCT-2023	5.340	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush	13-OCT-2023	4.210	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush180	22-SEP-23	3.930	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush180	22-SEP-23	9.260	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F12	Fountain				
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush180	22-SEP-23	2.680	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush180	22-SEP-23	1.460	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush180	26-OCT-16	2.200	ppb
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Flush180	26-OCT-16	1.000	ppb
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Initial	22-SEP-23	23.100	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Initial	26-OCT-16	2.400	ppb
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Initial	29-NOV-2023	4.390	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Initial	07-NOV-2023	4.710	ug/L
51566	51566-2-HAL-F12	Main- Outside Room 223, Right Fountain	Initial	13-OCT-2023	15.300	ug/L
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-TL-S30	Main- Teachers Lounge, South Wall, Center Sink	Initial	22-SEP-23	1.250	ug/L
51566	51566-1-TL-S29	Main- Teachers Lounge, South Wall, East Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S29	Main- Teachers Lounge, South Wall, East Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S29	Main- Teachers Lounge, South Wall, East Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S29	Main- Teachers Lounge, South Wall, East Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S29	Main- Teachers Lounge, South Wall, East Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S29	Main- Teachers Lounge, South Wall, East Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S29	Main- Teachers Lounge, South Wall, East Sink	Initial	26-OCT-16	1.000	ppb
51566	51566-1-TL-S29	Main- Teachers Lounge, South Wall, East Sink	Initial	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Flush180	22-SEP-23	1.000	ug/L
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Flush180	26-OCT-16	2.700	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Flush180	26-OCT-16	1.000	ppb
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Initial	26-OCT-16	4.500	ppb
51566	51566-1-TL-S31	Main- Teachers Lounge, South Wall, West Sink	Initial	22-SEP-23	1.000	ug/L