



Sep 10, 2024

MASON

4217 W 18TH ST, Chicago IL 60623.

Dear **MASON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

MASON

4217 W 18TH ST, Chicago IL 60623.

Estimadas familias de **MASON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51210	51210-1-HAL-WC05	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC05	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC05	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC05	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC05	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC06	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC06	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC06	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC06	1st FL Corridor addition Across from 129	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush	06-OCT-2023	1.030	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush	06-OCT-2023	1.150	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush180	20-SEP-23	6.300	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush180	20-SEP-23	4.600	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush180	20-SEP-23	4.880	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush180	20-SEP-23	3.320	ug/L
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Flush180	20-SEP-23	1.080	ug/L
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Initial	20-SEP-23	7.810	ug/L
51210	51210-1-HAL-F02	1st FL Corridor addition Across from 149	Initial	20-SEP-23	1.110	ug/L
51210	51210-1-HAL-F01	1st FL Corridor addition Across from 149	Initial	06-OCT-2023	1.810	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	20-SEP-23	1.480	ug/L
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	20-SEP-23	1.180	ug/L
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-WC04	1st FL NE Corridor Across 114 Main Building	Initial	20-SEP-23	1.700	ug/L
51210	51210-1-HAL-WC03	1st FL NE Corridor Across 114 Main Building	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush	06-OCT-2023	3.280	ug/L
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush	06-OCT-2023	3.960	ug/L
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush	06-OCT-2023	3.270	ug/L
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush	06-OCT-2023	3.680	ug/L
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC02	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC02	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC02	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC02	1st FI SE Corridor by 103 Main Building	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush180	20-AUG-20	3.470	ug/L
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush180	20-SEP-23	3.170	ug/L
51210	51210-1-HAL-WC01	1st FI SE Corridor by 103 Main Building	Flush180	20-SEP-23	2.680	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51210	51210-1-HAL-WC01	1st Fl SE Corridor by 103 Main Building	Flush180	20-SEP-23	8.020	ug/L
51210	51210-1-HAL-WC01	1st Fl SE Corridor by 103 Main Building	Flush180	20-SEP-23	8.650	ug/L
51210	51210-1-HAL-WC01	1st Fl SE Corridor by 103 Main Building	Initial	20-AUG-20	1.140	ug/L
51210	51210-1-HAL-WC01	1st Fl SE Corridor by 103 Main Building	Initial	20-SEP-23	1.910	ug/L
51210	51210-1-HAL-WC01	1st Fl SE Corridor by 103 Main Building	Initial	06-OCT-2023	4.920	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Flush	06-OCT-2023	2.820	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Flush	06-OCT-2023	2.290	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Flush	06-OCT-2023	3.310	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Flush	06-OCT-2023	1.310	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Flush180	20-SEP-23	7.420	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Flush180	20-SEP-23	4.020	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Flush180	20-SEP-23	7.050	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Flush180	20-SEP-23	4.520	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Initial	20-SEP-23	8.420	ug/L
51210	51210-1-HAL-RBF01	1st Fl SE Corridor by 103 Main Building, Rftrofitted Bottle Filler	Initial	06-OCT-2023	1.220	ug/L
51210	51210-2-HAL-WC05	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	6.930	ppb
51210	51210-2-HAL-WC05	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC05	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC05	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	10.400	ppb
51210	51210-2-HAL-WC05	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	11.900	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC06	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC07	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC07	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC07	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC07	2nd FL Corridor Addition Across from 223	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC02	2nd FL Corridor Addition Across from 253	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC02	2nd FL Corridor Addition Across from 253	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC02	2nd FL Corridor Addition Across from 253	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC02	2nd FL Corridor Addition Across from 253	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC01	2nd FL Corridor Addition Across from 253	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC01	2nd FL Corridor Addition Across from 253	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-WC01	2nd FL Corridor Addition Across from 253	Flush180	15-JUN-16	1.000	ppb
51210	51210-2-HAL-	2nd FL Corridor Addition Across	Flush180	15-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC02	353				
51210	51210-1-141-F01	Inside room 141, Fountain	Flush180	20-SEP-23	1.940	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Flush180	20-SEP-23	1.480	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Flush180	20-SEP-23	1.460	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Flush180	20-SEP-23	1.230	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Flush180	24-NOV-21	1.000	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Flush180	24-NOV-21	1.090	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Flush180	24-NOV-21	1.000	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Flush180	24-NOV-21	1.000	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Initial	20-SEP-23	3.090	ug/L
51210	51210-1-141-F01	Inside room 141, Fountain	Initial	24-NOV-21	1.580	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Flush180	24-NOV-21	1.000	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Flush180	24-NOV-21	1.000	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Flush180	24-NOV-21	1.000	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-143-F01	Inside room 143, Fountain	Initial	24-NOV-21	1.000	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush	09-NOV-2023	44.400	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush	09-NOV-2023	29.000	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush	09-NOV-2023	17.000	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush	09-NOV-2023	19.300	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush	06-OCT-2023	40.500	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush	06-OCT-2023	23.400	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush	06-OCT-2023	7.780	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush	06-OCT-2023	13.100	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush180	20-SEP-23	119.000	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush180	20-SEP-23	92.600	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush180	20-SEP-23	128.000	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Flush180	20-SEP-23	71.000	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Initial	20-SEP-23	425.000	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Initial	09-NOV-2023	91.100	ug/L
51210	51210-1-149-F01	Kindergarten 149, Drinking Fountain	Initial	06-OCT-2023	5.180	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush	06-OCT-2023	3.190	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush	06-OCT-2023	1.250	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush	06-OCT-2023	1.660	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush	06-OCT-2023	1.080	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	20-SEP-23	4.290	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	20-SEP-23	2.600	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	20-SEP-23	2.120	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Flush180	20-SEP-23	1.600	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Initial	20-SEP-23	13.200	ug/L
51210	51210-1-149-S01	Kindergarten 149, Sink	Initial	06-OCT-2023	2.180	ug/L
51210	51210-1-151-S01	Kindergarten 151	Flush180	20-SEP-23	1.160	ug/L
51210	51210-1-151-S01	Kindergarten 151	Flush180	20-SEP-23	1.180	ug/L
51210	51210-1-151-S01	Kindergarten 151	Flush180	20-SEP-23	1.340	ug/L
51210	51210-1-151-S01	Kindergarten 151	Flush180	20-SEP-23	1.310	ug/L
51210	51210-1-151-S01	Kindergarten 151	Flush180	15-JUN-16	15.000	ppb
51210	51210-1-151-S01	Kindergarten 151	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-151-S01	Kindergarten 151	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-151-S01	Kindergarten 151	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-151-S01	Kindergarten 151	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-151-S01	Kindergarten 151	Flush180	04-AUG-16	1.710	ppb
51210	51210-1-151-S01	Kindergarten 151	Flush180	04-AUG-16	1.190	ppb
51210	51210-1-151-S01	Kindergarten 151	Flush180	04-AUG-16	1.120	ppb
51210	51210-1-151-S01	Kindergarten 151	Flush180	04-AUG-16	1.430	ppb
51210	51210-1-151-S10	Kindergarten 151	Flush180	09-NOV-16	2.000	ppb
51210	51210-1-151-S10	Kindergarten 151	Flush180	09-NOV-16	1.000	ppb
51210	51210-1-151-S10	Kindergarten 151	Flush180	09-NOV-16	1.000	ppb
51210	51210-1-151-S10	Kindergarten 151	Flush180	09-NOV-16	1.000	ppb
51210	51210-1-151-S10	Kindergarten 151	Flush180	09-NOV-16	1.000	ppb
51210	51210-1-151-S01	Kindergarten 151	Initial	20-SEP-23	1.710	ug/L
51210	51210-1-151-S01	Kindergarten 151	Initial	04-AUG-16	1.440	ppb
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush	09-NOV-2023	6.120	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush	09-NOV-2023	4.520	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush	09-NOV-2023	2.880	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush	09-NOV-2023	1.980	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush	06-OCT-2023	5.780	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush	06-OCT-2023	22.900	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush	06-OCT-2023	2.570	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush	06-OCT-2023	5.700	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush180	20-SEP-23	5.210	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush180	20-SEP-23	6.070	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush180	20-SEP-23	5.330	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Flush180	20-SEP-23	3.290	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Initial	20-SEP-23	8.080	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Initial	09-NOV-2023	12.600	ug/L
51210	51210-1-151-F01	Kindergarten 151, Fountain	Initial	06-OCT-2023	6.250	ug/L
51210	51210-1-KIT-KS05	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS05	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS05	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS06	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS06	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS06	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS06	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS06	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS06	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS05	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS05	Kitchen	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS01	Kitchen 1958 Addition	Flush180	15-JUN-16	8.250	ppb
51210	51210-1A-KIT-KS01	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS02	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS02	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS02	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS02	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS03	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS03	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS03	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS03	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS04	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS04	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS04	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS04	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS04					
51210	51210-1A-KIT-KS01	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS01	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1A-KIT-KS01	Kitchen 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS01	Kitchen, E. Wall 3 Basin Left Sink	Initial	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush180	20-SEP-23	5.490	ug/L
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS02	Kitchen, E. Wall 3 Basin Right Sink	Initial	06-OCT-2023	1.000	ug/L
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Flush180	15-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS03					
51210	51210-1-KIT-KS03	Kitchen, N. Wall 2 Basin Left Sink	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush	06-OCT-2023	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	20-SEP-23	13.200	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-KIT-KS04	Kitchen, N. Wall 2 Basin Right Sink	Initial	06-OCT-2023	1.000	ug/L
51210	51210-1-117-S01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-117-S01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	5.970	ppb
51210	51210-1-1151210-1-117-S01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-117-F01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-117-F01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-117-F01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-117-F01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-117-F01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-117-S01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-117-S01	Pre-K 117 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-F01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-F01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-F01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-F01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-F01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-F01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-S01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-S01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-S01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-119-S01	Pre-K 119 1958 Addition	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-	Pre-K 141	Flush180	15-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51210	51210-1-141-S01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-S01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-S01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-S01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-WC01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-WC01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-WC01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-WC01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-WC01	Pre-K 141	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-141-WC01	Pre-K 141	Flush180	20-AUG-20	1.000	ug/L
51210	51210-1-141-S01	Pre-K 141	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-141-S01	Pre-K 141	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-141-S01	Pre-K 141	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-141-S01	Pre-K 141	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-141-WC01	Pre-K 141	Initial	20-AUG-20	1.580	ug/L
51210	51210-1-141-S01	Pre-K 141	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-141-S02	Pre-K 141, Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-141-S02	Pre-K 141, Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-141-S02	Pre-K 141, Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-141-S02	Pre-K 141, Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-141-S02	Pre-K 141, Right Sink	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-143-S01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-S01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-S01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-S01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-WC01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-WC01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-WC01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-WC01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-WC01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-S01	Pre-K 143	Flush180	15-JUN-16	1.000	ppb
51210	51210-1-143-S01	Pre-K 143	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-S01	Pre-K 143	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-S01	Pre-K 143	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-S01	Pre-K 143	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-S01	Pre-K 143	Initial	20-SEP-23	1.000	ug/L
51210	51210-1-143-	Pre-K 143, Right Sink	Flush180	20-SEP-23	1.000	ug/L

**Water Quality Assessment
Roswell B Mason Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02					
51210	51210-1-143-S02	Pre-K 143, Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-S02	Pre-K 143, Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-S02	Pre-K 143, Right Sink	Flush180	20-SEP-23	1.000	ug/L
51210	51210-1-143-S02	Pre-K 143, Right Sink	Initial	20-SEP-23	2.250	ug/L