



Sep 10, 2024

MATHER HS

5835 N LINCOLN AVE, Chicago IL 60659.

Dear **MATHER HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

MATHER HS

5835 N LINCOLN AVE, Chicago IL 60659.

Estimadas familias de **MATHER HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51535	51535-2-HAL-WC06	Main- 2nd Floor, Outside East Gym, Left Center Wat	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC06	Main- 2nd Floor, Outside East Gym, Left Center Wat	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC06	Main- 2nd Floor, Outside East Gym, Left Center Wat	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC06	Main- 2nd Floor, Outside East Gym, Left Center Wat	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC06	Main- 2nd Floor, Outside East Gym, Left Center Wat	Initial	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC05	Main- 2nd Floor, Outside East Gym, Left Water Cool	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC05	Main- 2nd Floor, Outside East Gym, Left Water Cool	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC05	Main- 2nd Floor, Outside East Gym, Left Water Cool	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC05	Main- 2nd Floor, Outside East Gym, Left Water Cool	Initial	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC07	Main- 2nd Floor, Outside East Gym, Right Center Wa	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC07	Main- 2nd Floor, Outside East Gym, Right Center Wa	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC07	Main- 2nd Floor, Outside East Gym, Right Center Wa	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC07	Main- 2nd Floor, Outside East Gym, Right Center Wa	Initial	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC08	Main- 2nd Floor, Outside East Gym, Right Water Coo	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC08	Main- 2nd Floor, Outside East Gym, Right Water Coo	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC08	Main- 2nd Floor, Outside East Gym, Right Water Coo	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC08	Main- 2nd Floor, Outside East Gym, Right Water Coo	Initial	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC02	Main- 2nd Floor, Outside West Gym, Left Center Wat	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC02	Main- 2nd Floor, Outside West Gym, Left Center Wat	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC02	Main- 2nd Floor, Outside West Gym, Left Center Wat	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC02	Main- 2nd Floor, Outside West Gym, Left Center Wat	Initial	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC01	Main- 2nd Floor, Outside West Gym, Left Water Cool	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC01	Main- 2nd Floor, Outside West Gym, Left Water Cool	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC01	Main- 2nd Floor, Outside West Gym, Left Water Cool	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC01	Main- 2nd Floor, Outside West Gym, Left Water Cool	Initial	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC03	Main- 2nd Floor, Outside West Gym, Right Center Wa	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC03	Main- 2nd Floor, Outside West Gym, Right Center Wa	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC03	Main- 2nd Floor, Outside West Gym, Right Center Wa	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC03	Main- 2nd Floor, Outside West Gym, Right Center Wa	Initial	07-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51535	51535-2-HAL-WC04	Main- 2nd Floor, Outside West Gym, Right Water Coo	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC04	Main- 2nd Floor, Outside West Gym, Right Water Coo	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC04	Main- 2nd Floor, Outside West Gym, Right Water Coo	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC04	Main- 2nd Floor, Outside West Gym, Right Water Coo	Flush180	07-OCT-16	1.000	ppb
51535	51535-2-HAL-WC04	Main- 2nd Floor, Outside West Gym, Right Water Coo	Initial	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F21	Main- Across From Main Office, Left Fountain	Flush180	07-OCT-16	0.380	ppb
51535	51535-1-HAL-F21	Main- Across From Main Office, Left Fountain	Flush180	07-OCT-16	0.235	ppb
51535	51535-1-HAL-F21	Main- Across From Main Office, Left Fountain	Flush180	07-OCT-16	0.125	ppb
51535	51535-1-HAL-F21	Main- Across From Main Office, Left Fountain	Flush180	07-OCT-16	0.127	ppb
51535	51535-1-HAL-F21	Main- Across From Main Office, Left Fountain	Initial	07-OCT-16	0.422	ppb
51535	51535-1-HAL-F22	Main- Across From Main Office, Right Fountain	Flush180	07-OCT-16	0.290	ppb
51535	51535-1-HAL-F22	Main- Across From Main Office, Right Fountain	Flush180	07-OCT-16	0.174	ppb
51535	51535-1-HAL-F22	Main- Across From Main Office, Right Fountain	Flush180	07-OCT-16	0.367	ppb
51535	51535-1-HAL-F22	Main- Across From Main Office, Right Fountain	Flush180	07-OCT-16	0.306	ppb
51535	51535-1-HAL-F22	Main- Across From Main Office, Right Fountain	Initial	07-OCT-16	0.555	ppb
51535	51535-1-HAL-F20	Main- Across From Room 108, Left Fountain	Flush180	07-OCT-16	0.209	ppb
51535	51535-1-HAL-F20	Main- Across From Room 108, Left Fountain	Flush180	07-OCT-16	0.239	ppb
51535	51535-1-HAL-F20	Main- Across From Room 108, Left Fountain	Flush180	07-OCT-16	0.379	ppb
51535	51535-1-HAL-F20	Main- Across From Room 108, Left Fountain	Flush180	07-OCT-16	0.248	ppb
51535	51535-1-HAL-F20	Main- Across From Room 108, Left Fountain	Initial	07-OCT-16	0.553	ppb
51535	51535-1-HAL-F19	Main- Across From Room 108, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F19	Main- Across From Room 108, Right Fountain	Flush180	07-OCT-16	0.133	ppb
51535	51535-1-HAL-F19	Main- Across From Room 108, Right Fountain	Flush180	07-OCT-16	0.484	ppb
51535	51535-1-HAL-F19	Main- Across From Room 108, Right Fountain	Flush180	07-OCT-16	0.176	ppb
51535	51535-1-HAL-F19	Main- Across From Room 108, Right Fountain	Initial	07-OCT-16	0.809	ppb
51535	51535-1-HAL-F17	Main- Across From Room 213, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F17	Main- Across From Room 213, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F17	Main- Across From Room 213, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F17	Main- Across From Room 213, Left Fountain	Flush180	07-OCT-16	0.222	ppb
51535	51535-1-HAL-F17	Main- Across From Room 213, Left Fountain	Initial	07-OCT-16	0.429	ppb
51535	51535-1-HAL-F16	Main- Across From Room 213, Right Fountain	Flush180	07-OCT-16	0.163	ppb
51535	51535-1-HAL-F16	Main- Across From Room 213, Right Fountain	Flush180	07-OCT-16	0.136	ppb
51535	51535-1-HAL-F16	Main- Across From Room 213, Right Fountain	Flush180	07-OCT-16	0.665	ppb
51535	51535-1-HAL-F16	Main- Across From Room 213, Right Fountain	Flush180	07-OCT-16	0.358	ppb
51535	51535-1-HAL-F16	Main- Across From Room 213, Right Fountain	Initial	07-OCT-16	0.807	ppb
51535	51535-1-HAL-F13	Main- Across From Room 424, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F13	Main- Across From Room 424, Left Fountain	Flush180	07-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51535	51535-1-HAL-F13	Main- Across From Room 424, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F13	Main- Across From Room 424, Left Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F13	Main- Across From Room 424, Left Fountain	Initial	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F14	Main- Across From Room 424, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F14	Main- Across From Room 424, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F14	Main- Across From Room 424, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F14	Main- Across From Room 424, Right Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F14	Main- Across From Room 424, Right Fountain	Initial	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC11	Main- Across From Room 451, Bottle Filler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC11	Main- Across From Room 451, Bottle Filler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC11	Main- Across From Room 451, Bottle Filler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC11	Main- Across From Room 451, Bottle Filler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC11	Main- Across From Room 451, Bottle Filler	Initial	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC12	Main- Across From Room 451, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC12	Main- Across From Room 451, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC12	Main- Across From Room 451, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC12	Main- Across From Room 451, Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC12	Main- Across From Room 451, Water Cooler	Initial	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS07	Main- Kithcen, Island Sink	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS07	Main- Kithcen, Island Sink	Flush180	07-OCT-16	0.202	ppb
51535	51535-1-KIT-KS07	Main- Kithcen, Island Sink	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS07	Main- Kithcen, Island Sink	Flush180	07-OCT-16	0.166	ppb
51535	51535-1-KIT-KS07	Main- Kithcen, Island Sink	Initial	07-OCT-16	0.432	ppb
51535	51535-1-KIT-KS04	Main- Kithcen, North Wall, Single Sink	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS04	Main- Kithcen, North Wall, Single Sink	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS04	Main- Kithcen, North Wall, Single Sink	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS04	Main- Kithcen, North Wall, Single Sink	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS04	Main- Kithcen, North Wall, Single Sink	Initial	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS06	Main- Kithcen, North Wall, Two Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS06	Main- Kithcen, North Wall, Two Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS06	Main- Kithcen, North Wall, Two Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS06	Main- Kithcen, North Wall, Two Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS06	Main- Kithcen, North Wall, Two Basin Left Faucet	Initial	07-OCT-16	0.163	ppb
51535	51535-1-KIT-KS05	Main- Kithcen, North Wall, Two Basin Right Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS05	Main- Kithcen, North Wall, Two Basin Right Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS05	Main- Kithcen, North Wall, Two Basin Right Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS05	Main- Kithcen, North Wall, Two Basin Right Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS05	Main- Kithcen, North Wall, Two Basin Right Faucet	Initial	07-OCT-16	0.191	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS05	Basin Right Faucet				
51535	51535-1-KIT-KS02	Main- Kithcen, South Wall, Three Basin Center Fauc	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS02	Main- Kithcen, South Wall, Three Basin Center Fauc	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS02	Main- Kithcen, South Wall, Three Basin Center Fauc	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS02	Main- Kithcen, South Wall, Three Basin Center Fauc	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS02	Main- Kithcen, South Wall, Three Basin Center Fauc	Initial	07-OCT-16	0.552	ppb
51535	51535-1-KIT-KS01	Main- Kithcen, South Wall, Three Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS01	Main- Kithcen, South Wall, Three Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS01	Main- Kithcen, South Wall, Three Basin Left Faucet	Flush180	07-OCT-16	1.590	ppb
51535	51535-1-KIT-KS01	Main- Kithcen, South Wall, Three Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS01	Main- Kithcen, South Wall, Three Basin Left Faucet	Initial	07-OCT-16	0.131	ppb
51535	51535-1-KIT-KS03	Main- Kithcen, South Wall, Three Basin Right Fauce	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS03	Main- Kithcen, South Wall, Three Basin Right Fauce	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS03	Main- Kithcen, South Wall, Three Basin Right Fauce	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS03	Main- Kithcen, South Wall, Three Basin Right Fauce	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS03	Main- Kithcen, South Wall, Three Basin Right Fauce	Initial	07-OCT-16	0.836	ppb
51535	51535-1-KIT-KS09	Main- Kithcen, West Wall, Three Basin Center Fauce	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS09	Main- Kithcen, West Wall, Three Basin Center Fauce	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS09	Main- Kithcen, West Wall, Three Basin Center Fauce	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS09	Main- Kithcen, West Wall, Three Basin Center Fauce	Initial	07-OCT-16	0.121	ppb
51535	51535-1-KIT-KS10	Main- Kithcen, West Wall, Three Basin Left Faucet	Flush180	07-OCT-16	0.286	ppb
51535	51535-1-KIT-KS10	Main- Kithcen, West Wall, Three Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS10	Main- Kithcen, West Wall, Three Basin Left Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS10	Main- Kithcen, West Wall, Three Basin Left Faucet	Initial	07-OCT-16	0.234	ppb
51535	51535-1-KIT-KS08	Main- Kithcen, West Wall, Three Basin Right Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS08	Main- Kithcen, West Wall, Three Basin Right Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS08	Main- Kithcen, West Wall, Three Basin Right Faucet	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-KIT-KS08	Main- Kithcen, West Wall, Three Basin Right Faucet	Initial	07-OCT-16	0.572	ppb
51535	51535-1-HAL-WC23	Main- Near Entrance Lobby, Left Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC23	Main- Near Entrance Lobby, Left Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC23	Main- Near Entrance Lobby, Left Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC23	Main- Near Entrance Lobby, Left Water Cooler	Initial	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC24	Main- Near Entrance Lobby, Right Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-	Main- Near Entrance Lobby, Right	Flush180	07-OCT-16	1.000	ppb

**Water Quality Assessment
Stephen T Mather High School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC24	Water Cooler				
51535	51535-1-HAL-WC24	Main- Near Entrance Lobby, Right Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC24	Main- Near Entrance Lobby, Right Water Cooler	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-WC24	Main- Near Entrance Lobby, Right Water Cooler	Initial	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F18	Main- Next to Room 300, Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F18	Main- Next to Room 300, Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F18	Main- Next to Room 300, Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F18	Main- Next to Room 300, Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-HAL-F18	Main- Next to Room 300, Fountain	Initial	07-OCT-16	1.000	ppb
51535	51535-1-POOL-F15	Main- Pool Area Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-POOL-F15	Main- Pool Area Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-POOL-F15	Main- Pool Area Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-POOL-F15	Main- Pool Area Fountain	Flush180	07-OCT-16	1.000	ppb
51535	51535-1-POOL-F15	Main- Pool Area Fountain	Initial	07-OCT-16	0.120	ppb