



**Sep 10, 2024**

**MCKAY**

**6901 S FAIRFIELD AVE, Chicago IL 60629.**

Dear **MCKAY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**MCKAY**

**6901 S FAIRFIELD AVE, Chicago IL 60629.**

Estimadas familias de **MCKAY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52507	52507-ADD-1-KIT-KS02	Addition- 1st floor Kitchen East Wall Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-KIT-KS02	Addition- 1st floor Kitchen East Wall Sink 2	Flush180	02-JUN-16	0.301	ppb
52507	52507-ADD-1-KIT-KS02	Addition- 1st floor Kitchen East Wall Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-KIT-KS02	Addition- 1st floor Kitchen East Wall Sink 2	Flush180	02-JUN-16	0.210	ppb
52507	52507-ADD-1-KIT-KS02	Addition- 1st floor Kitchen East Wall Sink 2	Initial	02-JUN-16	0.305	ppb
52507	52507-ADD-1-KIT-KS01	Addition- 1st floor Kitchen North Wall Sink	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-KIT-KS01	Addition- 1st floor Kitchen North Wall Sink	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-KIT-KS01	Addition- 1st floor Kitchen North Wall Sink	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-KIT-KS01	Addition- 1st floor Kitchen North Wall Sink	Flush180	02-JUN-16	0.219	ppb
52507	52507-ADD-1-KIT-KS01	Addition- 1st floor Kitchen North Wall Sink	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-1-KIT-KS03	Addition- 1st floor Kitchen South Wall Sink 3	Flush180	02-JUN-16	0.272	ppb
52507	52507-ADD-1-KIT-KS03	Addition- 1st floor Kitchen South Wall Sink 3	Flush180	02-JUN-16	0.828	ppb
52507	52507-ADD-1-KIT-KS03	Addition- 1st floor Kitchen South Wall Sink 3	Flush180	02-JUN-16	0.146	ppb
52507	52507-ADD-1-KIT-KS03	Addition- 1st floor Kitchen South Wall Sink 3	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-KIT-KS03	Addition- 1st floor Kitchen South Wall Sink 3	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F04	Addition- 1st floor N. Fountain 1 Outside Girls Ba	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F04	Addition- 1st floor N. Fountain 1 Outside Girls Ba	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F04	Addition- 1st floor N. Fountain 1 Outside Girls Ba	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F04	Addition- 1st floor N. Fountain 1 Outside Girls Ba	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F04	Addition- 1st floor N. Fountain 1 Outside Girls Ba	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F05	Addition- 1st floor N. Fountain 2 Outside Girls Ba	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F05	Addition- 1st floor N. Fountain 2 Outside Girls Ba	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F05	Addition- 1st floor N. Fountain 2 Outside Girls Ba	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-HAL-F05	Addition- 1st floor N. Fountain 2 Outside Girls Ba	Flush180	02-JUN-16	0.133	ppb
52507	52507-ADD-1-HAL-F05	Addition- 1st floor N. Fountain 2 Outside Girls Ba	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-2-HAL-F02	Addition- 2nd floor Fountain 1 Outside Girls Bathr	Flush180	02-JUN-16	1.070	ppb
52507	52507-ADD-2-HAL-F02	Addition- 2nd floor Fountain 1 Outside Girls Bathr	Flush180	02-JUN-16	0.670	ppb
52507	52507-ADD-2-HAL-F02	Addition- 2nd floor Fountain 1 Outside Girls Bathr	Flush180	02-JUN-16	0.673	ppb
52507	52507-ADD-2-HAL-F02	Addition- 2nd floor Fountain 1 Outside Girls Bathr	Initial	02-JUN-16	1.240	ppb
52507	52507-ADD-2-HAL-F03	Addition- 2nd floor Fountain 2 Outside Girls Bathr	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-2-HAL-F03	Addition- 2nd floor Fountain 2 Outside Girls Bathr	Flush180	02-JUN-16	0.131	ppb
52507	52507-ADD-2-HAL-F03	Addition- 2nd floor Fountain 2 Outside Girls Bathr	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-2-HAL-F03	Addition- 2nd floor Fountain 2 Outside Girls Bathr	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-2-HAL-F03	Addition- 2nd floor Fountain 2 Outside Girls Bathr	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-3-HAL-F02	Addition- 3rd floor Fountain Outside Room 320	Flush180	02-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52507	52507-ADD-3-HAL-F02	Addition- 3rd floor Fountain Outside Room 320	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-3-HAL-F02	Addition- 3rd floor Fountain Outside Room 320	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-3-HAL-F02	Addition- 3rd floor Fountain Outside Room 320	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-3-HAL-F02	Addition- 3rd floor Fountain Outside Room 320	Flush180	05-AUG-20	1.000	ug/L
52507	52507-ADD-3-HAL-F02	Addition- 3rd floor Fountain Outside Room 320	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-3-HAL-F02	Addition- 3rd floor Fountain Outside Room 320	Initial	05-AUG-20	1.000	ug/L
52507	52507-ADD-1-128-BF01	Addition- Inside Room 128 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-BF01	Addition- Inside Room 128 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-BF01	Addition- Inside Room 128 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-BF01	Addition- Inside Room 128 Bottle Filler	Initial	19-OCT-22	2.860	ug/L
52507	52507-ADD-1-128-F01	Addition- Inside Room 128 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-F01	Addition- Inside Room 128 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-F01	Addition- Inside Room 128 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-F01	Addition- Inside Room 128 Fountain	Initial	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S07	Addition- Inside Room 128 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-128-S07	Addition- Inside Room 128 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-128-S07	Addition- Inside Room 128 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-128-S07	Addition- Inside Room 128 Sink 1	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-1-128-S08	Addition- Inside Room 128 Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-128-S08	Addition- Inside Room 128 Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-128-S08	Addition- Inside Room 128 Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-128-S08	Addition- Inside Room 128 Sink 2	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-1-128-S01	Addition- Inside Room 128 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S01	Addition- Inside Room 128 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S01	Addition- Inside Room 128 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S01	Addition- Inside Room 128 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S01	Addition- Inside Room 128 Sink Left	Initial	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S02	Addition- Inside Room 128 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S02	Addition- Inside Room 128 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S02	Addition- Inside Room 128 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S02	Addition- Inside Room 128 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-128-S02	Addition- Inside Room 128 Sink Right	Initial	19-OCT-22	1.060	ug/L
52507	52507-ADD-1-129-S10	Addition- Inside Room 129 Sink 1	Flush180	02-JUN-16	1.000	ppb





Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	131-S02	Right				
52507	52507-ADD-1-131-S02	Addition- Inside Room 131 Sink Right	Initial	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-BF01	Addition- Inside Room 132 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-BF01	Addition- Inside Room 132 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-BF01	Addition- Inside Room 132 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-BF01	Addition- Inside Room 132 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-BF01	Addition- Inside Room 132 Bottle Filler	Initial	19-OCT-22	1.820	ug/L
52507	52507-ADD-1-132-F01	Addition- Inside Room 132 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-F01	Addition- Inside Room 132 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-F01	Addition- Inside Room 132 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-F01	Addition- Inside Room 132 Fountain	Initial	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S19	Addition- Inside Room 132 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S19	Addition- Inside Room 132 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S19	Addition- Inside Room 132 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S19	Addition- Inside Room 132 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S19	Addition- Inside Room 132 Sink 1	Initial	02-JUN-16	0.245	ppb
52507	52507-ADD-1-132-S20	Addition- Inside Room 132 Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S20	Addition- Inside Room 132 Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S20	Addition- Inside Room 132 Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S20	Addition- Inside Room 132 Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S20	Addition- Inside Room 132 Sink 2	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-1-132-S01	Addition- Inside Room 132 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S01	Addition- Inside Room 132 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S01	Addition- Inside Room 132 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S01	Addition- Inside Room 132 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S01	Addition- Inside Room 132 Sink Left	Initial	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S02	Addition- Inside Room 132 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S02	Addition- Inside Room 132 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S02	Addition- Inside Room 132 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-132-S02	Addition- Inside Room 132 Sink Right	Initial	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-BF01	Addition- Inside Room 133 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-BF01	Addition- Inside Room 133 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-BF01	Addition- Inside Room 133 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-BF01	Addition- Inside Room 133 Bottle Filler	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-BF01	Addition- Inside Room 133 Bottle Filler	Initial	19-OCT-22	1.820	ug/L
52507	52507-ADD-1-	Addition- Inside Room 133	Flush180	02-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	133-F21	Fountain				
52507	52507-ADD-1-133-F21	Addition- Inside Room 133 Fountain	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-133-F21	Addition- Inside Room 133 Fountain	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-133-F21	Addition- Inside Room 133 Fountain	Flush180	02-JUN-16	0.177	ppb
52507	52507-ADD-1-133-F21	Addition- Inside Room 133 Fountain	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-1-133-F01	Addition- Inside Room 133 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-F01	Addition- Inside Room 133 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-F01	Addition- Inside Room 133 Fountain	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-F01	Addition- Inside Room 133 Fountain	Initial	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-S22	Addition- Inside Room 133 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-133-S22	Addition- Inside Room 133 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-133-S22	Addition- Inside Room 133 Sink 1	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-133-S22	Addition- Inside Room 133 Sink 1	Initial	02-JUN-16	1.000	ppb
52507	52507-ADD-1-133-S23	Addition- Inside Room 133 Sink 2	Flush180	02-JUN-16	0.132	ppb
52507	52507-ADD-1-133-S23	Addition- Inside Room 133 Sink 2	Flush180	02-JUN-16	0.151	ppb
52507	52507-ADD-1-133-S23	Addition- Inside Room 133 Sink 2	Flush180	02-JUN-16	1.000	ppb
52507	52507-ADD-1-133-S23	Addition- Inside Room 133 Sink 2	Initial	02-JUN-16	0.139	ppb
52507	52507-ADD-1-133-S01	Addition- Inside Room 133 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-S01	Addition- Inside Room 133 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-S01	Addition- Inside Room 133 Sink Left	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-S01	Addition- Inside Room 133 Sink Left	Initial	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-S02	Addition- Inside Room 133 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-S02	Addition- Inside Room 133 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-S02	Addition- Inside Room 133 Sink Right	Flush180	19-OCT-22	1.000	ug/L
52507	52507-ADD-1-133-S02	Addition- Inside Room 133 Sink Right	Initial	19-OCT-22	1.000	ug/L
52507	52507-1-HAL-F02	Main- 1st FI North Outside Boiler Rm, Fountain	Flush180	02-JUN-16	0.609	ppb
52507	52507-1-HAL-F02	Main- 1st FI North Outside Boiler Rm, Fountain	Flush180	02-JUN-16	1.630	ppb
52507	52507-1-HAL-F02	Main- 1st FI North Outside Boiler Rm, Fountain	Flush180	02-JUN-16	0.559	ppb
52507	52507-1-HAL-F02	Main- 1st FI North Outside Boiler Rm, Fountain	Flush180	02-JUN-16	0.749	ppb
52507	52507-1-HAL-F02	Main- 1st FI North Outside Boiler Rm, Fountain	Initial	02-JUN-16	0.544	ppb
52507	52507-1-HAL-F03	Main- 1st FI South Outside Boy Bathroom, Fountain	Flush180	02-JUN-16	0.415	ppb
52507	52507-1-HAL-F03	Main- 1st FI South Outside Boy Bathroom, Fountain	Flush180	02-JUN-16	0.257	ppb
52507	52507-1-HAL-F03	Main- 1st FI South Outside Boy Bathroom, Fountain	Flush180	02-JUN-16	0.459	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52507	52507-1-HAL-F03	Main- 1st FI South Outside Boy Bathroom, Fountain	Flush180	02-JUN-16	0.663	ppb
52507	52507-1-HAL-F03	Main- 1st FI South Outside Boy Bathroom, Fountain	Flush180	05-AUG-20	1.000	ug/L
52507	52507-1-HAL-F03	Main- 1st FI South Outside Boy Bathroom, Fountain	Initial	02-JUN-16	0.439	ppb
52507	52507-1-HAL-F03	Main- 1st FI South Outside Boy Bathroom, Fountain	Initial	05-AUG-20	1.000	ug/L
52507	52507-2-HAL-F01	Main- 2nd FI North Outside Room 206, Fountain	Flush180	02-JUN-16	1.000	ppb
52507	52507-2-HAL-F01	Main- 2nd FI North Outside Room 206, Fountain	Flush180	02-JUN-16	1.000	ppb
52507	52507-2-HAL-F01	Main- 2nd FI North Outside Room 206, Fountain	Flush180	02-JUN-16	1.000	ppb
52507	52507-2-HAL-F01	Main- 2nd FI North Outside Room 206, Fountain	Flush180	02-JUN-16	1.000	ppb
52507	52507-2-HAL-F01	Main- 2nd FI North Outside Room 206, Fountain	Initial	02-JUN-16	1.000	ppb