



Sep 10, 2024

METCALFE

12339 S NORMAL AVE, Chicago IL 60628.

Dear **METCALFE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

METCALFE

12339 S NORMAL AVE, Chicago IL 60628.

Estimadas familias de **METCALFE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Flush180	14-JUN-16	0.250	ppb
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Flush180	14-JUN-16	0.288	ppb
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Flush180	14-JUN-16	0.133	ppb
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Flush180	14-JUN-16	0.184	ppb
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F04	Hallway Across from Auditorium, Fountain 1	Initial	14-JUN-16	0.123	ppb
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	14-JUN-16	0.273	ppb
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	14-JUN-16	0.152	ppb
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	14-JUN-16	0.300	ppb
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	14-JUN-16	0.208	ppb
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Flush180	18-AUG-20	1.210	ug/L
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Initial	14-JUN-16	0.150	ppb
51503	51503-1-HAL-F05	Hallway Across from Auditorium, Fountain 2	Initial	18-AUG-20	1.000	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	11-JUN-2024	10.100	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	16-MAY-2024	15.800	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	16-MAY-2024	13.900	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	16-MAY-2024	26.000	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	16-MAY-2024	11.800	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	23-APR-2024	3.590	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	23-APR-2024	5.590	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	23-APR-2024	7.330	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	23-APR-2024	2.270	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	11-JUN-2024	19.300	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	11-JUN-2024	31.200	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush	11-JUN-2024	13.300	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush180	02-DEC-22	3.480	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush180	02-DEC-22	5.300	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush180	02-DEC-22	3.650	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush180	02-DEC-22	1.780	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush180	14-JUN-16	5.080	ppb
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush180	14-JUN-16	4.540	ppb
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush180	14-JUN-16	5.030	ppb
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Flush180	14-JUN-16	5.500	ppb
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Initial	02-DEC-22	3.270	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Initial	14-JUN-16	7.080	ppb
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Initial	16-MAY-2024	6.580	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Initial	23-APR-2024	20.000	ug/L
51503	51503-1-101-S06	Inside Room 101 Kindergarden, Sink	Initial	11-JUN-2024	23.100	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	13-OCT-22	1.120	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	13-OCT-22	1.000	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	13-OCT-22	1.000	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	13-OCT-22	1.000	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	14-SEP-22	1.340	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	14-SEP-22	2.400	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	14-SEP-22	1.470	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	14-SEP-22	2.170	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	25-AUG-22	17.000	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	25-AUG-22	11.800	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	25-AUG-22	4.210	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Flush180	25-AUG-22	3.590	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Initial	13-OCT-22	4.630	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Initial	14-SEP-22	6.020	ug/L
51503	51503-1-101-BF01	Inside Room 101 Kindergarten, Bottle Filler	Initial	25-AUG-22	21.000	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Flush180	14-SEP-22	1.000	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Flush180	14-SEP-22	1.000	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Flush180	14-SEP-22	1.000	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Flush180	25-AUG-22	3.040	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Flush180	25-AUG-22	2.300	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Flush180	25-AUG-22	1.150	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Flush180	25-AUG-22	1.000	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Initial	14-SEP-22	4.380	ug/L
51503	51503-1-101-F01	Inside Room 101 Kindergarten, Fountain	Initial	25-AUG-22	24.800	ug/L

Water Quality Assessment Ralph H Metcalfe Elementary Community Academy

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51503	51503-1-102-BF01	Inside Room 102 Kindergarden, Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-BF01	Inside Room 102 Kindergarden, Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-BF01	Inside Room 102 Kindergarden, Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-BF01	Inside Room 102 Kindergarden, Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-BF01	Inside Room 102 Kindergarden, Bottle Filler	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-102-F01	Inside Room 102 Kindergarden, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-F01	Inside Room 102 Kindergarden, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-F01	Inside Room 102 Kindergarden, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-F01	Inside Room 102 Kindergarden, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-F01	Inside Room 102 Kindergarden, Fountain	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Flush180	14-JUN-16	0.950	ppb
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Flush180	14-JUN-16	0.974	ppb
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Flush180	14-JUN-16	1.040	ppb
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Flush180	14-JUN-16	1.020	ppb
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-102-S07	Inside Room 102 Kindergarden, Sink	Initial	14-JUN-16	1.040	ppb
51503	51503-1-104-BF01	Inside Room 104 Pre-K, Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-BF01	Inside Room 104 Pre-K, Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-BF01	Inside Room 104 Pre-K, Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-BF01	Inside Room 104 Pre-K, Bottle Filler	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-104-F01	Inside Room 104 Pre-K, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-F01	Inside Room 104 Pre-K, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-F01	Inside Room 104 Pre-K, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-F01	Inside Room 104 Pre-K, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-F01	Inside Room 104 Pre-K, Fountain	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Flush180	14-JUN-16	0.938	ppb
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Flush180	14-JUN-16	1.110	ppb
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Flush180	14-JUN-16	1.300	ppb
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Flush180	14-JUN-16	1.500	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S08					
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-104-S08	Inside Room 104 Pre-K, Sink	Initial	14-JUN-16	1.060	ppb
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Flush180	14-JUN-16	0.976	ppb
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Flush180	14-JUN-16	0.993	ppb
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Flush180	14-JUN-16	0.998	ppb
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Flush180	14-JUN-16	1.000	ppb
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Initial	14-JUN-16	0.816	ppb
51503	51503-1-KIT-KS01	Kitchen (Left), Sink	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-KIT-KS02	Kitchen (Right), Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-KIT-KS02	Kitchen (Right), Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-KIT-KS02	Kitchen (Right), Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-KIT-KS02	Kitchen (Right), Sink	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-KIT-KS02	Kitchen (Right), Sink	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-RBF01	Lunchroom (North Wall), Retrofit Bottle Filler	Flush180	02-DEC-22	1.130	ug/L
51503	51503-1-CAF-RBF01	Lunchroom (North Wall), Retrofit Bottle Filler	Flush180	02-DEC-22	1.020	ug/L
51503	51503-1-CAF-RBF01	Lunchroom (North Wall), Retrofit Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-RBF01	Lunchroom (North Wall), Retrofit Bottle Filler	Flush180	02-DEC-22	1.030	ug/L
51503	51503-1-CAF-RBF01	Lunchroom (North Wall), Retrofit Bottle Filler	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-BF01	Lunchroom (South Wall), Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-BF01	Lunchroom (South Wall), Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-BF01	Lunchroom (South Wall), Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-BF01	Lunchroom (South Wall), Bottle Filler	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-BF01	Lunchroom (South Wall), Bottle Filler	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Flush180	14-JUN-16	0.129	ppb
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Flush180	14-JUN-16	0.231	ppb
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Flush180	14-JUN-16	1.000	ppb
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Flush180	14-JUN-16	0.312	ppb
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Initial	02-DEC-22	1.000	ug/L
51503	51503-1-CAF-F02	Lunchroom (South Wall), Fountain	Initial	14-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Flush180	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Flush180	14-JUN-16	0.371	ppb
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Flush180	14-JUN-16	0.131	ppb
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Flush180	14-JUN-16	0.277	ppb
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Flush180	14-JUN-16	0.363	ppb
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Initial	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-F01	Next to Room 212, Fountain	Initial	14-JUN-16	1.000	ppb
51503	51503-2-HAL-RBF01	Next to Room 212, Retrofit Bottle Filler, left	Flush180	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-RBF01	Next to Room 212, Retrofit Bottle Filler, left	Flush180	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-RBF01	Next to Room 212, Retrofit Bottle Filler, left	Flush180	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-RBF01	Next to Room 212, Retrofit Bottle Filler, left	Flush180	02-DEC-22	1.000	ug/L
51503	51503-2-HAL-RBF01	Next to Room 212, Retrofit Bottle Filler, left	Initial	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-BF01	Outside of Library, Bottle Filler, Right	Flush180	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-BF01	Outside of Library, Bottle Filler, Right	Flush180	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-BF01	Outside of Library, Bottle Filler, Right	Flush180	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-BF01	Outside of Library, Bottle Filler, Right	Flush180	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-BF01	Outside of Library, Bottle Filler, Right	Initial	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-F01	Outside of Library, Fountain	Flush180	14-JUN-16	1.000	ppb
51503	51503-3-HAL-F01	Outside of Library, Fountain	Flush180	14-JUN-16	0.309	ppb
51503	51503-3-HAL-F01	Outside of Library, Fountain	Flush180	14-JUN-16	0.419	ppb
51503	51503-3-HAL-F01	Outside of Library, Fountain	Flush180	14-JUN-16	0.180	ppb
51503	51503-3-HAL-F01	Outside of Library, Fountain	Flush180	18-AUG-20	1.270	ug/L
51503	51503-3-HAL-F01	Outside of Library, Fountain	Initial	14-JUN-16	1.000	ppb
51503	51503-3-HAL-F01	Outside of Library, Fountain	Initial	18-AUG-20	3.030	ug/L
51503	51503-3-HAL-F02	Outside of Library, Fountain, left	Flush180	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-F02	Outside of Library, Fountain, left	Flush180	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-F02	Outside of Library, Fountain, left	Flush180	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-F02	Outside of Library, Fountain, left	Flush180	02-DEC-22	1.000	ug/L
51503	51503-3-HAL-F02	Outside of Library, Fountain, left	Initial	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	18-AUG-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Flush180	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Initial	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Initial	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F01	Modular Outside Girls Toilets (North), Fountain 1	Initial	18-AUG-20	1.000	ug/L
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Flush180	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Flush180	14-JUN-16	0.349	ppb
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Flush180	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Flush180	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Flush180	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Flush180	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Flush180	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Initial	14-JUN-16	1.000	ppb
53842	53842-1-HAL-F02	Modular Outside Girls Toilets (South), Fountain 2	Initial	02-DEC-22	1.000	ug/L
53842	53842-1-HAL-BF01	Modular-Next to room 121 Bottle Filler	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-BF01	Modular-Next to room 121 Bottle Filler	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-BF01	Modular-Next to room 121 Bottle Filler	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-BF01	Modular-Next to room 121 Bottle Filler	Initial	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-F04	Modular-Next to room 121 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-F04	Modular-Next to room 121 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-F04	Modular-Next to room 121 Left Fountain	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-F04	Modular-Next to room 121 Left Fountain	Initial	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-F03	Modular-Next to room 121 Right Fountain	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-F03	Modular-Next to room 121 Right Fountain	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-F03	Modular-Next to room 121 Right Fountain	Flush180	14-SEP-23	1.000	ug/L
53842	53842-1-HAL-F03	Modular-Next to room 121 Right Fountain	Initial	14-SEP-23	1.000	ug/L