



Sep 10, 2024

MITCHELL

2233 W OHIO ST, Chicago IL 60612.

Dear **MITCHELL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

MITCHELL

2233 W OHIO ST, Chicago IL 60612.

Estimadas familias de **MITCHELL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-HAL-F03	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-HAL-F03	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-HAL-F03	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-HAL-F03	1st FL Hallway between 101 and 105	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	07-JAN-20	1.610	ug/L
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	07-JAN-20	1.320	ug/L
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	07-JAN-20	1.050	ug/L
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	07-JAN-20	1.590	ug/L
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Flush180	07-JAN-20	1.830	ug/L
51140	51140-1-S-HAL-F02	1st FL Hallway between 101 and 105	Initial	07-JAN-20	1.000	ug/L
51140	51140-1-S-HAL-F01	1st FL Hallway between 101 and 105	Initial	07-JAN-20	1.000	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	25-AUG-23	1.500	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	25-AUG-23	2.770	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	25-AUG-23	2.710	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	25-AUG-23	2.550	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	25-AUG-23	2.040	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	25-AUG-23	1.920	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	25-AUG-23	1.600	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	25-AUG-23	1.560	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	1.000	ppb
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	5.350	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	1.000	ppb
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	7.770	ppb
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	1.000	ppb
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	1.000	ppb
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	1.000	ppb
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	1.000	ppb
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	18-JUN-16	1.000	ppb
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	07-JAN-20	3.910	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	07-JAN-20	4.220	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	07-JAN-20	4.140	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Flush180	07-JAN-20	3.650	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	07-JAN-20	4.620	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	07-JAN-20	3.480	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	07-JAN-20	2.840	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	07-JAN-20	3.060	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	21-APR-20	10.200	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	21-APR-20	6.190	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	21-APR-20	5.900	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	21-APR-20	5.980	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	05-MAR-20	27.800	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	05-MAR-20	27.500	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	05-MAR-20	6.180	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Flush180	05-MAR-20	6.150	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Initial	25-AUG-23	1.420	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Initial	25-AUG-23	1.820	ug/L
51140	51140-2-S-HAL-F01	2nd FL Hallway between 201 and 203	Initial	07-JAN-20	3.230	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Initial	07-JAN-20	5.970	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Initial	21-APR-20	30.000	ug/L
51140	51140-2-S-HAL-F02	2nd FL Hallway between 201 and 203	Initial	05-MAR-20	179.000	ug/L
51140	51140-2-S-HAL-BF01	2nd FL Hallway between 201 and 203, Bottle Filler	Flush180	25-AUG-23	1.440	ug/L
51140	51140-2-S-HAL-BF01	2nd FL Hallway between 201 and 203, Bottle Filler	Flush180	25-AUG-23	1.510	ug/L
51140	51140-2-S-HAL-BF01	2nd FL Hallway between 201 and 203, Bottle Filler	Flush180	25-AUG-23	1.480	ug/L
51140	51140-2-S-HAL-BF01	2nd FL Hallway between 201 and 203, Bottle Filler	Flush180	25-AUG-23	1.580	ug/L
51140	51140-2-S-HAL-BF01	2nd FL Hallway between 201 and 203, Bottle Filler	Initial	25-AUG-23	1.450	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	18-JUN-16	1.000	ppb
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	07-JAN-20	1.410	ug/L
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	07-JAN-20	1.060	ug/L
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	07-JAN-20	1.000	ug/L
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Flush180	07-JAN-20	1.000	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	07-JAN-20	2.280	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	07-JAN-20	2.100	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	07-JAN-20	1.540	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	07-JAN-20	2.270	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	04-AUG-20	5.780	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	30-OCT-20	1.000	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	30-OCT-20	1.000	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	30-OCT-20	1.000	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Flush180	30-OCT-20	1.000	ug/L
51140	51140-3-S-HAL-F01	3rd FL Hallway between 301 and 303	Initial	07-JAN-20	1.060	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Initial	07-JAN-20	1.160	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Initial	04-AUG-20	8.990	ug/L
51140	51140-3-S-HAL-F02	3rd FL Hallway between 301 and 303	Initial	30-OCT-20	1.090	ug/L
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	31-AUG-16	3.410	ppb
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	31-AUG-16	3.450	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	31-AUG-16	1.630	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	31-AUG-16	2.180	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	31-AUG-16	1.640	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	31-AUG-16	2.100	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	31-AUG-16	1.730	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	MAP-F02					
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	31-AUG-16	4.210	ppb
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	31-AUG-16	2.880	ppb
51140	51140-B-MAP-F01	Maproom - Basement	Flush180	31-AUG-16	4.000	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	18-JUN-16	31.700	ppb
51140	51140-B-MAP-F02	Maproom - Basement	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-MAP-F01	Maproom - Basement	Initial	18-JUN-16	110.000	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	13-SEP-23	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	13-SEP-23	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	13-SEP-23	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	13-SEP-23	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	31-AUG-16	0.122	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	16-NOV-16	0.420	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	16-NOV-16	0.230	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	16-NOV-16	0.430	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	16-NOV-16	0.500	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	18-JUN-16	67.700	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	07-JAN-20	18.900	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	07-JAN-20	1.630	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	07-JAN-20	1.490	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	07-JAN-20	7.570	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	21-APR-20	76.100	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	21-APR-20	120.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	21-APR-20	70.900	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	21-APR-20	50.200	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	05-MAR-20	42.400	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS01					
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	05-MAR-20	78.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	05-MAR-20	4.290	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Flush180	05-MAR-20	5.140	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Initial	13-SEP-23	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Initial	16-NOV-16	2.200	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Initial	31-AUG-16	3.970	ppb
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Initial	07-JAN-20	15.700	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Initial	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Initial	21-APR-20	289.000	ug/L
51140	51140-B-S-KIT-KS01	North Kitchen, Left Sink	Initial	05-MAR-20	107.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush	04-OCT-2023	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush	04-OCT-2023	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush	04-OCT-2023	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush	04-OCT-2023	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	13-SEP-23	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	13-SEP-23	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	13-SEP-23	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	07-JAN-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	07-JAN-20	7.580	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	07-JAN-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	07-JAN-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	21-APR-20	7.470	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	21-APR-20	1.820	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	21-APR-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	21-APR-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	05-MAR-20	7.520	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	05-MAR-20	4.470	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	05-MAR-20	4.190	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Flush180	05-MAR-20	3.410	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Initial	13-SEP-23	10.500	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Initial	07-JAN-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Initial	11-FEB-20	1.000	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Initial	21-APR-20	84.600	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Initial	05-MAR-20	13.200	ug/L
51140	51140-B-S-KIT-KS02	North Kitchen, Middle Sink	Initial	04-OCT-2023	1.000	ug/L
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Flush180	07-JAN-20	1.000	ug/L
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Flush180	07-JAN-20	1.280	ug/L
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Flush180	07-JAN-20	4.250	ug/L
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Flush180	07-JAN-20	1.000	ug/L
51140	51140-B-S-KIT-KS03	North Kitchen, Right Sink	Initial	07-JAN-20	2.180	ug/L
51140	51140-1-W-101-S01	Room 101 - Pre-K	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-W-101-S01	Room 101 - Pre-K	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-W-101-S01	Room 101 - Pre-K	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-W-101-S01	Room 101 - Pre-K	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-W-101-S01	Room 101 - Pre-K	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-W-101-S01	Room 101 - Pre-K	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-W-101-S01	Room 101 - Pre-K	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-W-101-S01	Room 101 - Pre-K	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-W-101-S01	Room 101 - Pre-K	Initial	07-JAN-20	1.470	ug/L
51140	51140-B-CAF-F02	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	31-AUG-16	0.122	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	31-AUG-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51140	51140-B-CAF-F01	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	31-AUG-16	0.176	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	18-JUN-16	17.900	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	31-AUG-16	0.816	ppb
51140	51140-B-CAF-F02	South Kitchen	Flush180	31-AUG-16	0.204	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	18-JUN-16	16.000	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F01	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	18-JUN-16	46.900	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F03	South Kitchen	Flush180	31-AUG-16	1.000	ppb
51140	51140-B-CAF-F04	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F04	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F04	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F04	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-B-CAF-F04	South Kitchen	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	18-JUN-16	1.000	ppb
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-N-TL-WC01	Teachers Lounge	Flush180	07-JAN-20	1.000	ug/L
51140	51140-1-N-TL-WC01	Teachers Lounge	Initial	07-JAN-20	1.000	ug/L

