



Sep 10, 2024

MONARCAS

5815 S HOMAN AVE, Chicago IL 60629.

Dear **MONARCAS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

MONARCAS

5815 S HOMAN AVE, Chicago IL 60629.

Estimadas familias de **MONARCAS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
50131	50131-1-HAL-F01	Annex- 1st floor S. Fountain	Flush180	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F01	Annex- 1st floor S. Fountain	Flush180	27-MAY-16	0.189	ppb
50131	50131-1-HAL-F01	Annex- 1st floor S. Fountain	Flush180	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F01	Annex- 1st floor S. Fountain	Flush180	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F01	Annex- 1st floor S. Fountain	Flush180	19-AUG-20	1.000	ug/L
50131	50131-1-HAL-F01	Annex- 1st floor S. Fountain	Initial	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F01	Annex- 1st floor S. Fountain	Initial	19-AUG-20	1.000	ug/L
50131	50131-1-HAL-F02	Annex- 1st floor S. Sink	Flush180	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F02	Annex- 1st floor S. Sink	Flush180	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F02	Annex- 1st floor S. Sink	Flush180	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F02	Annex- 1st floor S. Sink	Flush180	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F02	Annex- 1st floor S. Sink	Flush180	19-AUG-20	1.000	ug/L
50131	50131-1-HAL-F02	Annex- 1st floor S. Sink	Initial	27-MAY-16	1.000	ppb
50131	50131-1-HAL-F02	Annex- 1st floor S. Sink	Initial	19-AUG-20	1.000	ug/L
51310	51310-1-HAL-BF01	First Floor Bottle Filler	Flush180	22-DEC-20	1.000	ug/L
51310	51310-1-HAL-BF01	First Floor Bottle Filler	Flush180	22-DEC-20	1.000	ug/L
51310	51310-1-HAL-BF01	First Floor Bottle Filler	Flush180	22-DEC-20	2.380	ug/L
51310	51310-1-HAL-BF01	First Floor Bottle Filler	Flush180	22-DEC-20	1.000	ug/L
51310	51310-1-HAL-BF01	First Floor Bottle Filler	Initial	22-DEC-20	1.000	ug/L
51310	51310-1-HAL-F04	Main- 1st floor Fountain 1 by Storage room	Flush180	27-MAY-16	50.900	ppb
51310	51310-1-HAL-F04	Main- 1st floor Fountain 1 by Storage room	Flush180	27-MAY-16	0.173	ppb
51310	51310-1-HAL-F04	Main- 1st floor Fountain 1 by Storage room	Flush180	27-MAY-16	2.180	ppb
51310	51310-1-HAL-F04	Main- 1st floor Fountain 1 by Storage room	Flush180	27-MAY-16	6.120	ppb
51310	51310-1-HAL-F04	Main- 1st floor Fountain 1 by Storage room	Flush180	19-AUG-20	1.000	ug/L
51310	51310-1-HAL-F04	Main- 1st floor Fountain 1 by Storage room	Initial	27-MAY-16	0.893	ppb
51310	51310-1-HAL-F04	Main- 1st floor Fountain 1 by Storage room	Initial	19-AUG-20	1.000	ug/L
51310	51310-1-HAL-F08	Main- 1st floor Fountain 1 by kitchen	Flush180	27-MAY-16	0.421	ppb
51310	51310-1-HAL-F08	Main- 1st floor Fountain 1 by kitchen	Flush180	27-MAY-16	0.641	ppb
51310	51310-1-HAL-F08	Main- 1st floor Fountain 1 by kitchen	Flush180	27-MAY-16	0.423	ppb
51310	51310-1-HAL-F08	Main- 1st floor Fountain 1 by kitchen	Flush180	27-MAY-16	0.455	ppb
51310	51310-1-HAL-F08	Main- 1st floor Fountain 1 by kitchen	Initial	27-MAY-16	0.494	ppb
51310	51310-1-HAL-F03	Main- 1st floor Fountain 2 by Office	Flush180	27-MAY-16	0.187	ppb
51310	51310-1-HAL-F03	Main- 1st floor Fountain 2 by Office	Flush180	27-MAY-16	0.149	ppb
51310	51310-1-HAL-F03	Main- 1st floor Fountain 2 by Office	Flush180	27-MAY-16	0.136	ppb
51310	51310-1-HAL-F03	Main- 1st floor Fountain 2 by Office	Flush180	27-MAY-16	0.352	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51310	51310-1-HAL-F03	Main- 1st floor Fountain 2 by Office	Initial	27-MAY-16	0.140	ppb
51310	51310-1-HAL-F05	Main- 1st floor Fountain 2 by Storage room	Flush180	27-MAY-16	1.000	ppb
51310	51310-1-HAL-F05	Main- 1st floor Fountain 2 by Storage room	Flush180	27-MAY-16	1.000	ppb
51310	51310-1-HAL-F05	Main- 1st floor Fountain 2 by Storage room	Flush180	27-MAY-16	0.132	ppb
51310	51310-1-HAL-F05	Main- 1st floor Fountain 2 by Storage room	Flush180	27-MAY-16	1.000	ppb
51310	51310-1-HAL-F05	Main- 1st floor Fountain 2 by Storage room	Initial	27-MAY-16	0.122	ppb
51310	51310-1-HAL-F09	Main- 1st floor Fountain 2 by kitchen	Flush180	27-MAY-16	0.575	ppb
51310	51310-1-HAL-F09	Main- 1st floor Fountain 2 by kitchen	Flush180	27-MAY-16	3.050	ppb
51310	51310-1-HAL-F09	Main- 1st floor Fountain 2 by kitchen	Flush180	27-MAY-16	0.691	ppb
51310	51310-1-HAL-F09	Main- 1st floor Fountain 2 by kitchen	Flush180	27-MAY-16	0.617	ppb
51310	51310-1-HAL-F09	Main- 1st floor Fountain 2 by kitchen	Initial	27-MAY-16	0.472	ppb
51310	51310-1-HAL-F02	Main- 1st floor Fountain by Office	Flush180	27-MAY-16	1.750	ppb
51310	51310-1-HAL-F02	Main- 1st floor Fountain by Office	Flush180	27-MAY-16	0.412	ppb
51310	51310-1-HAL-F02	Main- 1st floor Fountain by Office	Flush180	27-MAY-16	0.179	ppb
51310	51310-1-HAL-F02	Main- 1st floor Fountain by Office	Flush180	27-MAY-16	0.205	ppb
51310	51310-1-HAL-F02	Main- 1st floor Fountain by Office	Initial	27-MAY-16	0.182	ppb
51310	51310-1-HAL-F06	Main- 1st floor Fountain by girls toilets	Flush180	27-MAY-16	0.159	ppb
51310	51310-1-HAL-F06	Main- 1st floor Fountain by girls toilets	Flush180	27-MAY-16	1.000	ppb
51310	51310-1-HAL-F06	Main- 1st floor Fountain by girls toilets	Flush180	27-MAY-16	1.000	ppb
51310	51310-1-HAL-F06	Main- 1st floor Fountain by girls toilets	Flush180	27-MAY-16	0.129	ppb
51310	51310-1-HAL-F06	Main- 1st floor Fountain by girls toilets	Initial	27-MAY-16	1.000	ppb
51310	51310-1-KIT-KS07	Main- 1st floor Kitchen Sink	Flush180	27-MAY-16	0.741	ppb
51310	51310-1-KIT-KS07	Main- 1st floor Kitchen Sink	Flush180	27-MAY-16	0.291	ppb
51310	51310-1-KIT-KS07	Main- 1st floor Kitchen Sink	Flush180	27-MAY-16	0.512	ppb
51310	51310-1-KIT-KS07	Main- 1st floor Kitchen Sink	Flush180	27-MAY-16	0.513	ppb
51310	51310-1-KIT-KS07	Main- 1st floor Kitchen Sink	Initial	27-MAY-16	0.534	ppb
51310	51310-2-HAL-F05	Main- 2nd floor Fountain 1 by Room 209	Flush180	27-MAY-16	0.315	ppb
51310	51310-2-HAL-F05	Main- 2nd floor Fountain 1 by Room 209	Flush180	27-MAY-16	0.409	ppb
51310	51310-2-HAL-F05	Main- 2nd floor Fountain 1 by Room 209	Flush180	27-MAY-16	0.146	ppb
51310	51310-2-HAL-F05	Main- 2nd floor Fountain 1 by Room 209	Flush180	27-MAY-16	0.303	ppb
51310	51310-2-HAL-F05	Main- 2nd floor Fountain 1 by Room 209	Initial	27-MAY-16	0.296	ppb
51310	51310-2-HAL-F06	Main- 2nd floor Fountain 2 by Room 209	Flush180	27-MAY-16	0.260	ppb
51310	51310-2-HAL-F06	Main- 2nd floor Fountain 2 by Room 209	Flush180	27-MAY-16	0.250	ppb
51310	51310-2-HAL-F06	Main- 2nd floor Fountain 2 by Room 209	Flush180	27-MAY-16	0.247	ppb
51310	51310-2-HAL-F06	Main- 2nd floor Fountain 2 by Room 209	Flush180	27-MAY-16	0.259	ppb
51310	51310-2-HAL-F06	Main- 2nd floor Fountain 2 by Room 209	Initial	27-MAY-16	0.189	ppb
51310	51310-2-HAL-F02	Main- 2nd floor Fountain by Room 201	Flush180	27-MAY-16	1.280	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51310	51310-2-HAL-F02	Main- 2nd floor Fountain by Room 201	Flush180	27-MAY-16	0.844	ppb
51310	51310-2-HAL-F02	Main- 2nd floor Fountain by Room 201	Flush180	27-MAY-16	1.100	ppb
51310	51310-2-HAL-F02	Main- 2nd floor Fountain by Room 201	Flush180	27-MAY-16	1.680	ppb
51310	51310-2-HAL-F02	Main- 2nd floor Fountain by Room 201	Initial	27-MAY-16	1.760	ppb
51310	51310-2-HAL-F04	Main- 2nd floor Fountain by Room 206	Flush180	27-MAY-16	0.476	ppb
51310	51310-2-HAL-F04	Main- 2nd floor Fountain by Room 206	Flush180	27-MAY-16	0.159	ppb
51310	51310-2-HAL-F04	Main- 2nd floor Fountain by Room 206	Flush180	27-MAY-16	0.215	ppb
51310	51310-2-HAL-F04	Main- 2nd floor Fountain by Room 206	Flush180	27-MAY-16	0.200	ppb
51310	51310-2-HAL-F04	Main- 2nd floor Fountain by Room 206	Initial	27-MAY-16	0.139	ppb
51310	51310-2-HAL-F07	Main- 2nd floor Fountain by Room 211	Flush180	27-MAY-16	0.891	ppb
51310	51310-2-HAL-F07	Main- 2nd floor Fountain by Room 211	Flush180	27-MAY-16	0.773	ppb
51310	51310-2-HAL-F07	Main- 2nd floor Fountain by Room 211	Flush180	27-MAY-16	0.997	ppb
51310	51310-2-HAL-F07	Main- 2nd floor Fountain by Room 211	Flush180	27-MAY-16	1.010	ppb
51310	51310-2-HAL-F07	Main- 2nd floor Fountain by Room 211	Initial	27-MAY-16	1.010	ppb
51310	51310-3-HAL-F03	Main- 3rd floor Fountain 1 by Room 306	Flush180	27-MAY-16	1.200	ppb
51310	51310-3-HAL-F03	Main- 3rd floor Fountain 1 by Room 306	Flush180	27-MAY-16	1.280	ppb
51310	51310-3-HAL-F03	Main- 3rd floor Fountain 1 by Room 306	Flush180	27-MAY-16	1.200	ppb
51310	51310-3-HAL-F03	Main- 3rd floor Fountain 1 by Room 306	Flush180	27-MAY-16	1.320	ppb
51310	51310-3-HAL-F03	Main- 3rd floor Fountain 1 by Room 306	Initial	27-MAY-16	1.200	ppb
51310	51310-3-HAL-F04	Main- 3rd floor Fountain 2 by Room 306	Flush180	27-MAY-16	0.711	ppb
51310	51310-3-HAL-F04	Main- 3rd floor Fountain 2 by Room 306	Flush180	27-MAY-16	0.645	ppb
51310	51310-3-HAL-F04	Main- 3rd floor Fountain 2 by Room 306	Flush180	27-MAY-16	0.594	ppb
51310	51310-3-HAL-F04	Main- 3rd floor Fountain 2 by Room 306	Flush180	27-MAY-16	0.478	ppb
51310	51310-3-HAL-F04	Main- 3rd floor Fountain 2 by Room 306	Initial	27-MAY-16	0.469	ppb
51310	51310-3-HAL-F02	Main- 3rd floor Fountain by Room 301	Flush180	27-MAY-16	1.140	ppb
51310	51310-3-HAL-F02	Main- 3rd floor Fountain by Room 301	Flush180	27-MAY-16	1.520	ppb
51310	51310-3-HAL-F02	Main- 3rd floor Fountain by Room 301	Flush180	27-MAY-16	1.880	ppb
51310	51310-3-HAL-F02	Main- 3rd floor Fountain by Room 301	Flush180	27-MAY-16	1.740	ppb
51310	51310-3-HAL-F02	Main- 3rd floor Fountain by Room 301	Initial	27-MAY-16	0.750	ppb
51310	51310-3-HAL-F05	Main- 3rd floor Fountain by Room 307	Flush180	27-MAY-16	0.538	ppb
51310	51310-3-HAL-F05	Main- 3rd floor Fountain by Room 307	Flush180	27-MAY-16	0.412	ppb
51310	51310-3-HAL-F05	Main- 3rd floor Fountain by Room 307	Flush180	27-MAY-16	0.485	ppb
51310	51310-3-HAL-F05	Main- 3rd floor Fountain by Room 307	Flush180	27-MAY-16	0.352	ppb
51310	51310-3-HAL-F05	Main- 3rd floor Fountain by Room 307	Flush180	19-AUG-20	2.150	ug/L
51310	51310-3-HAL-F05	Main- 3rd floor Fountain by Room 307	Initial	27-MAY-16	0.479	ppb
51310	51310-3-HAL-F05	Main- 3rd floor Fountain by Room 307	Initial	19-AUG-20	2.040	ug/L
51310	51310-1-HAL-F10	Main- Left Fountain by Main Office	Flush180	07-SEP-23	1.000	ug/L
51310	51310-1-HAL-	Main- Left Fountain by Main Office	Flush180	07-SEP-23	1.040	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F10					
51310	51310-1-HAL-F10	Main- Left Fountain by Main Office	Flush180	07-SEP-23	1.000	ug/L
51310	51310-1-HAL-F10	Main- Left Fountain by Main Office	Flush180	07-SEP-23	4.210	ug/L
51310	51310-1-HAL-F10	Main- Left Fountain by Main Office	Initial	07-SEP-23	1.000	ug/L
51310	51310-3-HAL-BF01	Third Floor Bottle Filler	Flush180	22-DEC-20	1.000	ug/L
51310	51310-3-HAL-BF01	Third Floor Bottle Filler	Flush180	22-DEC-20	1.000	ug/L
51310	51310-3-HAL-BF01	Third Floor Bottle Filler	Flush180	22-DEC-20	1.000	ug/L
51310	51310-3-HAL-BF01	Third Floor Bottle Filler	Flush180	22-DEC-20	1.030	ug/L
51310	51310-3-HAL-BF01	Third Floor Bottle Filler	Initial	22-DEC-20	1.000	ug/L
54257	54257-1-HAL-F09	Modular- 1st floor Corridor N. Fountain 1	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F09	Modular- 1st floor Corridor N. Fountain 1	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F09	Modular- 1st floor Corridor N. Fountain 1	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F09	Modular- 1st floor Corridor N. Fountain 1	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F09	Modular- 1st floor Corridor N. Fountain 1	Initial	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F11	Modular- 1st floor Corridor N. Fountain 3	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F11	Modular- 1st floor Corridor N. Fountain 3	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F11	Modular- 1st floor Corridor N. Fountain 3	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F11	Modular- 1st floor Corridor N. Fountain 3	Initial	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F10	Modular- 1st floor Corridor N. fountain 2	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F10	Modular- 1st floor Corridor N. fountain 2	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F10	Modular- 1st floor Corridor N. fountain 2	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F10	Modular- 1st floor Corridor N. fountain 2	Flush180	27-MAY-16	0.134	ppb
54257	54257-1-HAL-F10	Modular- 1st floor Corridor N. fountain 2	Initial	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F02	Modular- 1st floor Fountain by Room 121	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F02	Modular- 1st floor Fountain by Room 121	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F02	Modular- 1st floor Fountain by Room 121	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F02	Modular- 1st floor Fountain by Room 121	Initial	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F04	Modular- 1st floor Fountain by room 122	Flush180	27-MAY-16	0.140	ppb
54257	54257-1-HAL-F04	Modular- 1st floor Fountain by room 122	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F04	Modular- 1st floor Fountain by room 122	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F04	Modular- 1st floor Fountain by room 122	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F04	Modular- 1st floor Fountain by room 122	Initial	27-MAY-16	0.218	ppb
54257	54257-1-HAL-F06	Modular- 1st floor Fountain by room 123	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F06	Modular- 1st floor Fountain by room 123	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F06	Modular- 1st floor Fountain by room 123	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F06	Modular- 1st floor Fountain by room 123	Flush180	27-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	room 123				
54257	54257-1-HAL-F06	Modular- 1st floor Fountain by room 123	Flush180	19-AUG-20	1.000	ug/L
54257	54257-1-HAL-F06	Modular- 1st floor Fountain by room 123	Initial	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F06	Modular- 1st floor Fountain by room 123	Initial	19-AUG-20	1.000	ug/L
54257	54257-1-124-F08	Modular- 1st floor Fountain in Room 124	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-124-F08	Modular- 1st floor Fountain in Room 124	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-124-F08	Modular- 1st floor Fountain in Room 124	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-124-F08	Modular- 1st floor Fountain in Room 124	Initial	27-MAY-16	0.127	ppb
54257	54257-1-126-F15	Modular- 1st floor Fountain in Room 126	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-126-F15	Modular- 1st floor Fountain in Room 126	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-126-F15	Modular- 1st floor Fountain in Room 126	Flush180	27-MAY-16	0.208	ppb
54257	54257-1-126-F15	Modular- 1st floor Fountain in Room 126	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-126-F15	Modular- 1st floor Fountain in Room 126	Initial	27-MAY-16	1.000	ppb
54257	54257-1-127-F17	Modular- 1st floor Fountain in Room 127	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-127-F17	Modular- 1st floor Fountain in Room 127	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-127-F17	Modular- 1st floor Fountain in Room 127	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-127-F17	Modular- 1st floor Fountain in Room 127	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-127-F17	Modular- 1st floor Fountain in Room 127	Initial	27-MAY-16	1.000	ppb
54257	54257-1-125-F13	Modular- 1st floor Fountian in Room 125	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-125-F13	Modular- 1st floor Fountian in Room 125	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-125-F13	Modular- 1st floor Fountian in Room 125	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-125-F13	Modular- 1st floor Fountian in Room 125	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-125-F13	Modular- 1st floor Fountian in Room 125	Initial	27-MAY-16	1.000	ppb
54257	54257-1-128-F19	Modular- 1st floor Fountian in Room 128	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-128-F19	Modular- 1st floor Fountian in Room 128	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-128-F19	Modular- 1st floor Fountian in Room 128	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-128-F19	Modular- 1st floor Fountian in Room 128	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-128-F19	Modular- 1st floor Fountian in Room 128	Flush180	19-AUG-20	1.000	ug/L
54257	54257-1-128-F19	Modular- 1st floor Fountian in Room 128	Initial	27-MAY-16	1.000	ppb
54257	54257-1-128-F19	Modular- 1st floor Fountian in Room 128	Initial	19-AUG-20	1.000	ug/L
54257	54257-1-121-S01	Modular- 1st floor Sink in Room 121	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-121-S01	Modular- 1st floor Sink in Room 121	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-121-S01	Modular- 1st floor Sink in Room 121	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-121-S01	Modular- 1st floor Sink in Room 121	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-121-S01	Modular- 1st floor Sink in Room 121	Initial	27-MAY-16	1.000	ppb
54257	54257-1-124-S07	Modular- 1st floor Sink in Room 124	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-124-S07	Modular- 1st floor Sink in Room 124	Flush180	27-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54257	54257-1-124-S07	Modular- 1st floor Sink in Room 124	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-124-S07	Modular- 1st floor Sink in Room 124	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-124-S07	Modular- 1st floor Sink in Room 124	Initial	27-MAY-16	0.275	ppb
54257	54257-1-125-S12	Modular- 1st floor Sink in Room 125	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-125-S12	Modular- 1st floor Sink in Room 125	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-125-S12	Modular- 1st floor Sink in Room 125	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-125-S12	Modular- 1st floor Sink in Room 125	Flush180	27-MAY-16	0.166	ppb
54257	54257-1-125-S12	Modular- 1st floor Sink in Room 125	Initial	27-MAY-16	1.000	ppb
54257	54257-1-126-S14	Modular- 1st floor Sink in Room 126	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-126-S14	Modular- 1st floor Sink in Room 126	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-126-S14	Modular- 1st floor Sink in Room 126	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-126-S14	Modular- 1st floor Sink in Room 126	Initial	27-MAY-16	0.198	ppb
54257	54257-1-127-S16	Modular- 1st floor Sink in Room 127	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-127-S16	Modular- 1st floor Sink in Room 127	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-127-S16	Modular- 1st floor Sink in Room 127	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-127-S16	Modular- 1st floor Sink in Room 127	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-127-S16	Modular- 1st floor Sink in Room 127	Initial	27-MAY-16	0.168	ppb
54257	54257-1-128-S18	Modular- 1st floor Sink in Room 128	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-128-S18	Modular- 1st floor Sink in Room 128	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-128-S18	Modular- 1st floor Sink in Room 128	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-128-S18	Modular- 1st floor Sink in Room 128	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-128-S18	Modular- 1st floor Sink in Room 128	Initial	27-MAY-16	0.253	ppb
54257	54257-1-122-S03	Modular- 1st floor Sink in room 122	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-122-S03	Modular- 1st floor Sink in room 122	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-122-S03	Modular- 1st floor Sink in room 122	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-122-S03	Modular- 1st floor Sink in room 122	Initial	27-MAY-16	0.165	ppb
54257	54257-1-123-S05	Modular- 1st floor Sink room 123	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-123-S05	Modular- 1st floor Sink room 123	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-123-S05	Modular- 1st floor Sink room 123	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-123-S05	Modular- 1st floor Sink room 123	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-123-S05	Modular- 1st floor Sink room 123	Initial	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F20	Modular- 1st floor corridor S. Sink	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F20	Modular- 1st floor corridor S. Sink	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F20	Modular- 1st floor corridor S. Sink	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F20	Modular- 1st floor corridor S. Sink	Flush180	27-MAY-16	1.000	ppb

Water Quality Assessment Monarcas Academy

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54257	54257-1-HAL-F20	Modular- 1st floor corridor S. Sink	Initial	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F21	Modular- 1st floor corridor W. Fountain	Flush180	27-MAY-16	0.144	ppb
54257	54257-1-HAL-F21	Modular- 1st floor corridor W. Fountain	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F21	Modular- 1st floor corridor W. Fountain	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F21	Modular- 1st floor corridor W. Fountain	Flush180	27-MAY-16	1.000	ppb
54257	54257-1-HAL-F21	Modular- 1st floor corridor W. Fountain	Initial	27-MAY-16	1.000	ppb