



Sep 10, 2024

MORTON

431 N TROY ST, Chicago IL 60612.

Dear **MORTON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

MORTON

431 N TROY ST, Chicago IL 60612.

Estimadas familias de **MORTON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anejo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51150	51150-1-N-KIT-KS02		Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS02		Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS02		Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS02		Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS03		Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS03		Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS03		Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS03		Flush180	24-JAN-20	1.000	ug/L
51150	51150-2-S-HAL-F01		Flush180	24-JAN-20	1.000	ug/L
51150	51150-2-S-HAL-F01		Flush180	24-JAN-20	1.000	ug/L
51150	51150-2-S-HAL-F01		Flush180	24-JAN-20	1.000	ug/L
51150	51150-2-S-HAL-F01		Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS02		Initial	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS03		Initial	24-JAN-20	1.000	ug/L
51150	51150-2-S-HAL-F01		Initial	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Flush180	18-JUN-16	0.208	ppb
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Flush180	18-JUN-16	0.208	ppb
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Flush180	18-JUN-16	0.207	ppb
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Flush180	18-JUN-16	0.204	ppb
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Initial	18-JUN-16	0.205	ppb
51150	51150-1-E-HAL-F01	Across From Room 104 (North), Fountain 1	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Flush180	18-JUN-16	0.433	ppb
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Flush180	18-JUN-16	0.253	ppb
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Flush180	18-JUN-16	0.348	ppb
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Flush180	18-JUN-16	0.262	ppb
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Flush180	24-JAN-20	2.670	ug/L
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Initial	18-JUN-16	0.395	ppb
51150	51150-1-E-HAL-F02	Across From Room 104 (South), Fountain 2	Initial	24-JAN-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Flush180	18-JUN-16	0.210	ppb
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Flush180	18-JUN-16	0.156	ppb
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Flush180	18-JUN-16	0.235	ppb
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Flush180	18-JUN-16	0.192	ppb
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Initial	18-JUN-16	0.205	ppb
51150	51150-2-S-HAL-F02	Across From Room 203 (West), Fountain 2	Initial	24-JAN-20	1.000	ug/L
51150	51150-3-HAL-F01	Across From Room 303 (East), Fountain 1	Flush180	18-JUN-16	2.930	ppb
51150	51150-3-HAL-F01	Across From Room 303 (East), Fountain 1	Flush180	18-JUN-16	0.237	ppb
51150	51150-3-HAL-F01	Across From Room 303 (East), Fountain 1	Flush180	18-JUN-16	0.299	ppb
51150	51150-3-HAL-F01	Across From Room 303 (East), Fountain 1	Flush180	18-JUN-16	0.269	ppb
51150	51150-3-HAL-F01	Across From Room 303 (East), Fountain 1	Initial	18-JUN-16	0.218	ppb
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Flush180	18-JUN-16	0.313	ppb
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Flush180	18-JUN-16	0.265	ppb
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Flush180	18-JUN-16	0.257	ppb
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Flush180	18-JUN-16	0.255	ppb
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Initial	18-JUN-16	0.272	ppb
51150	51150-3-S-HAL-F02	Across From Room 303 (West), Fountain 2	Initial	24-JAN-20	1.000	ug/L
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Flush180	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Flush180	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Flush180	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Flush180	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Flush180	19-AUG-20	1.000	ug/L
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Flush180	01-MAY-20	1.000	ug/L
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Flush180	01-MAY-20	1.000	ug/L
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Flush180	01-MAY-20	1.000	ug/L
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Initial	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Initial	19-AUG-20	1.780	ug/L
51150	51150-4-HAL-F01	Across From Room 403 (East), Fountain 1	Initial	01-MAY-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	18-JUN-16	15.400	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	18-JUN-16	9.250	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	18-JUN-16	6.300	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	18-JUN-16	25.600	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	01-MAY-20	1.000	ug/L
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	01-MAY-20	1.000	ug/L
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	01-MAY-20	1.000	ug/L
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Flush180	01-MAY-20	1.000	ug/L
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Initial	25-AUG-16	1.000	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Initial	18-JUN-16	17.500	ppb
51150	51150-4-HAL-F02	Across From Room 403 (West), Fountain 2	Initial	01-MAY-20	1.920	ug/L
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Flush180	18-JUN-16	0.247	ppb
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Flush180	18-JUN-16	0.292	ppb
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Flush180	18-JUN-16	0.244	ppb
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Flush180	18-JUN-16	0.224	ppb
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Initial	18-JUN-16	0.216	ppb
51150	51150-4-N-HAL-F03	Across From Room 408, Fountain 2	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	18-JUN-16	0.624	ppb
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	18-JUN-16	0.658	ppb
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	18-JUN-16	0.607	ppb
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	18-JUN-16	0.452	ppb
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	24-JAN-20	3.190	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	24-JAN-20	1.410	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	01-MAY-20	1.000	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	01-MAY-20	1.000	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	01-MAY-20	1.000	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Flush180	01-MAY-20	1.000	ug/L
51150	51150-1-S-	Inside Room 108 (North Center),	Initial	18-JUN-16	0.658	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	108-S06	Sink 2				
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Initial	24-JAN-20	59.400	ug/L
51150	51150-1-S-108-S06	Inside Room 108 (North Center), Sink 2	Initial	01-MAY-20	1.000	ug/L
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Flush180	18-JUN-16	0.613	ppb
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Flush180	18-JUN-16	0.770	ppb
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Flush180	18-JUN-16	0.634	ppb
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Flush180	18-JUN-16	0.585	ppb
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Initial	18-JUN-16	3.700	ppb
51150	51150-1-W-108-S05	Inside Room 108 (North), Sink 1	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Flush180	18-JUN-16	0.805	ppb
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Flush180	18-JUN-16	0.786	ppb
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Flush180	18-JUN-16	0.469	ppb
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Flush180	18-JUN-16	0.786	ppb
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Initial	18-JUN-16	0.786	ppb
51150	51150-1-S-108-S07	Inside Room 108 (South Center), Sink 3	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Flush180	18-JUN-16	0.234	ppb
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Flush180	18-JUN-16	0.284	ppb
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Flush180	18-JUN-16	0.310	ppb
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Flush180	18-JUN-16	0.214	ppb
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Initial	18-JUN-16	1.000	ppb
51150	51150-1-S-108-S08	Inside Room 108 (South), Sink 4	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Flush180	18-JUN-16	0.376	ppb
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Flush180	18-JUN-16	0.352	ppb
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Flush180	18-JUN-16	0.326	ppb
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Flush180	18-JUN-16	0.158	ppb
51150	51150-1-E-	Inside Room 109 (Center), Sink 2	Flush180	24-JAN-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	109-S10					
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Initial	18-JUN-16	0.745	ppb
51150	51150-1-E-109-S10	Inside Room 109 (Center), Sink 2	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Flush180	18-JUN-16	0.465	ppb
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Flush180	18-JUN-16	0.446	ppb
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Flush180	18-JUN-16	0.447	ppb
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Flush180	18-JUN-16	0.491	ppb
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Initial	18-JUN-16	0.388	ppb
51150	51150-1-E-109-S09	Inside Room 109 (North), Sink 1	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Flush180	18-JUN-16	0.293	ppb
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Flush180	18-JUN-16	0.175	ppb
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Flush180	18-JUN-16	0.224	ppb
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Flush180	18-JUN-16	0.242	ppb
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Initial	18-JUN-16	0.230	ppb
51150	51150-1-E-109-S11	Inside Room 109 (South), Sink	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Flush180	18-JUN-16	1.000	ppb
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Flush180	18-JUN-16	1.000	ppb
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Flush180	18-JUN-16	1.000	ppb
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Flush180	18-JUN-16	1.000	ppb
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Initial	18-JUN-16	1.000	ppb
51150	51150-1-N-110-WC14	Inside Room 110, Fountain	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-N-KIT-KS04	Kitchen, Sink	Flush180	18-JUN-16	0.138	ppb
51150	51150-1-N-KIT-KS04	Kitchen, Sink	Flush180	18-JUN-16	0.250	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51150	51150-1-W-HAL-F12	Outside Room 109 (North), Fountain 1	Initial	18-JUN-16	0.567	ppb
51150	51150-1-W-HAL-F12	Outside Room 109 (North), Fountain 1	Initial	19-AUG-20	1.000	ug/L
51150	51150-1-W-HAL-F12	Outside Room 109 (North), Fountain 1	Initial	24-JAN-20	1.000	ug/L
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Flush180	18-JUN-16	0.591	ppb
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Flush180	18-JUN-16	0.355	ppb
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Flush180	18-JUN-16	0.555	ppb
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Flush180	18-JUN-16	0.601	ppb
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Flush180	24-JAN-20	1.000	ug/L
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Initial	18-JUN-16	0.480	ppb
51150	51150-1-W-HAL-F13	Outside Room 109 (South), Fountain 2	Initial	24-JAN-20	1.000	ug/L