



Sep 10, 2024

NEIL

8555 S MICHIGAN AVE, Chicago IL 60619.

Dear **NEIL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

NEIL

8555 S MICHIGAN AVE, Chicago IL 60619.

Estimadas familias de **NEIL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51473	51473-1-HAL-F20	Bottle Filler across from girls restroom	Flush180	06-JAN-21	1.000	ug/L
51473	51473-1-HAL-F20	Bottle Filler across from girls restroom	Flush180	06-JAN-21	1.000	ug/L
51473	51473-1-HAL-F20	Bottle Filler across from girls restroom	Initial	06-JAN-21	1.000	ug/L
51473	51473-1-HAL-F20	Bottle Filler across from girls restroom	Initial	06-JAN-21	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Initial	10-FEB-22	1.030	ug/L
51473	51473-1-HAL-RBF01	Bottle Filler across from girls restroom	Initial	10-FEB-22	1.030	ug/L
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F14	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F13	Main- 1st Floor Adjacent to Medical Needs Bathroom	Flush180	10-FEB-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51473	51473-1-HAL-F18	Main- 1st Floor Adjacent to Room 100 Left, Fountai	Initial	10-FEB-22	1.150	ug/L
51473	51473-1-HAL-F18	Main- 1st Floor Adjacent to Room 100 Left, Fountai	Initial	10-FEB-22	1.150	ug/L
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	15-SEP-16	2.900	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	15-SEP-16	2.900	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	15-SEP-16	2.300	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	15-SEP-16	2.300	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	15-SEP-16	3.600	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	15-SEP-16	3.600	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Initial	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F19	Main- 1st Floor Adjacent to Room 100 Right, Founta	Initial	15-SEP-16	2.000	ppb
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	10-FEB-22	4.740	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	10-FEB-22	4.740	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	10-FEB-22	1.490	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	10-FEB-22	1.490	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	10-FEB-22	1.240	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	10-FEB-22	1.240	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	10-FEB-22	1.370	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Flush180	10-FEB-22	1.370	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Initial	10-FEB-22	1.530	ug/L
51473	51473-1-HAL-RBF02	Main- 1st Floor Adjacent to Room 100 Right, Founta	Initial	10-FEB-22	1.530	ug/L
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	15-SEP-16	2.300	ppb
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	15-SEP-16	2.300	ppb
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	15-SEP-16	4.600	ppb
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	15-SEP-16	4.600	ppb
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	15-SEP-16	2.700	ppb
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	15-SEP-16	2.700	ppb
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	10-FEB-22	19.300	ug/L
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	10-FEB-22	19.300	ug/L
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	10-FEB-22	6.510	ug/L
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	10-FEB-22	6.510	ug/L
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	10-FEB-22	5.440	ug/L
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	10-FEB-22	5.440	ug/L
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	10-FEB-22	5.190	ug/L
51473	51473-1-HAL-F07	Main- 1st Floor Adjacent to Room 112 Left, Fountai	Flush180	10-FEB-22	5.190	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F08	112 Right, Founta				
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	10-FEB-22	2.930	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	10-FEB-22	2.540	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	10-FEB-22	2.540	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	15-SEP-22	4.290	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	15-SEP-22	4.290	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	15-SEP-22	3.250	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	15-SEP-22	3.250	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	15-SEP-22	4.740	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	15-SEP-22	4.740	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	18-AUG-22	6.150	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	18-AUG-22	6.150	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	18-AUG-22	4.580	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	18-AUG-22	4.580	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	18-AUG-22	3.840	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	18-AUG-22	3.840	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	18-AUG-22	4.100	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	18-AUG-22	4.100	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	15-SEP-22	4.680	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	15-SEP-22	4.680	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	04-OCT-22	1.470	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	04-OCT-22	1.470	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	04-OCT-22	1.290	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	04-OCT-22	1.290	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	04-OCT-22	1.120	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	04-OCT-22	1.120	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	04-OCT-22	1.160	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Flush180	04-OCT-22	1.160	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	15-SEP-16	3.300	ppb
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	15-SEP-16	3.300	ppb
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	10-FEB-22	6.600	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	10-FEB-22	6.600	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	15-SEP-22	5.140	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	15-SEP-22	5.140	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	18-AUG-22	6.180	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	18-AUG-22	6.180	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	04-OCT-22	1.680	ug/L
51473	51473-1-HAL-F08	Main- 1st Floor Adjacent to Room 112 Right, Founta	Initial	04-OCT-22	1.680	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51473	51473-1-101-S20	Main- 1st Floor Inside Room 101, Sink	Initial	15-SEP-16	2.500	ppb
51473	51473-1-101-S20	Main- 1st Floor Inside Room 101, Sink	Initial	10-FEB-22	1.000	ug/L
51473	51473-1-101-S20	Main- 1st Floor Inside Room 101, Sink	Initial	10-FEB-22	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-SEP-16	3.600	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-SEP-16	3.600	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-SEP-16	4.600	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-SEP-16	4.600	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-SEP-16	5.600	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-SEP-16	5.600	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-SEP-16	4.500	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-SEP-16	4.500	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-OCT-20	1.280	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Flush180	15-OCT-20	1.280	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Initial	15-SEP-16	4.900	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Initial	15-SEP-16	4.900	ppb
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Initial	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Initial	09-DEC-20	1.000	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Initial	15-OCT-20	5.050	ug/L
51473	51473-1-102-S17	Main- 1st Floor Inside Room 102, Sink	Initial	15-OCT-20	5.050	ug/L
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	06-JAN-21	1.000	ug/L
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	06-JAN-21	1.000	ug/L
51473	51473-1-KIT-KS10	Main- 1st Floor KITchen Center Left, Sink	Flush180	10-FEB-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS11	Right, Sink				
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	06-JAN-21	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	06-JAN-21	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Initial	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Initial	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Initial	06-JAN-21	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Initial	06-JAN-21	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Initial	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS09	Main- 1st Floor KITchen Left, Sink	Initial	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	06-JAN-21	1.000	ug/L
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	06-JAN-21	1.000	ug/L
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-KIT-KS12	Main- 1st Floor KITchen Right, Sink	Flush180	10-FEB-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	10-FEB-22	1.270	ug/L
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	10-FEB-22	1.270	ug/L
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Initial	15-SEP-16	2.100	ppb
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Initial	15-SEP-16	2.100	ppb
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Initial	10-FEB-22	4.850	ug/L
51473	51473-1-HAL-F05	Main- 1st Floor Next to Principle's Office Right,	Initial	10-FEB-22	4.850	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	15-SEP-16	2.400	ppb
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	15-SEP-16	2.400	ppb
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	06-JAN-21	5.070	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	06-JAN-21	5.070	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	20-JAN-21	29.700	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	20-JAN-21	29.700	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	10-FEB-22	1.000	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	20-JAN-21	25.600	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	20-JAN-21	25.600	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	20-JAN-21	18.700	ug/L
51473	51473-1-HAL-F04	Main- In Between Rooms 137/135 Left, Fountain	Flush180	20-JAN-21	18.700	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Right, Fountain				
51473	51473-1-HAL-F03	Main- In Between Rooms 137/135 Right, Fountain	Initial	15-SEP-16	2.300	ppb
51473	51473-1-HAL-F03	Main- In Between Rooms 137/135 Right, Fountain	Initial	10-FEB-22	2.770	ug/L
51473	51473-1-HAL-F03	Main- In Between Rooms 137/135 Right, Fountain	Initial	10-FEB-22	2.770	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-SEP-16	2.100	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-SEP-16	2.100	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-SEP-16	2.000	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	09-DEC-20	4.050	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	09-DEC-20	4.050	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	09-DEC-20	2.230	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	09-DEC-20	2.230	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	09-DEC-20	2.070	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	09-DEC-20	2.070	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	09-DEC-20	1.910	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	09-DEC-20	1.910	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	22-DEC-20	1.000	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	22-DEC-20	1.000	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	22-DEC-20	1.000	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	22-DEC-20	1.000	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	22-DEC-20	1.000	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	22-DEC-20	1.000	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	22-DEC-20	1.000	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	22-DEC-20	1.000	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-OCT-20	3.520	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Flush180	15-OCT-20	3.520	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Initial	15-SEP-16	2.600	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Initial	15-SEP-16	2.600	ppb
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Initial	22-DEC-20	1.190	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Initial	22-DEC-20	1.190	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Initial	09-DEC-20	5.120	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Initial	09-DEC-20	5.120	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Initial	15-OCT-20	5.440	ug/L
51473	51473-1-HAL-F15	Main-1st Floor Adjacent to Restroom Left, Fountain	Initial	15-OCT-20	5.440	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	22-SEP-21	1.600	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	22-SEP-21	1.600	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	22-SEP-21	1.090	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	22-SEP-21	1.090	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	22-SEP-21	1.000	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	22-SEP-21	1.000	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	22-SEP-21	1.000	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	22-SEP-21	1.000	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	10-FEB-22	1.100	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	10-FEB-22	1.100	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	10-FEB-22	1.620	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	10-FEB-22	1.620	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	10-FEB-22	2.150	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	10-FEB-22	2.150	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	10-FEB-22	1.940	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Flush180	10-FEB-22	1.940	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Initial	22-SEP-21	1.370	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Initial	22-SEP-21	1.370	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Initial	10-FEB-22	1.020	ug/L
51473	51473-1-102-F01	Room 102 Drinking Fountain	Initial	10-FEB-22	1.020	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	22-SEP-21	1.430	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	22-SEP-21	1.430	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	22-SEP-21	1.800	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	22-SEP-21	1.800	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	22-SEP-21	2.170	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	22-SEP-21	2.170	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	10-FEB-22	6.490	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	10-FEB-22	6.490	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	10-FEB-22	5.950	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51473	51473-1-102-S01	Room 102 Sink	Flush180	10-FEB-22	5.950	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	10-FEB-22	4.860	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	10-FEB-22	4.860	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	10-FEB-22	3.980	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	10-FEB-22	3.980	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	22-SEP-21	1.420	ug/L
51473	51473-1-102-S01	Room 102 Sink	Flush180	22-SEP-21	1.420	ug/L
51473	51473-1-102-S01	Room 102 Sink	Initial	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Initial	18-AUG-22	1.000	ug/L
51473	51473-1-102-S01	Room 102 Sink	Initial	10-FEB-22	2.680	ug/L
51473	51473-1-102-S01	Room 102 Sink	Initial	10-FEB-22	2.680	ug/L
51473	51473-1-102-S01	Room 102 Sink	Initial	22-SEP-21	1.710	ug/L
51473	51473-1-102-S01	Room 102 Sink	Initial	22-SEP-21	1.710	ug/L