



**Sep 10, 2024**

**NEW FIELD**

**1707 W MORSE AVE, Chicago IL 60626.**

Dear **NEW FIELD** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**NEW FIELD**

**1707 W MORSE AVE, Chicago IL 60626.**

Estimadas familias de **NEW FIELD**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51080	51080-3-N-RES-S01	3rd floor restroom	Flush180	31-JUL-20	1.000	ug/L
51080	51080-3-N-RES-S01	3rd floor restroom	Initial	31-JUL-20	2.230	ug/L
51080	51080-1-HAL-F34	Main- 1st Floor Outside Bathroom, Center Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F34	Main- 1st Floor Outside Bathroom, Center Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F34	Main- 1st Floor Outside Bathroom, Center Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F34	Main- 1st Floor Outside Bathroom, Center Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F34	Main- 1st Floor Outside Bathroom, Center Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F35	Main- 1st Floor Outside Bathroom, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F35	Main- 1st Floor Outside Bathroom, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F35	Main- 1st Floor Outside Bathroom, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F35	Main- 1st Floor Outside Bathroom, Left Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F33	Main- 1st Floor Outside Bathroom, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F33	Main- 1st Floor Outside Bathroom, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F33	Main- 1st Floor Outside Bathroom, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-HAL-F33	Main- 1st Floor Outside Bathroom, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F01	Main- 2nd Floor Outside Bathroom, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F01	Main- 2nd Floor Outside Bathroom, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F01	Main- 2nd Floor Outside Bathroom, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F01	Main- 2nd Floor Outside Bathroom, Left Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F02	Main- 2nd Floor Outside Bathroom, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F02	Main- 2nd Floor Outside Bathroom, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F02	Main- 2nd Floor Outside Bathroom, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F02	Main- 2nd Floor Outside Bathroom, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-101-S31	Main- Inside Room 101, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-S31	Main- Inside Room 101, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-S31	Main- Inside Room 101, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-S31	Main- Inside Room 101, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-S31	Main- Inside Room 101, Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-101-F30	Main- Inside Room 101, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-F30	Main- Inside Room 101, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-F30	Main- Inside Room 101, Left Fountain	Flush180	27-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51080	51080-1-101-F30	Main- Inside Room 101, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-F30	Main- Inside Room 101, Left Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-101-S32	Main- Inside Room 101, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-S32	Main- Inside Room 101, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-S32	Main- Inside Room 101, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-S32	Main- Inside Room 101, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-101-S32	Main- Inside Room 101, Right Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-102-S29	Main- Inside Room 102, Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-102-S29	Main- Inside Room 102, Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-102-S29	Main- Inside Room 102, Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-102-S29	Main- Inside Room 102, Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-102-S29	Main- Inside Room 102, Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-103-S27	Main- Inside Room 103, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-S27	Main- Inside Room 103, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-S27	Main- Inside Room 103, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-S27	Main- Inside Room 103, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-S27	Main- Inside Room 103, Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-103-S28	Main- Inside Room 103, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-S28	Main- Inside Room 103, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-S28	Main- Inside Room 103, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-S28	Main- Inside Room 103, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-S28	Main- Inside Room 103, Left Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-103-F26	Main- Inside Room 103, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-F26	Main- Inside Room 103, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-F26	Main- Inside Room 103, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-F26	Main- Inside Room 103, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-103-F26	Main- Inside Room 103, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-105-S24	Main- Inside Room 105, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-S24	Main- Inside Room 105, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-S24	Main- Inside Room 105, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-S24	Main- Inside Room 105, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-S24	Main- Inside Room 105, Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-105-F23	Main- Inside Room 105, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-F23	Main- Inside Room 105, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-F23	Main- Inside Room 105, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-F23	Main- Inside Room 105, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-F23	Main- Inside Room 105, Left Fountain	Initial	27-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51080	51080-1-105-S25	Main- Inside Room 105, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-S25	Main- Inside Room 105, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-S25	Main- Inside Room 105, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-S25	Main- Inside Room 105, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-105-S25	Main- Inside Room 105, Right Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-108-S21	Main- Inside Room 108, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-S21	Main- Inside Room 108, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-S21	Main- Inside Room 108, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-S21	Main- Inside Room 108, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-S21	Main- Inside Room 108, Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-108-F22	Main- Inside Room 108, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-F22	Main- Inside Room 108, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-F22	Main- Inside Room 108, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-F22	Main- Inside Room 108, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-F22	Main- Inside Room 108, Left Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-108-S20	Main- Inside Room 108, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-S20	Main- Inside Room 108, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-S20	Main- Inside Room 108, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-S20	Main- Inside Room 108, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-108-S20	Main- Inside Room 108, Right Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-109-S18	Main- Inside Room 109, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-S18	Main- Inside Room 109, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-S18	Main- Inside Room 109, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-S18	Main- Inside Room 109, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-S18	Main- Inside Room 109, Center Sink	Initial	27-SEP-16	2.500	ppb
51080	51080-1-109-S19	Main- Inside Room 109, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-S19	Main- Inside Room 109, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-S19	Main- Inside Room 109, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-S19	Main- Inside Room 109, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-S19	Main- Inside Room 109, Left Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-109-F17	Main- Inside Room 109, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-F17	Main- Inside Room 109, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-F17	Main- Inside Room 109, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-F17	Main- Inside Room 109, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-109-F17	Main- Inside Room 109, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-110-S12	Main- Inside Room 110, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-S12	Main- Inside Room 110, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-	Main- Inside Room 110, Center	Flush180	27-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S12	Sink				
51080	51080-1-110-S12	Main- Inside Room 110, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-S12	Main- Inside Room 110, Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-110-S11	Main- Inside Room 110, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-S11	Main- Inside Room 110, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-S11	Main- Inside Room 110, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-S11	Main- Inside Room 110, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-S11	Main- Inside Room 110, Left Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-110-F13	Main- Inside Room 110, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-F13	Main- Inside Room 110, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-F13	Main- Inside Room 110, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-F13	Main- Inside Room 110, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-110-F13	Main- Inside Room 110, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-111-S15	Main- Inside Room 111, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-S15	Main- Inside Room 111, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-S15	Main- Inside Room 111, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-S15	Main- Inside Room 111, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-S15	Main- Inside Room 111, Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-111-F14	Main- Inside Room 111, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-F14	Main- Inside Room 111, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-F14	Main- Inside Room 111, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-F14	Main- Inside Room 111, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-F14	Main- Inside Room 111, Left Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-111-S16	Main- Inside Room 111, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-S16	Main- Inside Room 111, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-S16	Main- Inside Room 111, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-S16	Main- Inside Room 111, Right Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-111-S16	Main- Inside Room 111, Right Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-112-S09	Main- Inside Room 112, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-S09	Main- Inside Room 112, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-S09	Main- Inside Room 112, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-S09	Main- Inside Room 112, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-S09	Main- Inside Room 112, Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-112-S08	Main- Inside Room 112, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-S08	Main- Inside Room 112, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-S08	Main- Inside Room 112, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-S08	Main- Inside Room 112, Left Sink	Initial	27-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S08					
51080	51080-1-112-F10	Main- Inside Room 112, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-F10	Main- Inside Room 112, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-F10	Main- Inside Room 112, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-F10	Main- Inside Room 112, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-112-F10	Main- Inside Room 112, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-113-S06	Main- Inside Room 113, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-S06	Main- Inside Room 113, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-S06	Main- Inside Room 113, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-S06	Main- Inside Room 113, Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-S06	Main- Inside Room 113, Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-113-S07	Main- Inside Room 113, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-S07	Main- Inside Room 113, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-S07	Main- Inside Room 113, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-S07	Main- Inside Room 113, Left Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-S07	Main- Inside Room 113, Left Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-113-F05	Main- Inside Room 113, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-F05	Main- Inside Room 113, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-F05	Main- Inside Room 113, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-F05	Main- Inside Room 113, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-113-F05	Main- Inside Room 113, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS03	Main- Kitchen, East Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS03	Main- Kitchen, East Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS03	Main- Kitchen, East Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS03	Main- Kitchen, East Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS03	Main- Kitchen, East Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS02	Main- Kitchen, South Wall, Left Sink Faucet	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS02	Main- Kitchen, South Wall, Left Sink Faucet	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS02	Main- Kitchen, South Wall, Left Sink Faucet	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS02	Main- Kitchen, South Wall, Left Sink Faucet	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS02	Main- Kitchen, South Wall, Left Sink Faucet	Initial	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS01	Main- Kitchen, South Wall, Right Sink Faucet	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS01	Main- Kitchen, South Wall, Right Sink Faucet	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS01	Main- Kitchen, South Wall, Right Sink Faucet	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS01	Main- Kitchen, South Wall, Right Sink Faucet	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS01	Main- Kitchen, South Wall, Right Sink Faucet	Initial	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS04	Main- Kitchen, West Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS04	Main- Kitchen, West Center Sink	Flush180	27-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51080	51080-1-KIT-KS04	Main- Kitchen, West Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS04	Main- Kitchen, West Center Sink	Flush180	27-SEP-16	1.000	ppb
51080	51080-1-KIT-KS04	Main- Kitchen, West Center Sink	Initial	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F03	Main- Outside Room 212, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F03	Main- Outside Room 212, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F03	Main- Outside Room 212, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F03	Main- Outside Room 212, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F03	Main- Outside Room 212, Left Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F04	Main- Outside Room 212, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F04	Main- Outside Room 212, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F04	Main- Outside Room 212, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F04	Main- Outside Room 212, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-2-HAL-F04	Main- Outside Room 212, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F02	Main- Outside Room 312, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F02	Main- Outside Room 312, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F02	Main- Outside Room 312, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F02	Main- Outside Room 312, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F02	Main- Outside Room 312, Left Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F01	Main- Outside Room 312, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F01	Main- Outside Room 312, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F01	Main- Outside Room 312, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F01	Main- Outside Room 312, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51080	51080-3-HAL-F01	Main- Outside Room 312, Right Fountain	Initial	27-SEP-16	1.000	ppb
51080	51080-1-E-KIT-S01	kitchen	Flush180	31-JUL-20	1.000	ug/L
51080	51080-1-E-KIT-S01	kitchen	Initial	31-JUL-20	1.000	ug/L