



Sep 10, 2024

NEWBERRY

700 W WILLOW ST, Chicago IL 60614.

Dear **NEWBERRY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

NEWBERRY

700 W WILLOW ST, Chicago IL 60614.

Estimadas familias de **NEWBERRY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	07-FEB-23	1.000	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	07-FEB-23	2.160	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	07-FEB-23	2.330	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	07-FEB-23	1.000	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	13-JAN-23	4.430	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	13-JAN-23	3.110	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	13-JAN-23	5.150	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	13-JAN-23	5.180	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	17-JUN-16	0.809	ppb
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	17-JUN-16	1.590	ppb
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	17-JUN-16	1.690	ppb
51170	51170-1-114-S05	Inside Room 114, Sink	Flush180	17-JUN-16	0.646	ppb
51170	51170-1-114-S05	Inside Room 114, Sink	Initial	07-FEB-23	3.190	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Initial	13-JAN-23	1.750	ug/L
51170	51170-1-114-S05	Inside Room 114, Sink	Initial	17-JUN-16	0.627	ppb
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Flush180	13-JAN-23	1.430	ug/L
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Flush180	13-JAN-23	1.420	ug/L
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Flush180	13-JAN-23	1.100	ug/L
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Flush180	17-JUN-16	0.977	ppb
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Flush180	17-JUN-16	2.190	ppb
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Flush180	17-JUN-16	1.150	ppb
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Flush180	17-JUN-16	2.430	ppb
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Initial	13-JAN-23	1.240	ug/L
51170	51170-1-116-S01	Inside Room 116 (North), Sink 1, in Classroom	Initial	17-JUN-16	0.845	ppb
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Flush180	13-JAN-23	1.940	ug/L
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Flush180	17-JUN-16	0.542	ppb
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Flush180	17-JUN-16	0.457	ppb
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Flush180	17-JUN-16	0.695	ppb
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Flush180	17-JUN-16	0.989	ppb
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Initial	13-JAN-23	3.890	ug/L
51170	51170-1-116-S02	Inside Room 116 (South), Sink 2 Closet Area	Initial	17-JUN-16	0.349	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Flush180	17-JUN-16	21.500	ppb
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Flush180	17-JUN-16	11.100	ppb
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Flush180	17-JUN-16	13.900	ppb
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Flush180	17-JUN-16	29.200	ppb
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Flush180	11-AUG-16	1.000	ppb
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Flush180	11-AUG-16	1.000	ppb
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Flush180	11-AUG-16	1.000	ppb
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Initial	11-AUG-16	3.300	ppb
51170	51170-1-KIT-KS10	Kitchen (East Wall), Cooking Sink 3	Initial	17-JUN-16	6.380	ppb
51170	51170-1-KIT-KS08	Kitchen (North Wall), Sink 1	Flush180	17-JUN-16	0.535	ppb
51170	51170-1-KIT-KS08	Kitchen (North Wall), Sink 1	Flush180	17-JUN-16	0.450	ppb
51170	51170-1-KIT-KS08	Kitchen (North Wall), Sink 1	Flush180	17-JUN-16	0.395	ppb
51170	51170-1-KIT-KS08	Kitchen (North Wall), Sink 1	Flush180	17-JUN-16	0.394	ppb
51170	51170-1-KIT-KS08	Kitchen (North Wall), Sink 1	Initial	17-JUN-16	0.687	ppb
51170	51170-1-KIT-KS09	Kitchen (West Wall), Sink 2	Flush180	17-JUN-16	1.060	ppb
51170	51170-1-KIT-KS09	Kitchen (West Wall), Sink 2	Flush180	17-JUN-16	1.780	ppb
51170	51170-1-KIT-KS09	Kitchen (West Wall), Sink 2	Flush180	17-JUN-16	4.870	ppb
51170	51170-1-KIT-KS09	Kitchen (West Wall), Sink 2	Flush180	17-JUN-16	3.620	ppb
51170	51170-1-KIT-KS09	Kitchen (West Wall), Sink 2	Initial	17-JUN-16	12.900	ppb
51170	51170-1-HAL-WC07	Outside Auditorium (East), Fountain 1	Flush180	17-JUN-16	1.000	ppb
51170	51170-1-HAL-WC07	Outside Auditorium (East), Fountain 1	Flush180	17-JUN-16	1.000	ppb
51170	51170-1-HAL-WC07	Outside Auditorium (East), Fountain 1	Flush180	17-JUN-16	1.000	ppb
51170	51170-1-HAL-WC07	Outside Auditorium (East), Fountain 1	Flush180	17-JUN-16	0.134	ppb
51170	51170-1-HAL-WC07	Outside Auditorium (East), Fountain 1	Initial	17-JUN-16	0.147	ppb
51170	51170-1-HAL-WC06	Outside Auditorium (West), Fountain 2	Flush180	17-JUN-16	0.265	ppb
51170	51170-1-HAL-WC06	Outside Auditorium (West), Fountain 2	Flush180	17-JUN-16	0.202	ppb
51170	51170-1-HAL-WC06	Outside Auditorium (West), Fountain 2	Flush180	17-JUN-16	0.297	ppb
51170	51170-1-HAL-WC06	Outside Auditorium (West), Fountain 2	Flush180	17-JUN-16	0.247	ppb
51170	51170-1-HAL-WC06	Outside Auditorium (West), Fountain 2	Initial	17-JUN-16	0.317	ppb
51170	51170-1-HAL-WC13	Outside Room 105 (East), Fountain 1	Flush180	17-JUN-16	0.497	ppb
51170	51170-1-HAL-WC13	Outside Room 105 (East), Fountain 1	Flush180	17-JUN-16	0.579	ppb
51170	51170-1-HAL-WC13	Outside Room 105 (East), Fountain 1	Flush180	17-JUN-16	0.427	ppb
51170	51170-1-HAL-WC13	Outside Room 105 (East), Fountain 1	Flush180	17-JUN-16	0.382	ppb
51170	51170-1-HAL-WC13	Outside Room 105 (East), Fountain 1	Initial	17-JUN-16	0.603	ppb
51170	51170-1-HAL-RBF02	Outside Room 105, Retrofit BF	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-RBF02	Outside Room 105, Retrofit BF	Flush180	13-JAN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51170	51170-1-HAL-RBF02	Outside Room 105, Retrofit BF	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-RBF02	Outside Room 105, Retrofit BF	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-RBF02	Outside Room 105, Retrofit BF	Initial	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Flush180	17-JUN-16	0.397	ppb
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Flush180	17-JUN-16	0.383	ppb
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Flush180	17-JUN-16	0.397	ppb
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Flush180	17-JUN-16	0.416	ppb
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Initial	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC14	Outside Room 105, Right Fountain	Initial	17-JUN-16	0.385	ppb
51170	51170-1-HAL-WC11	Outside Room 109 (East), Fountain 1	Flush180	17-JUN-16	0.360	ppb
51170	51170-1-HAL-WC11	Outside Room 109 (East), Fountain 1	Flush180	17-JUN-16	0.535	ppb
51170	51170-1-HAL-WC11	Outside Room 109 (East), Fountain 1	Flush180	17-JUN-16	0.245	ppb
51170	51170-1-HAL-WC11	Outside Room 109 (East), Fountain 1	Flush180	17-JUN-16	0.448	ppb
51170	51170-1-HAL-WC11	Outside Room 109 (East), Fountain 1	Flush180	30-JUL-20	1.000	ug/L
51170	51170-1-HAL-WC11	Outside Room 109 (East), Fountain 1	Initial	17-JUN-16	0.565	ppb
51170	51170-1-HAL-WC11	Outside Room 109 (East), Fountain 1	Initial	30-JUL-20	1.000	ug/L
51170	51170-1-HAL-RBF01	Outside Room 109, Retrofit BF	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-RBF01	Outside Room 109, Retrofit BF	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-RBF01	Outside Room 109, Retrofit BF	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-RBF01	Outside Room 109, Retrofit BF	Initial	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Flush180	17-JUN-16	0.390	ppb
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Flush180	17-JUN-16	0.300	ppb
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Flush180	17-JUN-16	0.299	ppb
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Flush180	17-JUN-16	0.303	ppb
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Initial	13-JAN-23	1.000	ug/L
51170	51170-1-HAL-WC12	Outside Room 109, Right Fountain	Initial	17-JUN-16	0.406	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	13-JAN-23	2.920	ug/L
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	13-JAN-23	2.450	ug/L
51170	51170-1-HAL-	Outside Room 114 Right Fountain	Flush180	13-JAN-23	2.170	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC03	1				
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	13-JAN-23	2.230	ug/L
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	17-JUN-16	3.240	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	11-AUG-16	14.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	13-OCT-16	1.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	13-OCT-16	7.500	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	13-OCT-16	1.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	16-SEP-16	1.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	16-SEP-16	6.400	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	16-SEP-16	40.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	16-SEP-16	1.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	13-OCT-16	3.300	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	17-JUN-16	47.900	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	17-JUN-16	3.890	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	17-JUN-16	2.530	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	11-AUG-16	9.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	11-AUG-16	8.500	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Flush180	11-AUG-16	9.900	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Initial	13-JAN-23	2.840	ug/L
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Initial	17-JUN-16	2.110	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Initial	13-OCT-16	14.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Initial	16-SEP-16	1.000	ppb
51170	51170-1-HAL-WC03	Outside Room 114 Right Fountain 1	Initial	11-AUG-16	41.000	ppb
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Flush180	13-JAN-23	1.690	ug/L
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Flush180	13-JAN-23	2.560	ug/L
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Flush180	13-JAN-23	2.580	ug/L
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Flush180	13-JAN-23	3.100	ug/L
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Flush180	17-JUN-16	4.030	ppb
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Flush180	17-JUN-16	3.430	ppb
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Flush180	17-JUN-16	4.170	ppb
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Flush180	17-JUN-16	2.860	ppb
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Initial	13-JAN-23	2.190	ug/L
51170	51170-1-HAL-WC04	Outside Room 114, Left Fountain	Initial	17-JUN-16	2.560	ppb
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Flush180	17-JUN-16	0.753	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC04					
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Flush180	17-JUN-16	0.597	ppb
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Flush180	17-JUN-16	0.786	ppb
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Flush180	17-JUN-16	0.804	ppb
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Flush180	30-JUL-20	1.000	ug/L
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Initial	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Initial	17-JUN-16	0.545	ppb
51170	51170-2-HAL-WC04	Outside Room 203, Left Fountain	Initial	30-JUL-20	1.000	ug/L
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Flush180	17-JUN-16	0.477	ppb
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Flush180	17-JUN-16	0.495	ppb
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Flush180	17-JUN-16	0.434	ppb
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Flush180	17-JUN-16	0.448	ppb
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Initial	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC05	Outside Room 203, Right Fountain	Initial	17-JUN-16	0.482	ppb
51170	51170-2-HAL-BF01	Outside Room 211, Left Bottle Filler	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-BF01	Outside Room 211, Left Bottle Filler	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-BF01	Outside Room 211, Left Bottle Filler	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-BF01	Outside Room 211, Left Bottle Filler	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-BF01	Outside Room 211, Left Bottle Filler	Initial	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Flush180	17-JUN-16	0.273	ppb
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Flush180	17-JUN-16	0.219	ppb
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Flush180	17-JUN-16	0.298	ppb
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Flush180	17-JUN-16	0.194	ppb
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Initial	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC02	Outside Room 211, Left Fountain	Initial	17-JUN-16	0.146	ppb
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Flush180	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Flush180	17-JUN-16	0.327	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Flush180	17-JUN-16	0.325	ppb
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Flush180	17-JUN-16	0.322	ppb
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Flush180	17-JUN-16	0.319	ppb
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Initial	13-JAN-23	1.000	ug/L
51170	51170-2-HAL-WC03	Outside Room 211, Right Fountain	Initial	17-JUN-16	0.306	ppb
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Flush180	13-JAN-23	2.620	ug/L
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Flush180	13-JAN-23	2.320	ug/L
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Flush180	13-JAN-23	2.550	ug/L
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Flush180	13-JAN-23	3.140	ug/L
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Flush180	17-JUN-16	2.560	ppb
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Flush180	17-JUN-16	2.490	ppb
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Flush180	17-JUN-16	2.610	ppb
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Flush180	17-JUN-16	2.390	ppb
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Initial	13-JAN-23	2.310	ug/L
51170	51170-2-HAL-F01	Outside Room 216, Left Fountain	Initial	17-JUN-16	6.180	ppb
51170	51170-2-HAL-F02	Outside Room 216, Right Fountain	Flush180	13-JAN-23	3.740	ug/L
51170	51170-2-HAL-F02	Outside Room 216, Right Fountain	Flush180	13-JAN-23	3.450	ug/L
51170	51170-2-HAL-F02	Outside Room 216, Right Fountain	Flush180	13-JAN-23	3.190	ug/L
51170	51170-2-HAL-F02	Outside Room 216, Right Fountain	Flush180	13-JAN-23	3.060	ug/L
51170	51170-2-HAL-F02	Outside Room 216, Right Fountain	Initial	13-JAN-23	4.490	ug/L