



Sep 10, 2024

NICHOLSON

6006 S PEORIA ST, Chicago IL 60621.

Dear **NICHOLSON** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

NICHOLSON

6006 S PEORIA ST, Chicago IL 60621.

Estimadas familias de **NICHOLSON**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51374	51374-1-HAL-RBF01	Main Building - 1st Floor By Main Office, Bottle Filler	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-RBF01	Main Building - 1st Floor By Main Office, Bottle Filler	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-RBF01	Main Building - 1st Floor By Main Office, Bottle Filler	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-RBF01	Main Building - 1st Floor By Main Office, Bottle Filler	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-RBF01	Main Building - 1st Floor By Main Office, Bottle Filler	Initial	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC10	Main Building - 1st Floor By Room 117, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC10	Main Building - 1st Floor By Room 117, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC10	Main Building - 1st Floor By Room 117, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC10	Main Building - 1st Floor By Room 117, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC10	Main Building - 1st Floor By Room 117, Fountain	Initial	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Flush180	14-SEP-16	1.000	ppb
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Flush180	14-SEP-16	0.947	ppb
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Flush180	14-SEP-16	1.050	ppb
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Flush180	14-SEP-16	1.030	ppb
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Flush180	04-NOV-21	1.370	ug/L
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Flush180	04-NOV-21	1.230	ug/L
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Flush180	04-NOV-21	1.430	ug/L
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Flush180	04-NOV-21	1.450	ug/L
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Initial	14-SEP-16	0.733	ppb
51374	51374-1-HAL-WC09	Main Building- 1st Floor Across From Room 102, Fou	Initial	04-NOV-21	1.260	ug/L
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Flush180	14-SEP-16	0.412	ppb
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Flush180	14-SEP-16	0.454	ppb
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Flush180	14-SEP-16	0.465	ppb
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Flush180	14-SEP-16	0.361	ppb
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Initial	14-SEP-16	0.287	ppb
51374	51374-1-HAL-WC05	Main Building- 1st Floor By Gym Left, Fountain	Initial	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	14-SEP-16	0.322	ppb
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	14-SEP-16	0.411	ppb
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	14-SEP-16	0.442	ppb
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	14-SEP-16	0.407	ppb
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	05-AUG-20	7.660	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	27-OCT-20	2.260	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	27-OCT-20	2.020	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	27-OCT-20	1.850	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	27-OCT-20	1.760	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Initial	14-SEP-16	0.247	ppb
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Initial	05-AUG-20	8.020	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Initial	27-OCT-20	2.470	ug/L
51374	51374-1-HAL-WC06	Main Building- 1st Floor By Gym Right, Fountain	Initial	04-NOV-21	1.000	ug/L
51374	51374-1-HAL-WC08	Main Building- 1st Floor By Main Office, Fountain	Flush180	14-SEP-16	0.352	ppb
51374	51374-1-HAL-WC08	Main Building- 1st Floor By Main Office, Fountain	Flush180	14-SEP-16	0.351	ppb
51374	51374-1-HAL-WC08	Main Building- 1st Floor By Main Office, Fountain	Flush180	14-SEP-16	0.327	ppb
51374	51374-1-HAL-WC08	Main Building- 1st Floor By Main Office, Fountain	Flush180	14-SEP-16	0.340	ppb
51374	51374-1-HAL-WC08	Main Building- 1st Floor By Main Office, Fountain	Flush180	05-AUG-20	1.000	ug/L
51374	51374-1-HAL-WC08	Main Building- 1st Floor By Main Office, Fountain	Initial	14-SEP-16	0.225	ppb
51374	51374-1-HAL-WC08	Main Building- 1st Floor By Main Office, Fountain	Initial	05-AUG-20	1.020	ug/L
51374	51374-1-HAL-WC07	Main Building- 1st Floor By Room 107, Fountain	Flush180	14-SEP-16	0.632	ppb
51374	51374-1-HAL-WC07	Main Building- 1st Floor By Room 107, Fountain	Flush180	14-SEP-16	0.573	ppb
51374	51374-1-HAL-WC07	Main Building- 1st Floor By Room 107, Fountain	Flush180	14-SEP-16	0.468	ppb
51374	51374-1-HAL-WC07	Main Building- 1st Floor By Room 107, Fountain	Flush180	14-SEP-16	0.679	ppb
51374	51374-1-HAL-WC07	Main Building- 1st Floor By Room 107, Fountain	Initial	14-SEP-16	0.373	ppb
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Flush180	14-SEP-16	0.756	ppb
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Flush180	14-SEP-16	1.190	ppb
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Flush180	14-SEP-16	0.689	ppb
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Flush180	14-SEP-16	1.020	ppb
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Initial	14-SEP-16	0.329	ppb
51374	51374-1-100-S13	Main Building- 1st Floor Inside Room 100, Sink	Initial	04-NOV-21	1.000	ug/L
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Flush180	14-SEP-16	1.120	ppb
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Flush180	14-SEP-16	1.180	ppb
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Flush180	14-SEP-16	1.650	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Flush180	14-SEP-16	0.863	ppb
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Flush180	04-NOV-21	1.000	ug/L
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Initial	14-SEP-16	0.937	ppb
51374	51374-1-101-S12	Main Building- 1st Floor Inside Room 101, Sink	Initial	04-NOV-21	1.000	ug/L
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Flush180	14-SEP-16	5.510	ppb
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Flush180	14-SEP-16	2.550	ppb
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Flush180	14-SEP-16	5.070	ppb
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Flush180	14-SEP-16	2.490	ppb
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Flush180	04-NOV-21	7.730	ug/L
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Flush180	04-NOV-21	10.700	ug/L
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Flush180	04-NOV-21	11.600	ug/L
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Flush180	04-NOV-21	16.500	ug/L
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Initial	14-SEP-16	4.670	ppb
51374	51374-1-102-S10	Main Building- 1st Floor Inside Room 102 Left, Sin	Initial	04-NOV-21	7.010	ug/L
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	21-OCT-16	2.000	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	21-OCT-16	2.300	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	21-OCT-16	2.000	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	21-OCT-16	2.000	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	14-SEP-16	5.430	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	14-SEP-16	16.800	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	14-SEP-16	4.440	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	14-SEP-16	6.440	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	21-OCT-16	1.000	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	21-OCT-16	1.000	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	21-OCT-16	2.000	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	21-OCT-16	2.300	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	04-NOV-21	33.800	ug/L
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	04-NOV-21	2.190	ug/L
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	04-NOV-21	3.820	ug/L
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Flush180	04-NOV-21	1.310	ug/L
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Initial	21-OCT-16	4.000	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Initial	14-SEP-16	68.600	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Initial	21-OCT-16	4.000	ppb
51374	51374-1-102-S11	Main Building- 1st Floor Inside Room 102 Right, Si	Initial	04-NOV-21	7.600	ug/L
51374	51374-2-HAL-	Main Building- 2nd Floor By Room	Flush180	14-SEP-16	1.350	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC02	202, Fountain				
51374	51374-2-HAL-WC02	Main Building- 2nd Floor By Room 202, Fountain	Flush180	14-SEP-16	1.200	ppb
51374	51374-2-HAL-WC02	Main Building- 2nd Floor By Room 202, Fountain	Flush180	14-SEP-16	1.330	ppb
51374	51374-2-HAL-WC02	Main Building- 2nd Floor By Room 202, Fountain	Flush180	14-SEP-16	1.310	ppb
51374	51374-2-HAL-WC02	Main Building- 2nd Floor By Room 202, Fountain	Initial	14-SEP-16	1.090	ppb
51374	51374-2-HAL-WC01	Main Building- 2nd Floor By Room 205B, Fountain	Flush180	14-SEP-16	0.645	ppb
51374	51374-2-HAL-WC01	Main Building- 2nd Floor By Room 205B, Fountain	Flush180	14-SEP-16	0.995	ppb
51374	51374-2-HAL-WC01	Main Building- 2nd Floor By Room 205B, Fountain	Flush180	14-SEP-16	0.807	ppb
51374	51374-2-HAL-WC01	Main Building- 2nd Floor By Room 205B, Fountain	Flush180	14-SEP-16	1.000	ppb
51374	51374-2-HAL-WC01	Main Building- 2nd Floor By Room 205B, Fountain	Initial	14-SEP-16	0.408	ppb
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Flush180	14-SEP-16	0.531	ppb
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Flush180	14-SEP-16	0.644	ppb
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Flush180	14-SEP-16	0.645	ppb
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Flush180	14-SEP-16	0.631	ppb
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Flush180	04-NOV-21	1.000	ug/L
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Initial	14-SEP-16	0.336	ppb
51374	51374-2-HAL-WC03	Main Building- 2nd Floor By Room 217, Fountain	Initial	04-NOV-21	1.000	ug/L
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Flush180	14-SEP-16	1.140	ppb
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Flush180	14-SEP-16	1.100	ppb
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Flush180	14-SEP-16	1.140	ppb
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Flush180	14-SEP-16	1.030	ppb
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Flush180	04-NOV-21	3.900	ug/L
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Flush180	04-NOV-21	4.060	ug/L
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Flush180	04-NOV-21	3.900	ug/L
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Flush180	04-NOV-21	3.990	ug/L
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Initial	14-SEP-16	0.835	ppb
51374	51374-2-HAL-WC04	Main Building- 2nd Floor By Room 227, Fountain	Initial	04-NOV-21	3.930	ug/L
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Flush180	14-SEP-16	0.496	ppb
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Flush180	14-SEP-16	0.481	ppb
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Flush180	14-SEP-16	0.459	ppb
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Flush180	14-SEP-16	0.512	ppb
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Flush180	05-NOV-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02	Sink				
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Initial	14-SEP-16	0.345	ppb
51374	51374-1-KIT-KS02	Main Building- Kitchen Center Slop Sink	Initial	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Flush180	14-SEP-16	0.627	ppb
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Flush180	14-SEP-16	0.543	ppb
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Flush180	14-SEP-16	1.180	ppb
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Flush180	14-SEP-16	1.220	ppb
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Initial	14-SEP-16	0.554	ppb
51374	51374-1-KIT-KS01	Main Building- Kitchen Left Slop Sink	Initial	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Flush180	14-SEP-16	0.464	ppb
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Flush180	14-SEP-16	0.471	ppb
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Flush180	14-SEP-16	0.464	ppb
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Flush180	14-SEP-16	0.582	ppb
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Initial	14-SEP-16	0.937	ppb
51374	51374-1-KIT-KS03	Main Building- Kitchen Right Slop Sink	Initial	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Flush180	14-SEP-16	0.480	ppb
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Flush180	14-SEP-16	0.464	ppb
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Flush180	14-SEP-16	0.478	ppb
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Flush180	14-SEP-16	0.575	ppb
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Flush180	05-NOV-21	1.000	ug/L
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Initial	14-SEP-16	0.620	ppb
51374	51374-1-KIT-KS04	Main Building- Kitchen Wash Sink	Initial	05-NOV-21	1.000	ug/L