



Sep 10, 2024

NORTH LAWDALE - CHRISTIANA HS

1615 S Christiana Ave, Chicago IL 60623.

Dear **NORTH LAWDALE - CHRISTIANA HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

NORTH LAWNSDALE - CHRISTIANA HS

1615 S Christiana Ave, Chicago IL 60623.

Estimadas familias de **NORTH LAWNSDALE - CHRISTIANA HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51206	51206-B-GYM-F01	Gym Left Fountain East Wall	Flush180	19-OCT-16	0.250	ppb
51206	51206-B-GYM-F01	Gym Left Fountain East Wall	Flush180	19-OCT-16	0.240	ppb
51206	51206-B-GYM-F01	Gym Left Fountain East Wall	Flush180	19-OCT-16	0.270	ppb
51206	51206-B-GYM-F01	Gym Left Fountain East Wall	Flush180	19-OCT-16	0.270	ppb
51206	51206-B-GYM-F01	Gym Left Fountain East Wall	Initial	19-OCT-16	0.240	ppb
51206	51206-B-KIT-KS01	Kitchen Left Sink West Wall	Flush180	19-OCT-16	0.740	ppb
51206	51206-B-KIT-KS01	Kitchen Left Sink West Wall	Flush180	19-OCT-16	0.790	ppb
51206	51206-B-KIT-KS01	Kitchen Left Sink West Wall	Flush180	19-OCT-16	0.760	ppb
51206	51206-B-KIT-KS01	Kitchen Left Sink West Wall	Flush180	19-OCT-16	0.770	ppb
51206	51206-B-KIT-KS01	Kitchen Left Sink West Wall	Initial	19-OCT-16	0.520	ppb
51206	51206-B-KIT-KS02	Kitchen Right Sink West Wall	Flush180	19-OCT-16	0.170	ppb
51206	51206-B-KIT-KS02	Kitchen Right Sink West Wall	Flush180	19-OCT-16	1.000	ppb
51206	51206-B-KIT-KS02	Kitchen Right Sink West Wall	Flush180	19-OCT-16	1.000	ppb
51206	51206-B-KIT-KS02	Kitchen Right Sink West Wall	Flush180	19-OCT-16	1.000	ppb
51206	51206-B-KIT-KS02	Kitchen Right Sink West Wall	Initial	19-OCT-16	0.210	ppb
51206	51206-B-KIT-KS03	Kitchen Warming Pantry	Flush180	19-OCT-16	11.000	ppb
51206	51206-B-KIT-KS03	Kitchen Warming Pantry	Flush180	19-OCT-16	8.000	ppb
51206	51206-B-KIT-KS03	Kitchen Warming Pantry	Flush180	19-OCT-16	8.700	ppb
51206	51206-B-KIT-KS03	Kitchen Warming Pantry	Flush180	19-OCT-16	5.200	ppb
51206	51206-B-KIT-KS03	Kitchen Warming Pantry	Initial	19-OCT-16	16.000	ppb
51206	51206-B-MOF-S01	Main Office	Flush180	19-OCT-16	0.700	ppb
51206	51206-B-MOF-S01	Main Office	Flush180	19-OCT-16	1.000	ppb
51206	51206-B-MOF-S01	Main Office	Flush180	19-OCT-16	1.400	ppb
51206	51206-B-MOF-S01	Main Office	Flush180	19-OCT-16	0.510	ppb
51206	51206-B-MOF-S01	Main Office	Initial	19-OCT-16	3.500	ppb
51206	51206-3-HAL-RBF01	North End Hall Right Bottle Filler Across 308	Flush	24-JAN-2024	2.100	ug/L
51206	51206-3-HAL-RBF01	North End Hall Right Bottle Filler Across 308	Flush	24-JAN-2024	1.650	ug/L
51206	51206-3-HAL-RBF01	North End Hall Right Bottle Filler Across 308	Flush	24-JAN-2024	1.280	ug/L
51206	51206-3-HAL-RBF01	North End Hall Right Bottle Filler Across 308	Flush	24-JAN-2024	1.100	ug/L
51206	51206-3-HAL-RBF01	North End Hall Right Bottle Filler Across 308	Initial	24-JAN-2024	1.710	ug/L
51206	51206-3-HAL-F01	North End hall Left Fountain	Flush180	19-OCT-16	0.610	ppb
51206	51206-3-HAL-F01	North End hall Left Fountain	Flush180	19-OCT-16	0.620	ppb
51206	51206-3-HAL-F01	North End hall Left Fountain	Flush180	19-OCT-16	1.200	ppb
51206	51206-3-HAL-F01	North End hall Left Fountain	Flush180	19-OCT-16	1.600	ppb
51206	51206-3-HAL-F01	North End hall Left Fountain	Initial	19-OCT-16	1.400	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51206	51206-3-HAL-F01	North End hall Left Fountain Across 308	Flush	24-JAN-2024	2.260	ug/L
51206	51206-3-HAL-F01	North End hall Left Fountain Across 308	Flush	24-JAN-2024	2.060	ug/L
51206	51206-3-HAL-F01	North End hall Left Fountain Across 308	Flush	24-JAN-2024	1.560	ug/L
51206	51206-3-HAL-F01	North End hall Left Fountain Across 308	Flush	24-JAN-2024	1.130	ug/L
51206	51206-3-HAL-F01	North End hall Left Fountain Across 308	Initial	24-JAN-2024	2.860	ug/L
51206	51206-2-HAL-RBF01	North End of Hall Left Bottle Filler	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-RBF01	North End of Hall Left Bottle Filler	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-RBF01	North End of Hall Left Bottle Filler	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-RBF01	North End of Hall Left Bottle Filler	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-RBF01	North End of Hall Left Bottle Filler	Initial	24-JAN-2024	1.100	ug/L
51206	51206-2-HAL-F04	North End of Hall Left Fountain	Flush180	19-OCT-16	1.000	ppb
51206	51206-2-HAL-F04	North End of Hall Left Fountain	Flush180	19-OCT-16	1.000	ppb
51206	51206-2-HAL-F04	North End of Hall Left Fountain	Flush180	19-OCT-16	1.000	ppb
51206	51206-2-HAL-F04	North End of Hall Left Fountain	Flush180	19-OCT-16	1.000	ppb
51206	51206-2-HAL-F04	North End of Hall Left Fountain	Initial	19-OCT-16	0.510	ppb
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Flush	24-JAN-2024	1.370	ug/L
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Flush180	19-OCT-16	0.570	ppb
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Flush180	19-OCT-16	0.660	ppb
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Flush180	19-OCT-16	0.610	ppb
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Flush180	19-OCT-16	0.650	ppb
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Initial	19-OCT-16	1.300	ppb
51206	51206-2-HAL-F05	North End of Hall Right Fountain	Initial	24-JAN-2024	2.420	ug/L
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Flush180	19-OCT-16	0.380	ppb
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Flush180	19-OCT-16	0.320	ppb
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Flush180	19-OCT-16	0.320	ppb
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Flush180	19-OCT-16	0.350	ppb
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Initial	19-OCT-16	0.410	ppb
51206	51206-1-HAL-F01	Outside RM 107A Left Fountain	Initial	24-JAN-2024	1.280	ug/L
51206	51206-1-HAL-RBF01	Outside RM 107A Right Bottle Filler	Flush	24-JAN-2024	1.720	ug/L
51206	51206-1-HAL-RBF01	Outside RM 107A Right Bottle Filler	Flush	24-JAN-2024	2.390	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51206	51206-1-HAL-RBF01	Outside RM 107A Right Bottle Filler	Flush	24-JAN-2024	2.130	ug/L
51206	51206-1-HAL-RBF01	Outside RM 107A Right Bottle Filler	Flush	24-JAN-2024	1.600	ug/L
51206	51206-1-HAL-RBF01	Outside RM 107A Right Bottle Filler	Initial	24-JAN-2024	1.000	ug/L
51206	51206-1-HAL-F02	Outside RM 107A Right Fountain	Flush180	19-OCT-16	0.990	ppb
51206	51206-1-HAL-F02	Outside RM 107A Right Fountain	Flush180	19-OCT-16	1.100	ppb
51206	51206-1-HAL-F02	Outside RM 107A Right Fountain	Flush180	19-OCT-16	1.400	ppb
51206	51206-1-HAL-F02	Outside RM 107A Right Fountain	Flush180	19-OCT-16	0.770	ppb
51206	51206-1-HAL-F02	Outside RM 107A Right Fountain	Initial	19-OCT-16	2.100	ppb
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush	13-FEB-2024	6.690	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush	13-FEB-2024	5.070	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush	13-FEB-2024	3.520	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush	13-FEB-2024	4.570	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush	30-MAY-2024	1.000	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush	30-MAY-2024	1.000	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush	30-MAY-2024	1.000	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush	30-MAY-2024	1.000	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush180	19-OCT-16	24.000	ppb
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush180	19-OCT-16	88.000	ppb
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush180	19-OCT-16	62.000	ppb
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Flush180	19-OCT-16	40.000	ppb
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Initial	19-OCT-16	9.600	ppb
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Initial	13-FEB-2024	5.040	ug/L
51206	51206-1-HAL-F03	Outside RM 113 Left Fountain	Initial	30-MAY-2024	1.000	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Flush	24-JAN-2024	19.700	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Flush	13-FEB-2024	1.730	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Flush	13-FEB-2024	1.520	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Flush	13-FEB-2024	1.740	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Flush	13-FEB-2024	3.180	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Flush	24-JAN-2024	12.300	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Flush	24-JAN-2024	9.900	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Flush	24-JAN-2024	8.600	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Initial	24-JAN-2024	23.100	ug/L
51206	51206-1-HAL-F04	Outside RM 113 Right Fountain	Initial	13-FEB-2024	4.060	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush	13-FEB-2024	1.620	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush	13-FEB-2024	1.570	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush	13-FEB-2024	1.000	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush	13-FEB-2024	1.000	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush	24-JAN-2024	1.170	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05					
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush	24-JAN-2024	13.400	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush	24-JAN-2024	1.000	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush180	19-OCT-16	8.000	ppb
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush180	19-OCT-16	14.000	ppb
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush180	19-OCT-16	9.900	ppb
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Flush180	19-OCT-16	25.000	ppb
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Initial	19-OCT-16	19.000	ppb
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Initial	13-FEB-2024	1.000	ug/L
51206	51206-1-HAL-F05	Outside RM 119 Left Fountain	Initial	24-JAN-2024	2.080	ug/L
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Flush	24-JAN-2024	4.680	ug/L
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Flush	24-JAN-2024	3.020	ug/L
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Flush	24-JAN-2024	3.050	ug/L
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Flush	24-JAN-2024	2.390	ug/L
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Flush180	19-OCT-16	5.000	ppb
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Flush180	19-OCT-16	6.000	ppb
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Flush180	19-OCT-16	5.400	ppb
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Flush180	19-OCT-16	11.000	ppb
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Initial	19-OCT-16	12.000	ppb
51206	51206-1-HAL-F06	Outside RM 119 Right Fountain	Initial	24-JAN-2024	3.680	ug/L
51206	51206-1-119-S01	RM 119 Sink	Flush180	19-OCT-16	6.700	ppb
51206	51206-1-119-S01	RM 119 Sink	Flush180	19-OCT-16	24.000	ppb
51206	51206-1-119-S01	RM 119 Sink	Flush180	19-OCT-16	7.100	ppb
51206	51206-1-119-S01	RM 119 Sink	Flush180	19-OCT-16	4.300	ppb
51206	51206-1-119-S01	RM 119 Sink	Initial	19-OCT-16	5.800	ppb
51206	51206-B-MOF-S01	Sink in Main Office	Flush	24-JAN-2024	1.000	ug/L
51206	51206-B-MOF-S01	Sink in Main Office	Flush	24-JAN-2024	1.000	ug/L
51206	51206-B-MOF-S01	Sink in Main Office	Flush	24-JAN-2024	1.000	ug/L
51206	51206-B-MOF-S01	Sink in Main Office	Flush	24-JAN-2024	1.000	ug/L
51206	51206-B-MOF-S01	Sink in Main Office	Initial	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-F01	South End of HALL	Flush180	19-OCT-16	2.800	ppb
51206	51206-2-HAL-F01	South End of HALL	Flush180	19-OCT-16	2.200	ppb
51206	51206-2-HAL-F01	South End of HALL	Flush180	19-OCT-16	1.400	ppb
51206	51206-2-HAL-F01	South End of HALL	Flush180	19-OCT-16	2.800	ppb
51206	51206-2-HAL-F01	South End of HALL	Initial	19-OCT-16	1.600	ppb
51206	51206-2-HAL-F01	South End of HALL Across 218	Flush	13-FEB-2024	1.000	ug/L
51206	51206-2-HAL-F01	South End of HALL Across 218	Flush	13-FEB-2024	1.120	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51206	51206-2-HAL-F01	South End of HALL Across 218	Flush	13-FEB-2024	1.000	ug/L
51206	51206-2-HAL-F01	South End of HALL Across 218	Flush	13-FEB-2024	1.000	ug/L
51206	51206-2-HAL-F01	South End of HALL Across 218	Flush	24-JAN-2024	2.380	ug/L
51206	51206-2-HAL-F01	South End of HALL Across 218	Flush	24-JAN-2024	1.300	ug/L
51206	51206-2-HAL-F01	South End of HALL Across 218	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-F01	South End of HALL Across 218	Flush	24-JAN-2024	1.000	ug/L
51206	51206-2-HAL-F01	South End of HALL Across 218	Initial	13-FEB-2024	1.230	ug/L
51206	51206-2-HAL-F01	South End of HALL Across 218	Initial	24-JAN-2024	7.920	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain	Flush180	19-OCT-16	3.100	ppb
51206	51206-3-HAL-F04	South End of Hall Left Fountain	Flush180	19-OCT-16	4.300	ppb
51206	51206-3-HAL-F04	South End of Hall Left Fountain	Flush180	19-OCT-16	5.000	ppb
51206	51206-3-HAL-F04	South End of Hall Left Fountain	Flush180	19-OCT-16	2.500	ppb
51206	51206-3-HAL-F04	South End of Hall Left Fountain	Initial	19-OCT-16	6.200	ppb
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Flush	13-FEB-2024	1.660	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Flush	13-FEB-2024	1.300	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Flush	13-FEB-2024	1.130	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Flush	13-FEB-2024	1.040	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Flush	24-JAN-2024	3.230	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Flush	24-JAN-2024	4.860	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Flush	24-JAN-2024	6.520	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Flush	24-JAN-2024	6.670	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Initial	13-FEB-2024	1.750	ug/L
51206	51206-3-HAL-F04	South End of Hall Left Fountain Across 318	Initial	24-JAN-2024	3.980	ug/L
51206	51206-3-HAL-F05	South End of Hall Right Fountain	Flush180	19-OCT-16	6.500	ppb
51206	51206-3-HAL-F05	South End of Hall Right Fountain	Flush180	19-OCT-16	7.000	ppb
51206	51206-3-HAL-F05	South End of Hall Right Fountain	Flush180	19-OCT-16	6.700	ppb
51206	51206-3-HAL-F05	South End of Hall Right Fountain	Flush180	19-OCT-16	9.500	ppb
51206	51206-3-HAL-F05	South End of Hall Right Fountain	Initial	19-OCT-16	21.000	ppb
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Flush	13-FEB-2024	1.000	ug/L
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Flush	13-FEB-2024	1.000	ug/L
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Flush	13-FEB-2024	1.000	ug/L
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Flush	24-JAN-2024	5.760	ug/L
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Flush	24-JAN-2024	4.620	ug/L
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Flush	24-JAN-2024	4.370	ug/L
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Flush	24-JAN-2024	3.420	ug/L
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Initial	13-FEB-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51206	51206-3-HAL-F05	South End of Hall Right Fountain Across 318	Initial	24-JAN-2024	10.100	ug/L
51206	51206-3-HAL-F03	Southeast Hall	Flush180	19-OCT-16	3.700	ppb
51206	51206-3-HAL-F03	Southeast Hall	Flush180	19-OCT-16	13.000	ppb
51206	51206-3-HAL-F03	Southeast Hall	Flush180	19-OCT-16	15.000	ppb
51206	51206-3-HAL-F03	Southeast Hall	Flush180	19-OCT-16	4.100	ppb
51206	51206-3-HAL-F03	Southeast Hall	Initial	19-OCT-16	17.000	ppb
51206	51206-B-HAL-F01	Southeast Hall Left Fountain	Flush180	19-OCT-16	6.400	ppb
51206	51206-B-HAL-F01	Southeast Hall Left Fountain	Flush180	19-OCT-16	7.000	ppb
51206	51206-B-HAL-F01	Southeast Hall Left Fountain	Flush180	19-OCT-16	6.400	ppb
51206	51206-B-HAL-F01	Southeast Hall Left Fountain	Flush180	19-OCT-16	6.300	ppb
51206	51206-B-HAL-F01	Southeast Hall Left Fountain	Initial	19-OCT-16	9.300	ppb
51206	51206-3-HAL-F03	Southeast Hall Next to 314	Flush	24-JAN-2024	2.690	ug/L
51206	51206-3-HAL-F03	Southeast Hall Next to 314	Flush	24-JAN-2024	2.520	ug/L
51206	51206-3-HAL-F03	Southeast Hall Next to 314	Flush	24-JAN-2024	2.540	ug/L
51206	51206-3-HAL-F03	Southeast Hall Next to 314	Flush	24-JAN-2024	2.290	ug/L
51206	51206-3-HAL-F03	Southeast Hall Next to 314	Initial	24-JAN-2024	3.010	ug/L
51206	51206-B-HAL-F02	Southeast Hall Right Fountain	Flush180	19-OCT-16	8.200	ppb
51206	51206-B-HAL-F02	Southeast Hall Right Fountain	Flush180	19-OCT-16	5.400	ppb
51206	51206-B-HAL-F02	Southeast Hall Right Fountain	Flush180	19-OCT-16	5.700	ppb
51206	51206-B-HAL-F02	Southeast Hall Right Fountain	Flush180	19-OCT-16	3.400	ppb
51206	51206-2-HAL-F03	Southeast Hall Right Fountain	Flush180	19-OCT-16	3.300	ppb
51206	51206-2-HAL-F03	Southeast Hall Right Fountain	Flush180	19-OCT-16	2.000	ppb
51206	51206-2-HAL-F03	Southeast Hall Right Fountain	Flush180	19-OCT-16	1.500	ppb
51206	51206-2-HAL-F03	Southeast Hall Right Fountain	Flush180	19-OCT-16	1.400	ppb
51206	51206-2-HAL-F03	Southeast Hall Right Fountain	Initial	19-OCT-16	3.200	ppb
51206	51206-B-HAL-F02	Southeast Hall Right Fountain	Initial	19-OCT-16	16.000	ppb
51206	51206-2-HAL-F03	Southeast Hall Right Fountain Next to 214	Flush	24-JAN-2024	3.190	ug/L
51206	51206-2-HAL-F03	Southeast Hall Right Fountain Next to 214	Flush	24-JAN-2024	3.020	ug/L
51206	51206-2-HAL-F03	Southeast Hall Right Fountain Next to 214	Flush	24-JAN-2024	2.430	ug/L
51206	51206-2-HAL-F03	Southeast Hall Right Fountain Next to 214	Flush	24-JAN-2024	1.830	ug/L
51206	51206-2-HAL-F03	Southeast Hall Right Fountain Next to 214	Initial	24-JAN-2024	3.850	ug/L