



**Sep 10, 2024**

**NORTHSIDE LEARNING HS**

**3730 W BRYN MAWR AVE, Chicago IL 60659.**

Dear **NORTHSIDE LEARNING HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**NORTHSIDE LEARNING HS**

**3730 W BRYN MAWR AVE, Chicago IL 60659.**

Estimadas familias de **NORTHSIDE LEARNING HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51542	51542-1-CAF-KS01	Café in Hallway Left Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS01	Café in Hallway Left Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS01	Café in Hallway Left Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS01	Café in Hallway Left Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS01	Café in Hallway Left Sink	Initial	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS02	Café in Hallway Right Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS02	Café in Hallway Right Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS02	Café in Hallway Right Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS02	Café in Hallway Right Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CAF-KS02	Café in Hallway Right Sink	Initial	03-MAY-22	1.000	ug/L
51542	51542-1-CUL-KS04	Culinary Arts Room 3 basin Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CUL-KS04	Culinary Arts Room 3 basin Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CUL-KS04	Culinary Arts Room 3 basin Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CUL-KS04	Culinary Arts Room 3 basin Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-CUL-KS04	Culinary Arts Room 3 basin Sink	Initial	03-MAY-22	1.000	ug/L
51542	51542-1-CUL-KS01	Culinary Arts Room Middle prep table sink	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS01	Culinary Arts Room Middle prep table sink	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS01	Culinary Arts Room Middle prep table sink	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS01	Culinary Arts Room Middle prep table sink	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS01	Culinary Arts Room Middle prep table sink	Initial	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS02	Culinary Arts Room Sink next to Stove	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS02	Culinary Arts Room Sink next to Stove	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS02	Culinary Arts Room Sink next to Stove	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS02	Culinary Arts Room Sink next to Stove	Initial	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS03	Culinary Arts Room- Sink next to dishwasher	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS03	Culinary Arts Room- Sink next to dishwasher	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS03	Culinary Arts Room- Sink next to dishwasher	Flush180	28-APR-22	1.000	ug/L
51542	51542-1-CUL-KS03	Culinary Arts Room- Sink next to dishwasher	Initial	28-APR-22	1.750	ug/L
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-	Main- Across From Room 110,	Flush180	18-OCT-16	2.900	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09	Left Fountain				
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Flush180	03-MAY-22	2.150	ug/L
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Initial	18-OCT-16	8.900	ppb
51542	51542-1-HAL-F09	Main- Across From Room 110, Left Fountain	Initial	03-MAY-22	3.680	ug/L
51542	51542-1-HAL-F10	Main- Across From Room 110, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F10	Main- Across From Room 110, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F10	Main- Across From Room 110, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F10	Main- Across From Room 110, Right Fountain	Initial	18-OCT-16	3.900	ppb
51542	51542-1-HAL-RBF01	Main- Across From Room 110, Right Retrofit Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-RBF01	Main- Across From Room 110, Right Retrofit Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-RBF01	Main- Across From Room 110, Right Retrofit Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-RBF01	Main- Across From Room 110, Right Retrofit Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-RBF01	Main- Across From Room 110, Right Retrofit Bottle Filler	Initial	03-MAY-22	1.870	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	10-JUN-22	1.000	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	10-JUN-22	2.530	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	10-JUN-22	1.000	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	10-JUN-22	1.000	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	03-MAY-22	1.420	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Initial	18-OCT-16	2.700	ppb
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Initial	10-JUN-22	4.350	ug/L
51542	51542-1-HAL-F07	Main- Across From Room 117, Left Fountain	Initial	03-MAY-22	5.020	ug/L
51542	51542-1-HAL-BF01	Main- Across From Room 117, Right Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-BF01	Main- Across From Room 117, Right Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-BF01	Main- Across From Room 117, Right Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-BF01	Main- Across From Room 117, Right Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-	Main- Across From Room 117,	Initial	03-MAY-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01	Right Bottle Filler				
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	16-DEC-20	2.150	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	12-FEB-21	1.000	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	12-FEB-21	1.080	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	12-FEB-21	1.000	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	12-FEB-21	1.000	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Initial	18-OCT-16	1.000	ppb
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Initial	16-DEC-20	42.900	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Initial	12-FEB-21	1.000	ug/L
51542	51542-1-HAL-F08	Main- Across From Room 117, Right Fountain	Initial	03-MAY-22	1.000	ug/L
51542	51542-1-125-F11	Main- Inside Multi-Purpose Room 125, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-125-F11	Main- Inside Multi-Purpose Room 125, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-125-F11	Main- Inside Multi-Purpose Room 125, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-125-F11	Main- Inside Multi-Purpose Room 125, Left Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-125-F11	Main- Inside Multi-Purpose Room 125, Left Fountain	Initial	18-OCT-16	2.600	ppb
51542	51542-1-125-BF01	Main- Inside Multi-Purpose Room 125, Right Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-125-BF01	Main- Inside Multi-Purpose Room 125, Right Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-125-BF01	Main- Inside Multi-Purpose Room 125, Right Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-125-BF01	Main- Inside Multi-Purpose Room 125, Right Bottle Filler	Initial	03-MAY-22	1.000	ug/L
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Initial	18-OCT-16	1.000	ppb
51542	51542-1-125-F12	Main- Inside Multi-Purpose Room 125, Right Fountain	Initial	03-MAY-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Flush180	18-OCT-16	3.500	ppb
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Flush180	18-OCT-16	2.300	ppb
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Flush180	03-MAY-22	1.230	ug/L
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Flush180	03-MAY-22	1.810	ug/L
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Initial	18-OCT-16	4.100	ppb
51542	51542-1-100-S14	Main- Inside Room 100, Sink	Initial	03-MAY-22	3.510	ug/L
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Initial	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS06	Main- Kitchen Dish Washing Room West Wall, Left Si	Initial	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS0551542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Flush180	03-MAY-22	1.010	ug/L
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Initial	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS05	Main- Kitchen Dish Washing Room West Wall, Right S	Initial	03-MAY-22	1.260	ug/L
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Flush180	10-JUN-22	3.080	ug/L
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Flush180	10-JUN-22	2.060	ug/L
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Flush180	10-JUN-22	3.540	ug/L
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Flush180	10-JUN-22	2.560	ug/L
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Flush180	03-MAY-22	79.000	ug/L
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Flush180	03-MAY-22	6.140	ug/L
51542	51542-1-KIT-	Main- Kitchen Dish Washing	Flush180	03-MAY-22	6.690	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS07	Sink/Sprayer				
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Flush180	03-MAY-22	6.780	ug/L
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Initial	10-JUN-22	4.390	ug/L
51542	51542-1-KIT-KS07	Main- Kitchen Dish Washing Sink/Sprayer	Initial	03-MAY-22	6.760	ug/L
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Initial	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS04	Main- Kitchen East Wall, Sink	Initial	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	18-OCT-16	8.300	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	18-OCT-16	13.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	18-OCT-16	4.700	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	18-OCT-16	22.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Flush180	03-MAY-22	1.000	ug/L
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Initial	18-OCT-16	17.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Initial	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Initial	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS01	Main- Kitchen Salad Room, North Wall, Sink (left)	Initial	03-MAY-22	1.920	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	18-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	29-JUL-22	3.730	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	29-JUL-22	10.100	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	29-JUL-22	4.820	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	29-JUL-22	1.000	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	10-JUN-22	3.760	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	10-JUN-22	9.690	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	10-JUN-22	5.180	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	10-JUN-22	1.850	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	31-AUG-22	1.000	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	31-AUG-22	1.080	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	31-AUG-22	1.000	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	31-AUG-22	3.620	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	03-MAY-22	8.270	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	03-MAY-22	17.200	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	03-MAY-22	5.160	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Flush180	03-MAY-22	2.210	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Initial	18-OCT-16	1.000	ppb
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Initial	29-JUL-22	7.510	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Initial	10-JUN-22	7.250	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Initial	31-AUG-22	1.000	ug/L
51542	51542-1-KIT-KS03	Main- Kitchen Salad Room, South Wall, Sink (right)	Initial	03-MAY-22	9.720	ug/L
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	08-DEC-16	3.000	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	08-DEC-16	2.400	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	08-DEC-16	2.300	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	08-DEC-16	2.400	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	18-OCT-16	8.700	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	18-OCT-16	11.000	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	18-OCT-16	22.000	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	18-OCT-16	11.000	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	08-DEC-16	3.000	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	08-DEC-16	2.300	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	08-DEC-16	1.000	ppb
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	29-JUL-22	8.870	ug/L
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	29-JUL-22	22.300	ug/L
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	29-JUL-22	20.800	ug/L
51542	51542-1-KIT-KS02	Main- Kitchen Salad Room, West Wall, Sink (middle)	Flush180	29-JUL-22	7.530	ug/L







Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Left Fountain				
52459	52459-1-HAL-F01	Mobile- Across From Restrooms, Left Fountain	Initial	18-OCT-16	1.000	ppb
52459	52459-1-HAL-F01	Mobile- Across From Restrooms, Left Fountain	Initial	16-DEC-20	8.550	ug/L
52459	52459-1-HAL-F01	Mobile- Across From Restrooms, Left Fountain	Initial	12-FEB-21	1.000	ug/L
52459	52459-1-HAL-RBF01	Mobile- Across From Restrooms, Left Retrofit Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-RBF01	Mobile- Across From Restrooms, Left Retrofit Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-RBF01	Mobile- Across From Restrooms, Left Retrofit Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-RBF01	Mobile- Across From Restrooms, Left Retrofit Bottle Filler	Flush180	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-RBF01	Mobile- Across From Restrooms, Left Retrofit Bottle Filler	Initial	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Flush180	18-OCT-16	1.000	ppb
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Flush180	18-OCT-16	1.000	ppb
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Flush180	18-OCT-16	1.000	ppb
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Flush180	18-OCT-16	1.000	ppb
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Flush180	03-MAY-22	1.000	ug/L
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Initial	18-OCT-16	6.600	ppb
52459	52459-1-HAL-F02	Mobile- Across From Restrooms, Right Fountain	Initial	03-MAY-22	1.000	ug/L