



Sep 10, 2024

OGDEN ES

24 W WALTON ST, Chicago IL 60610.

Dear **OGDEN ES** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

OGDEN ES

24 W WALTON ST, Chicago IL 60610.

Estimadas familias de **OGDEN ES**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51134	51134-1-KIT-KS01	Kitchen Left Sink North Wall	Flush180	07-OCT-16	0.310	ppb
51134	51134-1-KIT-KS01	Kitchen Left Sink North Wall	Flush180	07-OCT-16	0.420	ppb
51134	51134-1-KIT-KS01	Kitchen Left Sink North Wall	Flush180	07-OCT-16	0.320	ppb
51134	51134-1-KIT-KS01	Kitchen Left Sink North Wall	Flush180	07-OCT-16	0.400	ppb
51134	51134-1-KIT-KS01	Kitchen Left Sink North Wall	Initial	07-OCT-16	0.630	ppb
51134	51134-1-KIT-KS02	Kitchen Middle Sink North Wall	Flush180	07-OCT-16	0.270	ppb
51134	51134-1-KIT-KS02	Kitchen Middle Sink North Wall	Flush180	07-OCT-16	1.000	ppb
51134	51134-1-KIT-KS02	Kitchen Middle Sink North Wall	Flush180	07-OCT-16	0.170	ppb
51134	51134-1-KIT-KS02	Kitchen Middle Sink North Wall	Flush180	07-OCT-16	0.190	ppb
51134	51134-1-KIT-KS02	Kitchen Middle Sink North Wall	Initial	07-OCT-16	0.370	ppb
51134	51134-1-KIT-KS03	Kitchen Right Sink North Wall	Flush180	07-OCT-16	3.300	ppb
51134	51134-1-KIT-KS03	Kitchen Right Sink North Wall	Flush180	07-OCT-16	0.910	ppb
51134	51134-1-KIT-KS03	Kitchen Right Sink North Wall	Flush180	07-OCT-16	0.500	ppb
51134	51134-1-KIT-KS03	Kitchen Right Sink North Wall	Flush180	07-OCT-16	1.400	ppb
51134	51134-1-KIT-KS03	Kitchen Right Sink North Wall	Initial	07-OCT-16	0.780	ppb
51134	51134-1-HAL-F03	Near Main Entrance Left Fountain	Flush180	07-OCT-16	0.510	ppb
51134	51134-1-HAL-F03	Near Main Entrance Left Fountain	Flush180	07-OCT-16	0.580	ppb
51134	51134-1-HAL-F03	Near Main Entrance Left Fountain	Flush180	07-OCT-16	0.560	ppb
51134	51134-1-HAL-F03	Near Main Entrance Left Fountain	Flush180	07-OCT-16	0.380	ppb
51134	51134-1-HAL-F03	Near Main Entrance Left Fountain	Initial	07-OCT-16	0.590	ppb
51134	51134-1-HAL-F04	Near Main Entrance Right Fountain	Flush180	07-OCT-16	0.250	ppb
51134	51134-1-HAL-F04	Near Main Entrance Right Fountain	Flush180	07-OCT-16	0.160	ppb
51134	51134-1-HAL-F04	Near Main Entrance Right Fountain	Flush180	07-OCT-16	0.140	ppb
51134	51134-1-HAL-F04	Near Main Entrance Right Fountain	Flush180	07-OCT-16	0.140	ppb
51134	51134-1-HAL-F04	Near Main Entrance Right Fountain	Initial	07-OCT-16	0.480	ppb
51134	51134-2-HAL-F03	Outside 2007B Left Fountain	Flush180	07-OCT-16	0.300	ppb
51134	51134-2-HAL-F03	Outside 2007B Left Fountain	Flush180	07-OCT-16	0.310	ppb
51134	51134-2-HAL-F03	Outside 2007B Left Fountain	Flush180	07-OCT-16	0.400	ppb
51134	51134-2-HAL-F03	Outside 2007B Left Fountain	Flush180	07-OCT-16	0.330	ppb
51134	51134-2-HAL-F03	Outside 2007B Left Fountain	Initial	07-OCT-16	0.440	ppb
51134	51134-2-HAL-F04	Outside 2007B Right Fountain	Flush180	07-OCT-16	0.330	ppb
51134	51134-2-HAL-F04	Outside 2007B Right Fountain	Flush180	07-OCT-16	0.370	ppb
51134	51134-2-HAL-F04	Outside 2007B Right Fountain	Flush180	07-OCT-16	0.300	ppb
51134	51134-2-HAL-F04	Outside 2007B Right Fountain	Flush180	07-OCT-16	0.340	ppb
51134	51134-2-HAL-F04	Outside 2007B Right Fountain	Initial	07-OCT-16	0.270	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51134	51134-2-HAL-F05	Outside 2010 Left Fountain	Flush180	07-OCT-16	0.160	ppb
51134	51134-2-HAL-F05	Outside 2010 Left Fountain	Flush180	07-OCT-16	0.120	ppb
51134	51134-2-HAL-F05	Outside 2010 Left Fountain	Flush180	07-OCT-16	0.088	ppb
51134	51134-2-HAL-F05	Outside 2010 Left Fountain	Flush180	07-OCT-16	0.120	ppb
51134	51134-2-HAL-F05	Outside 2010 Left Fountain	Initial	07-OCT-16	0.140	ppb
51134	51134-2-HAL-F06	Outside 2010 Right Fountain	Flush180	07-OCT-16	0.081	ppb
51134	51134-2-HAL-F06	Outside 2010 Right Fountain	Flush180	07-OCT-16	0.071	ppb
51134	51134-2-HAL-F06	Outside 2010 Right Fountain	Flush180	07-OCT-16	0.170	ppb
51134	51134-2-HAL-F06	Outside 2010 Right Fountain	Flush180	07-OCT-16	0.120	ppb
51134	51134-2-HAL-F06	Outside 2010 Right Fountain	Initial	07-OCT-16	0.190	ppb
51134	51134-2-HAL-F01	Outside 2027 Left FO Outside 2027 Left Fountain	Flush180	07-OCT-16	0.094	ppb
51134	51134-2-HAL-F01	Outside 2027 Left FO Outside 2027 Left Fountain	Flush180	07-OCT-16	0.250	ppb
51134	51134-2-HAL-F01	Outside 2027 Left FO Outside 2027 Left Fountain	Flush180	07-OCT-16	0.080	ppb
51134	51134-2-HAL-F01	Outside 2027 Left FO Outside 2027 Left Fountain	Flush180	07-OCT-16	0.067	ppb
51134	51134-2-HAL-F01	Outside 2027 Left FO Outside 2027 Left Fountain	Initial	07-OCT-16	0.210	ppb
51134	51134-2-HAL-F02	Outside 2027 Right Fountain	Flush180	07-OCT-16	1.000	ppb
51134	51134-2-HAL-F02	Outside 2027 Right Fountain	Flush180	07-OCT-16	0.350	ppb
51134	51134-2-HAL-F02	Outside 2027 Right Fountain	Flush180	07-OCT-16	0.620	ppb
51134	51134-2-HAL-F02	Outside 2027 Right Fountain	Flush180	07-OCT-16	0.720	ppb
51134	51134-2-HAL-F02	Outside 2027 Right Fountain	Initial	07-OCT-16	0.420	ppb
51134	51134-1-HAL-F07	Outside RM 1010 Left Fountain	Flush180	07-OCT-16	0.100	ppb
51134	51134-1-HAL-F07	Outside RM 1010 Left Fountain	Flush180	07-OCT-16	0.130	ppb
51134	51134-1-HAL-F07	Outside RM 1010 Left Fountain	Flush180	07-OCT-16	0.240	ppb
51134	51134-1-HAL-F07	Outside RM 1010 Left Fountain	Flush180	07-OCT-16	0.094	ppb
51134	51134-1-HAL-F07	Outside RM 1010 Left Fountain	Initial	07-OCT-16	0.110	ppb
51134	51134-1-HAL-F08	Outside RM 1010 Right Fountain	Flush180	07-OCT-16	0.082	ppb
51134	51134-1-HAL-F08	Outside RM 1010 Right Fountain	Flush180	07-OCT-16	0.180	ppb
51134	51134-1-HAL-F08	Outside RM 1010 Right Fountain	Flush180	07-OCT-16	0.070	ppb
51134	51134-1-HAL-F08	Outside RM 1010 Right Fountain	Flush180	07-OCT-16	0.180	ppb
51134	51134-1-HAL-F08	Outside RM 1010 Right Fountain	Initial	07-OCT-16	0.170	ppb
51134	51134-1-HAL-F01	Outside RM 1027B lunchroom staff	Flush180	07-OCT-16	0.630	ppb
51134	51134-1-HAL-F01	Outside RM 1027B lunchroom staff	Flush180	07-OCT-16	0.260	ppb
51134	51134-1-HAL-F01	Outside RM 1027B lunchroom staff	Flush180	07-OCT-16	0.130	ppb
51134	51134-1-HAL-F01	Outside RM 1027B lunchroom staff	Flush180	07-OCT-16	0.390	ppb
51134	51134-1-HAL-F02	Outside RM 1027B lunchroom staff	Flush180	07-OCT-16	0.089	ppb
51134	51134-1-HAL-F02	Outside RM 1027B lunchroom staff	Flush180	07-OCT-16	0.079	ppb
51134	51134-1-HAL-F02	Outside RM 1027B lunchroom staff	Flush180	07-OCT-16	0.068	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51134	51134-1-HAL-F02	Outside RM 1027B lunchroom staff	Flush180	07-OCT-16	1.000	ppb
51134	51134-1-HAL-F01	Outside RM 1027B lunchroom staff	Initial	07-OCT-16	0.350	ppb
51134	51134-1-HAL-F02	Outside RM 1027B lunchroom staff	Initial	07-OCT-16	0.180	ppb
51134	51134-1-HAL-F05	Outside Women's Restroom Left Fountain	Flush180	07-OCT-16	0.330	ppb
51134	51134-1-HAL-F05	Outside Women's Restroom Left Fountain	Flush180	07-OCT-16	0.350	ppb
51134	51134-1-HAL-F05	Outside Women's Restroom Left Fountain	Flush180	07-OCT-16	0.320	ppb
51134	51134-1-HAL-F05	Outside Women's Restroom Left Fountain	Flush180	07-OCT-16	0.430	ppb
51134	51134-1-HAL-F05	Outside Women's Restroom Left Fountain	Initial	07-OCT-16	0.330	ppb
51134	51134-1-HAL-F06	Outside Women's Restroom Right Fountain	Flush180	07-OCT-16	0.320	ppb
51134	51134-1-HAL-F06	Outside Women's Restroom Right Fountain	Flush180	07-OCT-16	0.430	ppb
51134	51134-1-HAL-F06	Outside Women's Restroom Right Fountain	Flush180	07-OCT-16	0.400	ppb
51134	51134-1-HAL-F06	Outside Women's Restroom Right Fountain	Flush180	07-OCT-16	0.440	ppb
51134	51134-1-HAL-F06	Outside Women's Restroom Right Fountain	Initial	07-OCT-16	0.430	ppb
51134	51134-1-1028-F02	RM 1028 Right Fount North Wall	Flush180	07-OCT-16	1.200	ppb
51134	51134-1-1028-F02	RM 1028 Right Fount North Wall	Flush180	07-OCT-16	1.700	ppb
51134	51134-1-1028-F02	RM 1028 Right Fount North Wall	Flush180	07-OCT-16	1.500	ppb
51134	51134-1-1028-F02	RM 1028 Right Fount North Wall	Flush180	07-OCT-16	0.810	ppb
51134	51134-1-1028-F02	RM 1028 Right Fount North Wall	Initial	07-OCT-16	0.580	ppb
51134	51134-1-1028-F01	RM 1028 left Fount. North Wall	Flush180	07-OCT-16	0.500	ppb
51134	51134-1-1028-F01	RM 1028 left Fount. North Wall	Flush180	07-OCT-16	1.600	ppb
51134	51134-1-1028-F01	RM 1028 left Fount. North Wall	Flush180	07-OCT-16	1.300	ppb
51134	51134-1-1028-F01	RM 1028 left Fount. North Wall	Flush180	07-OCT-16	1.200	ppb
51134	51134-1-1028-F01	RM 1028 left Fount. North Wall	Initial	07-OCT-16	0.450	ppb
51134	51134-2-2030-WC01	RM 2030 Teacher's Lounge	Flush180	07-OCT-16	1.000	ppb
51134	51134-2-2030-WC01	RM 2030 Teacher's Lounge	Flush180	07-OCT-16	1.000	ppb
51134	51134-2-2030-WC01	RM 2030 Teacher's Lounge	Flush180	07-OCT-16	0.094	ppb
51134	51134-2-2030-WC01	RM 2030 Teacher's Lounge	Flush180	07-OCT-16	1.000	ppb
51134	51134-2-2030-WC01	RM 2030 Teacher's Lounge	Initial	07-OCT-16	0.100	ppb
51163	51163-2-HAL-F02	Main- 2nd Floor Outside Gym, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F02	Main- 2nd Floor Outside Gym, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F02	Main- 2nd Floor Outside Gym, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F02	Main- 2nd Floor Outside Gym, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F02	Main- 2nd Floor Outside Gym, Right Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F04	Main- 2nd Floor Outside Room 201, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F04	Main- 2nd Floor Outside Room 201, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F04	Main- 2nd Floor Outside Room 201, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F04	Main- 2nd Floor Outside Room 201, Left Fountain	Flush180	27-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51163	51163-2-HAL-F04	Main- 2nd Floor Outside Room 201, Left Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F03	Main- 2nd Floor Outside Room 201, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F03	Main- 2nd Floor Outside Room 201, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F03	Main- 2nd Floor Outside Room 201, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F03	Main- 2nd Floor Outside Room 201, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-2-HAL-F03	Main- 2nd Floor Outside Room 201, Right Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F04	Main- 3rd Floor Outside Room 301, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F04	Main- 3rd Floor Outside Room 301, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F04	Main- 3rd Floor Outside Room 301, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F04	Main- 3rd Floor Outside Room 301, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F04	Main- 3rd Floor Outside Room 301, Left Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F03	Main- 3rd Floor Outside Room 301, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F03	Main- 3rd Floor Outside Room 301, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F03	Main- 3rd Floor Outside Room 301, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F03	Main- 3rd Floor Outside Room 301, Right Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F01	Main- 3rd Floor Outside Room 313, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F01	Main- 3rd Floor Outside Room 313, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F01	Main- 3rd Floor Outside Room 313, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F01	Main- 3rd Floor Outside Room 313, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F01	Main- 3rd Floor Outside Room 313, Left Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F02	Main- 3rd Floor Outside Room 313, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F02	Main- 3rd Floor Outside Room 313, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F02	Main- 3rd Floor Outside Room 313, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F02	Main- 3rd Floor Outside Room 313, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-3-HAL-F02	Main- 3rd Floor Outside Room 313, Right Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS01	Main- Kitchen, North Wall, Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS01	Main- Kitchen, North Wall, Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS01	Main- Kitchen, North Wall, Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS01	Main- Kitchen, North Wall, Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS01	Main- Kitchen, North Wall, Sink	Initial	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS03	Main- Kitchen, West Wall, Center Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS03	Main- Kitchen, West Wall, Center Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS03	Main- Kitchen, West Wall, Center Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS03	Main- Kitchen, West Wall, Center Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS03	Main- Kitchen, West Wall, Center Sink	Initial	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS02	Main- Kitchen, West Wall, North Sink	Flush180	27-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51163	51163-1-KIT-KS02	Main- Kitchen, West Wall, North Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS02	Main- Kitchen, West Wall, North Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS02	Main- Kitchen, West Wall, North Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS02	Main- Kitchen, West Wall, North Sink	Initial	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS04	Main- Kitchen, West Wall, South Sprayer Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS04	Main- Kitchen, West Wall, South Sprayer Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS04	Main- Kitchen, West Wall, South Sprayer Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS04	Main- Kitchen, West Wall, South Sprayer Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-KIT-KS04	Main- Kitchen, West Wall, South Sprayer Sink	Initial	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F05	Main- Outside Cafeteria, North Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F05	Main- Outside Cafeteria, North Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F05	Main- Outside Cafeteria, North Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F05	Main- Outside Cafeteria, North Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F05	Main- Outside Cafeteria, North Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F06	Main- Outside Cafeteria, South Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F06	Main- Outside Cafeteria, South Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F06	Main- Outside Cafeteria, South Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F06	Main- Outside Cafeteria, South Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F06	Main- Outside Cafeteria, South Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F12	Main- Outside Restrooms, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F12	Main- Outside Restrooms, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F12	Main- Outside Restrooms, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F12	Main- Outside Restrooms, Left Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F12	Main- Outside Restrooms, Left Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F11	Main- Outside Restrooms, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F11	Main- Outside Restrooms, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F11	Main- Outside Restrooms, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F11	Main- Outside Restrooms, Right Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-HAL-F11	Main- Outside Restrooms, Right Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-1-102-BF01	Main- Pre-K Room 102, Bottle Filler	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-BF01	Main- Pre-K Room 102, Bottle Filler	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-BF01	Main- Pre-K Room 102, Bottle Filler	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-BF01	Main- Pre-K Room 102, Bottle Filler	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-BF01	Main- Pre-K Room 102, Bottle Filler	Initial	30-SEP-22	1.000	ug/L
51163	51163-1-102-F08	Main- Pre-K Room 102, Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-F08	Main- Pre-K Room 102, Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-F08	Main- Pre-K Room 102, Fountain	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-F08	Main- Pre-K Room 102, Fountain	Flush180	27-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F08					
51163	51163-1-102-F08	Main- Pre-K Room 102, Fountain	Initial	27-SEP-16	1.000	ppb
51163	51163-1-102-F01	Main- Pre-K Room 102, Fountain	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-F01	Main- Pre-K Room 102, Fountain	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-F01	Main- Pre-K Room 102, Fountain	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-F01	Main- Pre-K Room 102, Fountain	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-F01	Main- Pre-K Room 102, Fountain	Initial	30-SEP-22	1.000	ug/L
51163	51163-1-102-S10	Main- Pre-K Room 102, Left Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-S10	Main- Pre-K Room 102, Left Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-S10	Main- Pre-K Room 102, Left Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-S10	Main- Pre-K Room 102, Left Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-S10	Main- Pre-K Room 102, Left Sink	Initial	27-SEP-16	1.000	ppb
51163	51163-1-102-S01	Main- Pre-K Room 102, Left Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-S01	Main- Pre-K Room 102, Left Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-S01	Main- Pre-K Room 102, Left Sink	Flush180	30-SEP-22	1.530	ug/L
51163	51163-1-102-S01	Main- Pre-K Room 102, Left Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-S01	Main- Pre-K Room 102, Left Sink	Initial	30-SEP-22	1.270	ug/L
51163	51163-1-102-S09	Main- Pre-K Room 102, Right Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-S09	Main- Pre-K Room 102, Right Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-S09	Main- Pre-K Room 102, Right Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-S09	Main- Pre-K Room 102, Right Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-102-S09	Main- Pre-K Room 102, Right Sink	Initial	27-SEP-16	1.000	ppb
51163	51163-1-102-S02	Main- Pre-K Room 102, Right Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-S02	Main- Pre-K Room 102, Right Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-S02	Main- Pre-K Room 102, Right Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-S02	Main- Pre-K Room 102, Right Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-102-S02	Main- Pre-K Room 102, Right Sink	Initial	30-SEP-22	1.000	ug/L
51163	51163-1-104-BF01	Main- Pre-K Room 104, Bottle Filler	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-BF01	Main- Pre-K Room 104, Bottle Filler	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-BF01	Main- Pre-K Room 104, Bottle Filler	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-BF01	Main- Pre-K Room 104, Bottle Filler	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-BF01	Main- Pre-K Room 104, Bottle Filler	Initial	30-SEP-22	1.000	ug/L
51163	51163-1-104-F01	Main- Pre-K Room 104, Fountain	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-F01	Main- Pre-K Room 104, Fountain	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-F01	Main- Pre-K Room 104, Fountain	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-F01	Main- Pre-K Room 104, Fountain	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-F01	Main- Pre-K Room 104, Fountain	Initial	30-SEP-22	1.000	ug/L
51163	51163-1-104-	Main- Pre-K Room 104, Left Sink	Flush180	30-SEP-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51163	51163-1-104-S01	Main- Pre-K Room 104, Left Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-S01	Main- Pre-K Room 104, Left Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-S01	Main- Pre-K Room 104, Left Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-S01	Main- Pre-K Room 104, Left Sink	Initial	30-SEP-22	1.000	ug/L
51163	51163-1-104-S02	Main- Pre-K Room 104, Right Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-S02	Main- Pre-K Room 104, Right Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-S02	Main- Pre-K Room 104, Right Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-S02	Main- Pre-K Room 104, Right Sink	Flush180	30-SEP-22	1.000	ug/L
51163	51163-1-104-S02	Main- Pre-K Room 104, Right Sink	Initial	30-SEP-22	1.000	ug/L
51163	51163-1-TL-S07	Main- Teachers Lounge Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-TL-S07	Main- Teachers Lounge Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-TL-S07	Main- Teachers Lounge Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-TL-S07	Main- Teachers Lounge Sink	Flush180	27-SEP-16	1.000	ppb
51163	51163-1-TL-S07	Main- Teachers Lounge Sink	Initial	27-SEP-16	1.000	ppb
51171	51171-1-HAL-WC01	Hall Outside Main Office 100 Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC01	Hall Outside Main Office 100 Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC01	Hall Outside Main Office 100 Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC01	Hall Outside Main Office 100 Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC01	Hall Outside Main Office 100 Left	Flush180	30-JUL-20	1.000	ug/L
51171	51171-1-HAL-WC01	Hall Outside Main Office 100 Left	Initial	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC01	Hall Outside Main Office 100 Left	Initial	30-JUL-20	1.000	ug/L
51171	51171-1-HAL-WC02	Hall Outside Main Office 100 Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC02	Hall Outside Main Office 100 Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC02	Hall Outside Main Office 100 Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC02	Hall Outside Main Office 100 Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC02	Hall Outside Main Office 100 Middle	Initial	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC03	Hall Outside Main Office 100 Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC03	Hall Outside Main Office 100 Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC03	Hall Outside Main Office 100 Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC03	Hall Outside Main Office 100 Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC03	Hall Outside Main Office 100 Right	Initial	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC08	Hall Outside RM 113 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC08	Hall Outside RM 113 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC08	Hall Outside RM 113 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC08	Hall Outside RM 113 Left Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC08	Hall Outside RM 113 Left Fountain	Initial	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC09	Hall Outside RM 113 Middle Fountain	Flush180	14-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51171	51171-1-HAL-WC09	Hall Outside RM 113 Middle Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC09	Hall Outside RM 113 Middle Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC09	Hall Outside RM 113 Middle Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC09	Hall Outside RM 113 Middle Fountain	Initial	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC10	Hall Outside RM 113 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC10	Hall Outside RM 113 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC10	Hall Outside RM 113 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC10	Hall Outside RM 113 Right Fountain	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-HAL-WC10	Hall Outside RM 113 Right Fountain	Initial	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC01	Hall Outside Restroom 201B Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC01	Hall Outside Restroom 201B Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC01	Hall Outside Restroom 201B Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC01	Hall Outside Restroom 201B Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC01	Hall Outside Restroom 201B Left	Initial	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC02	Hall Outside Restroom 201B Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC02	Hall Outside Restroom 201B Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC02	Hall Outside Restroom 201B Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC02	Hall Outside Restroom 201B Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC02	Hall Outside Restroom 201B Middle	Initial	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC03	Hall Outside Restroom 201B Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC03	Hall Outside Restroom 201B Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC03	Hall Outside Restroom 201B Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC03	Hall Outside Restroom 201B Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC03	Hall Outside Restroom 201B Right	Initial	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC04	Hall Outside Restroom 218D Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC04	Hall Outside Restroom 218D Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC04	Hall Outside Restroom 218D Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC04	Hall Outside Restroom 218D Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC04	Hall Outside Restroom 218D Left	Initial	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC05	Hall Outside Restroom 218D Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC05	Hall Outside Restroom 218D Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC05	Hall Outside Restroom 218D Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC05	Hall Outside Restroom 218D Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC05	Hall Outside Restroom 218D Middle	Initial	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC06	Hall Outside Restroom 218D Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC06	Hall Outside Restroom 218D Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC06	Hall Outside Restroom 218D Right	Flush180	14-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51171	51171-2-HAL-WC06	Hall Outside Restroom 218D Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-2-HAL-WC06	Hall Outside Restroom 218D Right	Initial	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC01	Hall Outside Restroom 301B Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC01	Hall Outside Restroom 301B Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC01	Hall Outside Restroom 301B Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC01	Hall Outside Restroom 301B Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC01	Hall Outside Restroom 301B Left	Initial	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC02	Hall Outside Restroom 301B Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC02	Hall Outside Restroom 301B Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC02	Hall Outside Restroom 301B Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC02	Hall Outside Restroom 301B Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC02	Hall Outside Restroom 301B Middle	Initial	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC03	Hall Outside Restroom 301B Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC03	Hall Outside Restroom 301B Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC03	Hall Outside Restroom 301B Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC03	Hall Outside Restroom 301B Right	Initial	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC04	Hall Outside Restroom 316D Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC04	Hall Outside Restroom 316D Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC04	Hall Outside Restroom 316D Left	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC04	Hall Outside Restroom 316D Left	Initial	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC05	Hall Outside Restroom 316D Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC05	Hall Outside Restroom 316D Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC05	Hall Outside Restroom 316D Middle	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC05	Hall Outside Restroom 316D Middle	Initial	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC06	Hall Outside Restroom 316D Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC06	Hall Outside Restroom 316D Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC06	Hall Outside Restroom 316D Right	Flush180	14-SEP-16	1.000	ppb
51171	51171-3-HAL-WC06	Hall Outside Restroom 316D Right	Initial	14-SEP-16	1.000	ppb
51171	51171-4-HAL-WC01	Hall on Roof Playground	Flush180	14-SEP-16	1.000	ppb
51171	51171-4-HAL-WC01	Hall on Roof Playground	Flush180	14-SEP-16	1.000	ppb
51171	51171-4-HAL-WC01	Hall on Roof Playground	Flush180	14-SEP-16	1.000	ppb
51171	51171-4-HAL-WC01	Hall on Roof Playground	Flush180	30-JUL-20	1.000	ug/L
51171	51171-4-HAL-	Hall on Roof Playground	Initial	14-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC01					
51171	51171-4-HAL-WC01	Hall on Roof Playground	Initial	30-JUL-20	1.000	ug/L
51171	51171-1-KIT-KS01	Kitchen Left Sink	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS01	Kitchen Left Sink	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS01	Kitchen Left Sink	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS01	Kitchen Left Sink	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS01	Kitchen Left Sink	Initial	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS02	Kitchen Right Sink	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS02	Kitchen Right Sink	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS02	Kitchen Right Sink	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS02	Kitchen Right Sink	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-KIT-KS02	Kitchen Right Sink	Initial	14-SEP-16	1.000	ppb
51171	51171-1-107-WC04	RM 107 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-107-WC04	RM 107 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-107-WC04	RM 107 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-107-WC04	RM 107 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-107-WC04	RM 107 Kindergarten	Initial	14-SEP-16	1.000	ppb
51171	51171-1-110-WC06	RM 110 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-110-WC06	RM 110 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-110-WC06	RM 110 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-110-WC06	RM 110 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-110-WC06	RM 110 Kindergarten	Initial	14-SEP-16	1.000	ppb
51171	51171-1-111-WC07	RM 111 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-111-WC07	RM 111 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-111-WC07	RM 111 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-111-WC07	RM 111 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-111-WC07	RM 111 Kindergarten	Initial	14-SEP-16	1.000	ppb
51171	51171-1-113-WC11	RM 113 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-113-WC11-51171-1-113-WC11	RM 113 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-113-WC11	RM 113 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-113-WC11	RM 113 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-113-WC11	RM 113 Kindergarten	Initial	14-SEP-16	1.000	ppb
51171	51171-1-115-WC12	RM 115 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-115-WC12	RM 115 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-115-WC12	RM 115 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-115-WC12	RM 115 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-115-WC12	RM 115 Kindergarten	Initial	14-SEP-16	1.000	ppb

Water Quality Assessment
William B Ogden Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51171	51171-1-109-WC05	Rm 109 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-109-WC05	Rm 109 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-109-WC05	Rm 109 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-109-WC05	Rm 109 Kindergarten	Flush180	14-SEP-16	1.000	ppb
51171	51171-1-109-WC05	Rm 109 Kindergarten	Initial	14-SEP-16	1.000	ppb