



**Sep 10, 2024**

**ONAHAN**

**6634 W RAVEN ST, Chicago IL 60631.**

Dear **ONAHAN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**ONAHAN**

**6634 W RAVEN ST, Chicago IL 60631.**

Estimadas familias de **ONAHAN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51024	51024-1-W-HAL-BF01	1st Floor, East Corridor, next to Girl's Toilet	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-BF01	1st Floor, East Corridor, next to Girl's Toilet	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-BF01	1st Floor, East Corridor, next to Girl's Toilet	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-BF01	1st Floor, East Corridor, next to Girl's Toilet	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-BF01	1st Floor, East Corridor, next to Girl's Toilet	Initial	13-FEB-20	1.000	ug/L
51024	51024-1-S-HAL-BF02	1st Floor, Outside Main Office	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-S-HAL-BF02	1st Floor, Outside Main Office	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-S-HAL-BF02	1st Floor, Outside Main Office	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-S-HAL-BF02	1st Floor, Outside Main Office	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-S-HAL-BF02	1st Floor, Outside Main Office	Initial	13-FEB-20	1.000	ug/L
51024	51024-3-HAL-F03	3rd Fl Corridor Main by 308, Left Fountain	Flush	06-OCT-2023	15.100	ug/L
51024	51024-3-HAL-F03	3rd Fl Corridor Main by 308, Left Fountain	Flush	06-OCT-2023	51.600	ug/L
51024	51024-3-HAL-F03	3rd Fl Corridor Main by 308, Left Fountain	Flush	06-OCT-2023	5.120	ug/L
51024	51024-3-HAL-F03	3rd Fl Corridor Main by 308, Left Fountain	Flush	06-OCT-2023	76.800	ug/L
51024	51024-3-HAL-F03	3rd Fl Corridor Main by 308, Left Fountain	Initial	06-OCT-2023	53.800	ug/L
51024	51024-3-HAL-F04	3rd Fl Corridor Main by 308, Right Fountain	Flush	06-OCT-2023	22.000	ug/L
51024	51024-3-HAL-F04	3rd Fl Corridor Main by 308, Right Fountain	Flush	06-OCT-2023	5.520	ug/L
51024	51024-3-HAL-F04	3rd Fl Corridor Main by 308, Right Fountain	Flush	06-OCT-2023	8.490	ug/L
51024	51024-3-HAL-F04	3rd Fl Corridor Main by 308, Right Fountain	Flush	06-OCT-2023	3.940	ug/L
51024	51024-3-HAL-F04	3rd Fl Corridor Main by 308, Right Fountain	Initial	06-OCT-2023	52.400	ug/L
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	19-SEP-17	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	19-SEP-17	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	08-DEC-17	0.492	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	08-DEC-17	0.484	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	08-DEC-17	0.494	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	08-DEC-17	0.498	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	27-SEP-16	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	27-SEP-16	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	27-SEP-16	2.100	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	27-SEP-16	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	19-MAY-17	21.200	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	19-MAY-17	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	19-MAY-17	2.780	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	19-MAY-17	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	19-SEP-17	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	19-SEP-17	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Initial	08-DEC-17	0.664	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Initial	27-SEP-16	4.800	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Initial	19-MAY-17	19.500	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Initial	19-SEP-17	1.000	ppb
51024	51024-1-W-HAL-F04	Main- 1st Floor Outside Main Office Right, Fountai	Initial	13-FEB-20	1.000	ug/L
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-MAY-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-MAY-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-MAY-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-SEP-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-SEP-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-SEP-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-SEP-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-SEP-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-SEP-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	08-DEC-17	0.605	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	27-SEP-16	3.500	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	27-SEP-16	2.600	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	27-SEP-16	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	27-SEP-16	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	19-MAY-17	1.000	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	08-DEC-17	0.507	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	08-DEC-17	0.514	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	08-DEC-17	0.506	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Initial	19-SEP-17	2.180	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Initial	08-DEC-17	0.715	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Initial	19-MAY-17	8.600	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Initial	27-SEP-16	8.900	ppb
51024	51024-2-S-HAL-F04	Main- 2nd Floor Outside Room 201 Right, Fountain	Initial	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Initial	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Initial	11-JUN-16	1.000	ppb
51024	51024-1-W-HAL-F01	Main: 1st Floor East Corridor, Next to Girls Toile	Initial	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F02	Main: 1st Floor East Corridor, Next to Girls Toile	Initial	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	19-MAY-17	4.040	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	19-MAY-17	4.850	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	19-MAY-17	5.840	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	19-MAY-17	8.220	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	19-SEP-17	1.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	19-SEP-17	1.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	19-SEP-17	1.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	19-SEP-17	1.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	08-DEC-17	0.501	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	08-DEC-17	0.668	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	08-DEC-17	0.868	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	08-DEC-17	0.585	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	11-JUN-16	181.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	18-AUG-16	190.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	08-SEP-16	9.400	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	08-SEP-16	22.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	08-SEP-16	8.300	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	08-SEP-16	8.200	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	11-JUN-16	12.600	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	11-JUN-16	7.600	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F03	Next to Main Office				
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	11-JUN-16	33.900	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	18-AUG-16	61.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	18-AUG-16	39.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	18-AUG-16	210.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Flush180	13-FEB-20	1.000	ug/L
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Initial	19-MAY-17	13.800	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Initial	19-SEP-17	10.300	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Initial	08-DEC-17	4.400	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Initial	18-AUG-16	75.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Initial	08-SEP-16	26.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Initial	11-JUN-16	2970.000	ppb
51024	51024-1-W-HAL-F03	Main: 1st Floor Main Corridor, Next to Main Office	Initial	13-FEB-20	1.000	ug/L
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	11-JUN-16	1.000	ppb
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	06-AUG-20	2.300	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	10-APR-20	2.800	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	10-APR-20	2.370	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	10-APR-20	2.300	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	10-APR-20	2.230	ug/L
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	2.470	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.810	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	7.710	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-W-	Main: 2nd Floor East Corridor,	Initial	11-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Next to Girls Toile				
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Initial	11-JUN-16	1.000	ppb
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Initial	06-AUG-20	2.790	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Initial	10-APR-20	3.490	ug/L
51024	51024-2-W-HAL-F01	Main: 2nd Floor East Corridor, Next to Girls Toile	Initial	13-FEB-20	1.000	ug/L
51024	51024-2-W-HAL-F02	Main: 2nd Floor East Corridor, Next to Girls Toile	Initial	13-FEB-20	1.130	ug/L
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	27-SEP-16	2.100	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	27-SEP-16	2.200	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	27-SEP-16	3.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	19-MAY-17	1.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	19-MAY-17	1.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	19-MAY-17	1.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	19-SEP-17	7.070	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	19-SEP-17	4.990	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	19-SEP-17	3.620	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	19-SEP-17	2.890	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	08-DEC-17	0.838	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	08-DEC-17	0.613	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	08-DEC-17	0.578	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	08-DEC-17	0.515	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	08-SEP-16	4.800	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	08-SEP-16	5.200	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	08-SEP-16	8.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	27-SEP-16	3.900	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	08-SEP-16	5.300	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	11-JUN-16	105.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	11-JUN-16	62.200	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	11-JUN-16	152.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	11-JUN-16	39.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	18-AUG-16	20.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	18-AUG-16	20.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	18-AUG-16	29.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	18-AUG-16	28.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	13-FEB-20	1.000	ug/L
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Flush180	13-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Initial	27-SEP-16	5.800	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Initial	19-MAY-17	5.270	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Initial	19-SEP-17	11.700	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Initial	08-DEC-17	3.650	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Initial	08-SEP-16	10.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Initial	11-JUN-16	1170.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Initial	18-AUG-16	110.000	ppb
51024	51024-2-S-HAL-F03	Main: 2nd Floor Main Corridor, Next to Room 201 Ea	Initial	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	11-JUN-16	15.300	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	11-JUN-16	47.200	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	11-JUN-16	14.200	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	27-SEP-16	2.700	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	27-SEP-16	2.800	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	19-MAY-17	9.230	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	19-MAY-17	2.030	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	19-MAY-17	1.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	19-MAY-17	1.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	11-JUN-16	18.500	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	18-AUG-16	16.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	18-AUG-16	23.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	18-AUG-16	17.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	18-AUG-16	54.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	08-SEP-16	7.700	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	08-SEP-16	8.700	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	08-SEP-16	7.900	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	08-SEP-16	8.100	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	27-SEP-16	1.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	27-SEP-16	2.100	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	12-JAN-18	6.790	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	08-DEC-17	18.200	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	08-DEC-17	14.600	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	08-DEC-17	12.900	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	08-DEC-17	10.500	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	12-JAN-18	1.540	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	12-JAN-18	0.787	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	12-JAN-18	0.609	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Flush180	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	19-MAY-17	17.100	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	19-SEP-17	4.490	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	18-AUG-16	520.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	08-SEP-16	6.900	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	27-SEP-16	8.800	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	08-DEC-17	24.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	12-JAN-18	12.200	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	11-JUN-16	109.000	ppb
51024	51024-3-S-HAL-F03	Main: 3rd Floor Main Corridor, Next to Room 301 Ea	Initial	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	11-JUN-16	296.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	11-JUN-16	38.900	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	18-AUG-16	77.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	18-AUG-16	93.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	18-AUG-16	100.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	18-AUG-16	96.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	08-SEP-16	6.600	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	08-SEP-16	6.700	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	08-SEP-16	5.700	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	08-DEC-17	1.990	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	24-JAN-18	0.810	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	24-JAN-18	0.746	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	24-JAN-18	0.915	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	24-JAN-18	1.300	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	08-DEC-17	5.460	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	08-DEC-17	4.290	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	08-DEC-17	2.790	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	11-JUN-16	47.400	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	11-JUN-16	123.000	ppb
51024	51024-3-S-	Main: 3rd Floor Main Corridor,	Flush180	19-MAY-17	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04	Next to Room 301 We				
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	19-MAY-17	1.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	19-MAY-17	1.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	08-SEP-16	6.600	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	27-SEP-16	5.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	27-SEP-16	8.100	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	27-SEP-16	9.400	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	19-MAY-17	2.470	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	27-SEP-16	6.700	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Flush180	13-FEB-20	1.000	ug/L
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	18-AUG-16	390.00 0	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	08-SEP-16	17.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	24-JAN-18	1.400	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	08-DEC-17	7.020	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	11-JUN-16	286.00 0	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	19-SEP-17	1.000	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	27-SEP-16	7.500	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	19-MAY-17	18.400	ppb
51024	51024-3-S-HAL-F04	Main: 3rd Floor Main Corridor, Next to Room 301 We	Initial	13-FEB-20	1.000	ug/L
51024	51024-3-HAL-F02	Main: 3rd Floor Main Corridor, Next to Room 310 Ea	Flush180	11-JUN-16	1.000	ppb
51024	51024-3-HAL-F02	Main: 3rd Floor Main Corridor, Next to Room 310 Ea	Flush180	11-JUN-16	1.000	ppb
51024	51024-3-HAL-F02	Main: 3rd Floor Main Corridor, Next to Room 310 Ea	Flush180	11-JUN-16	1.000	ppb
51024	51024-3-HAL-F02-51024-3-HAL-F02	Main: 3rd Floor Main Corridor, Next to Room 310 Ea				
51024	51024-3-HAL-F02	Main: 3rd Floor Main Corridor, Next to Room 310 Ea	Initial	11-JUN-16	10.800	ppb
51024	51024-3-HAL-F01	Main: 3rd Floor Next to Room 301, West Fountain	Initial	15-SEP-16	8.300	ppb
51024	51024-3-HAL-F01	Main: 3rd Floor Next to Room 301, West Fountain	Initial	15-SEP-16	10.000	ppb
51024	51024-3-HAL-F01	Main: 3rd Floor Next to Room 301, West Fountain	Initial	15-SEP-16	7.300	ppb
51024	51024-3-HAL-F01	Main: 3rd Floor Next to Room 301, West Fountain	Initial	15-SEP-16	5.800	ppb
51024	51024-3-HAL-F01	Main: 3rd Floor Next to Room 301, West Fountain	Initial	15-SEP-16	6.800	ppb
51024	51024-B-WM	Main: Basement, Supply Line Off of Main	Initial	15-SEP-16	73.000	ppb
51024	51024-B-WM	Main: Basement, Supply Line Off of Main	Initial	15-SEP-16	170.00 0	ppb
51024	51024-B-WM	Main: Basement, Supply Line Off of Main	Initial	15-SEP-16	170.00 0	ppb

**Water Quality Assessment**  
**William J Onahan Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51024	51024-B-WM	Main: Basement, Supply Line Off of Main	Initial	15-SEP-16	70.000	ppb
51024	51024-B-WM	Main: Basement, Supply Line Off of Main	Initial	15-SEP-16	59.000	ppb