



Sep 10, 2024

ORIOLE PARK

5424 N OKETO AVE, Chicago IL 60656.

Dear **ORIOLE PARK** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

ORIOLE PARK

5424 N OKETO AVE, Chicago IL 60656.

Estimadas familias de **ORIOLE PARK:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51025	51025-2-E-HAL-F07		Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F07		Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F07		Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F07		Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F07		Initial	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F03	Annex, across from 268, right fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F02	Annex, across from mechanical room, center fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Flush180	30-JUL-20	1.000	ug/L
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Initial	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Initial	11-JUN-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51025	51025-2-W-HAL-F01	Annex, left fountain across from 268	Initial	30-JUL-20	1.000	ug/L
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Initial	01-JUN-16	1.000	ppb
51025	51025-2-W-HAL-F02	Annex- Across From Room 268 - Center Fountain 2	Initial	11-JUN-19	1.000	ug/L
51025	51025-ANX-2-HAL-F03	Annex- Across From Room 268 - East Fountain 3	Flush180	01-JUN-16	1.000	ppb
51025	51025-ANX-2-HAL-F03	Annex- Across From Room 268 - East Fountain 3	Flush180	01-JUN-16	1.000	ppb
51025	51025-ANX-2-HAL-F03	Annex- Across From Room 268 - East Fountain 3	Flush180	01-JUN-16	1.000	ppb
51025	51025-ANX-2-HAL-F03	Annex- Across From Room 268 - East Fountain 3	Initial	01-JUN-16	1.000	ppb
51025	51025-ANX-2-HAL-F01	Annex- Across From Room 268 - West Fountain 1	Flush180	01-JUN-16	1.000	ppb
51025	51025-ANX-2-HAL-F01	Annex- Across From Room 268 - West Fountain 1	Flush180	01-JUN-16	1.000	ppb
51025	51025-ANX-2-HAL-F01	Annex- Across From Room 268 - West Fountain 1	Flush180	01-JUN-16	1.000	ppb
51025	51025-ANX-2-HAL-F01	Annex- Across From Room 268 - West Fountain 1	Flush180	01-JUN-16	1.000	ppb
51025	51025-ANX-2-HAL-F01	Annex- Across From Room 268 - West Fountain 1	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-153-F01	Annex- Insdie Room 153, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-153-F01	Annex- Insdie Room 153, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-153-F01	Annex- Insdie Room 153, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-153-F01	Annex- Insdie Room 153, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-153-F01	Annex- Insdie Room 153, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-153-F01	Annex- Insdie Room 153, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-153-F01	Annex- Insdie Room 153, Fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-153-F01	Annex- Insdie Room 153, Fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Flush180	11-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-159-F01	Annex- Insdie Room 159, Fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-153-S01	Annex- Inside Room 153, Sink	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-155-F01	Annex- Inside Room 155, Fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-155-S01	Annex- Inside Room 155, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-155-S01	Annex- Inside Room 155, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-155-S01	Annex- Inside Room 155, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-155-S01	Annex- Inside Room 155, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-155-S01	Annex- Inside Room 155, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-155-S01	Annex- Inside Room 155, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-155-S01	Annex- Inside Room 155, Sink	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-155-S01	Annex- Inside Room 155, Sink	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-	Annex- Inside Room 157, Fountain	Flush180	01-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	157-F01					
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-157-F01	Annex- Inside Room 157, Fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-157-S01	Annex- Inside Room 157, Sink	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-159-S01	Annex- Inside Room 159, Sink	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-161-F01	Annex- Inside Room 161, Fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-S-	Annex- Inside Room 161, Sink	Flush180	01-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	161-S01					
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Initial	01-JUN-16	1.000	ppb
51025	51025-1-S-161-S01	Annex- Inside Room 161, Sink	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-N-KIT-KS05	Annex- Kitchen island sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-KIT-KS05	Annex- Kitchen island sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-KIT-KS05	Annex- Kitchen island sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-KIT-KS05	Annex- Kitchen island sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-KIT-KS05	Annex- Kitchen island sink	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Initial	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS02	Annex- Kitchen, Right sink	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	11-JUN-19	77.000	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	11-JUN-19	4.160	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	11-JUN-19	1.510	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	24-APR-20	2.690	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	24-APR-20	1.970	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	24-APR-20	1.040	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	24-APR-20	1.000	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	14-MAY-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	14-MAY-20	1.000	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	14-MAY-20	1.000	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Flush180	14-MAY-20	1.000	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Initial	01-JUN-16	12.300	ppb
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Initial	11-JUN-19	174.000	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Initial	24-APR-20	11.200	ug/L
51025	51025-1-E-KIT-KS03	Annex- Kitchen, Sprayer	Initial	14-MAY-20	1.000	ug/L
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-W-KIT-KS01	Annex- Kitchen, West Sink 1	Initial	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Initial	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F01	Annex- Left Fountain 1, Across from mechanical Room	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-F01	Annex- Lunchroom Fountain 1, Left	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F01	Annex- Lunchroom Fountain 1, Left	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F01	Annex- Lunchroom Fountain 1, Left	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F01	Annex- Lunchroom Fountain 1, Left	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F01	Annex- Lunchroom Fountain 1, Left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-F01	Annex- Lunchroom Fountain 1, Left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-F01	Annex- Lunchroom Fountain 1, Left	Initial	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F01	Annex- Lunchroom Fountain 1, Left	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-F02	Annex- Lunchroom Fountain 2, Right	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F02	Annex- Lunchroom Fountain 2, Right	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F02	Annex- Lunchroom Fountain 2, Right	Flush180	01-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51025	51025-1-N-CAF-F02	Annex- Lunchroom Fountain 2, Right	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F02	Annex- Lunchroom Fountain 2, Right	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-F02	Annex- Lunchroom Fountain 2, Right	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-F02	Annex- Lunchroom Fountain 2, Right	Initial	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-F02	Annex- Lunchroom Fountain 2, Right	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Initial	01-JUN-16	1.000	ppb
51025	51025-1-N-CAF-BF01	Annex- Lunchroom bottle filler	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Initial	01-JUN-16	1.000	ppb
51025	51025-1-N-HAL-F03	Annex- across from mechanical room, right fixture	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-E-KIT-KS04	Kitchen sink, east wall	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-KIT-KS04	Kitchen sink, east wall	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-KIT-KS04	Kitchen sink, east wall	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-KIT-KS04	Kitchen sink, east wall	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-KIT-KS04	Kitchen sink, east wall	Initial	11-JUN-19	1.000	ug/L
51025	51025-2-N-HAL-F04	Main building, left fountain, across from 208	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-N-HAL-F04	Main building, left fountain, across from 208	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-N-HAL-F04	Main building, left fountain, across from 208	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-N-HAL-F04	Main building, left fountain, across from 208	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-N-HAL-F04	Main building, left fountain, across from 208	Initial	11-JUN-19	1.000	ug/L
51025	51025-2-N-HAL-F05	Main building- across from 208, right fountain	Flush180	11-JUN-19	1.050	ug/L
51025	51025-2-N-HAL-F05	Main building- across from 208, right fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-N-	Main building- across from 208,	Flush180	11-JUN-19	1.030	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F05	right fountain				
51025	51025-2-N-HAL-F05	Main building- across from 208, right fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-N-HAL-F05	Main building- across from 208, right fountain	Initial	11-JUN-19	1.150	ug/L
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Initial	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F09	Main- Across from room 200, second fountain, right faucet	Initial	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F06	Main- Next to room 200, left fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F06	Main- Next to room 200, left fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F06	Main- Next to room 200, left fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F06	Main- Next to room 200, left fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F06	Main- Next to room 200, left fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F06	Main- Next to room 200, left fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F06	Main- Next to room 200, left fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-2-E-HAL-F06	Main- Next to room 200, left fountain	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F07	Main- across from 108 left fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F07	Main- across from 108 left fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F07	Main- across from 108 left fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F04	Main- across from 108, left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F04	Main- across from 108, left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F04	Main- across from 108, left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F04	Main- across from 108, left	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F05	Main- across from 108, right	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F05	Main- across from 108, right	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F05	Main- across from 108, right	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-N-HAL-F05	Main- across from 108, right	Initial	11-JUN-19	1.010	ug/L
51025	51025-2-E-	Main- left, next to classroom 200	Flush180	11-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F08					
51025	51025-2-E-HAL-F08	Main- left, next to classroom 200	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F08	Main- left, next to classroom 200	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F08	Main- left, next to classroom 200	Flush180	11-JUN-19	1.000	ug/L
51025	51025-2-E-HAL-F08	Main- left, next to classroom 200	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F06	Main- next to 102, left fountain	Flush180	30-JUL-20	1.000	ug/L
51025	51025-1-E-HAL-F06	Main- next to 102, left fountain	Initial	30-JUL-20	1.120	ug/L
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Initial	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F08	Main- next to room 102, left	Initial	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Flush180	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Flush180	11-JUN-19	1.000	ug/L
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Initial	01-JUN-16	1.000	ppb
51025	51025-1-E-HAL-F09	Main- next to room 102, right faucet on second fountain	Initial	11-JUN-19	1.000	ug/L