



Sep 10, 2024

ORTIZ DE DOMINGUEZ

3000 S LAWDALE AVE, Chicago IL 60623.

Dear **ORTIZ DE DOMINGUEZ** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

ORTIZ DE DOMINGUEZ

3000 S LAWDALE AVE, Chicago IL 60623.

Estimadas familias de **ORTIZ DE DOMINGUEZ:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51271	51271-1-HAL-F14	1st Floor By Electrical Room, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-HAL-F14	1st Floor By Electrical Room, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-HAL-F14	1st Floor By Electrical Room, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-HAL-F14	1st Floor By Electrical Room, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-HAL-F14	1st Floor By Electrical Room, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush	24-APR-2024	1.000	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush	24-APR-2024	1.000	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush	24-APR-2024	1.000	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush	24-APR-2024	1.000	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush180	24-MAY-23	1.790	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush180	24-MAY-23	3.280	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush180	24-MAY-23	7.040	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush180	24-MAY-23	6.970	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-102-S29	1st Floor Inside Room 102, Sink	Initial	24-APR-2024	1.000	ug/L
51271	51271-1-112-S19	1st Floor Inside Room 112 Leftt, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-112-S19	1st Floor Inside Room 112 Leftt, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-112-S19	1st Floor Inside Room 112 Leftt, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-112-S19	1st Floor Inside Room 112 Leftt, Sink	Flush180	23-SEP-16	8.500	ppb
51271	51271-1-112-S19	1st Floor Inside Room 112 Leftt, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-112-S19	1st Floor Inside Room 112 Leftt, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-112-S19	1st Floor Inside Room 112 Leftt, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-112-S19	1st Floor Inside Room 112 Leftt, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Flush180	24-MAY-23	3.200	ug/L
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Flush180	23-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Flush180	23-SEP-16	4.000	ppb
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-112-S18	1st Floor Inside Room 112 Right, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-112-WC17	1st Floor Inside Room 112, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-112-WC17	1st Floor Inside Room 112, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-112-WC17	1st Floor Inside Room 112, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-112-WC17	1st Floor Inside Room 112, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-112-WC17	1st Floor Inside Room 112, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Flush180	24-MAY-23	1.290	ug/L
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Flush180	23-SEP-16	8.100	ppb
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Flush180	23-SEP-16	2.200	ppb
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-113-S21	1st Floor Inside Room 113 Left, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Flush180	24-MAY-23	1.610	ug/L
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Flush180	23-SEP-16	8.400	ppb
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-113-S22	1st Floor Inside Room 113 Right, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-113-WC20	1st Floor Inside Room 113, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-113-WC20	1st Floor Inside Room 113, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-113-WC20	1st Floor Inside Room 113, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-113-WC20	1st Floor Inside Room 113, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Flush180	24-MAY-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-114-S25	1st Floor Inside Room 114 Left, Sink	Initial	23-SEP-16	2.800	ppb
51271	51271-1-114-S24	1st Floor Inside Room 114 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-S24	1st Floor Inside Room 114 Right, Sink	Flush180	23-SEP-16	2.200	ppb
51271	51271-1-114-S24	1st Floor Inside Room 114 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-S24	1st Floor Inside Room 114 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-S24	1st Floor Inside Room 114 Right, Sink	Initial	23-SEP-16	4.500	ppb
51271	51271-1-114-WC23	1st Floor Inside Room 114, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-WC23	1st Floor Inside Room 114, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-WC23	1st Floor Inside Room 114, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-WC23	1st Floor Inside Room 114, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-114-WC23	1st Floor Inside Room 114, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-115-S27	1st Floor Inside Room 115 Left, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-115-S28	1st Floor Inside Room 115 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-115-S28	1st Floor Inside Room 115 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-115-S28	1st Floor Inside Room 115 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-115-S28	1st Floor Inside Room 115 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-115-S28	1st Floor Inside Room 115 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-S28	1st Floor Inside Room 115 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-S28	1st Floor Inside Room 115 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-S28	1st Floor Inside Room 115 Right, Sink	Initial	24-MAY-23	5.200	ug/L
51271	51271-1-115-	1st Floor Inside Room 115 Right, Sink	Initial	23-SEP-16	4.400	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S28	Sink				
51271	51271-1-115-WC26	1st Floor Inside Room 115, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-WC26	1st Floor Inside Room 115, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-WC26	1st Floor Inside Room 115, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-WC26	1st Floor Inside Room 115, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-115-WC26	1st Floor Inside Room 115, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-116-S06	1st Floor Inside Room 116 Left, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-116-S07	1st Floor Inside Room 116 Right, Sink	Initial	23-SEP-16	2.300	ppb
51271	51271-1-116-WC05	1st Floor Inside Room 116, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-WC05	1st Floor Inside Room 116, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-WC05	1st Floor Inside Room 116, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-WC05	1st Floor Inside Room 116, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-116-WC05	1st Floor Inside Room 116, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Flush180	24-MAY-23	1.690	ug/L
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Flush180	24-MAY-23	1.290	ug/L
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Flush180	23-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S10	Sink				
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Initial	24-MAY-23	2.700	ug/L
51271	51271-1-118-S10	1st Floor Inside Room 118 Left, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Flush180	23-SEP-16	5.200	ppb
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-118-S09	1st Floor Inside Room 118 Right, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-118-WC08	1st Floor Inside Room 118, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-WC08	1st Floor Inside Room 118, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-WC08	1st Floor Inside Room 118, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-WC08	1st Floor Inside Room 118, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-118-WC08	1st Floor Inside Room 118, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-1-120-WC11	1st Floor Inside Room 120, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-WC11	1st Floor Inside Room 120, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-WC11	1st Floor Inside Room 120, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-WC11	1st Floor Inside Room 120, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-WC11	1st Floor Inside Room 120, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-120-S13	1st Floor Inside Room Left, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Flush180	24-MAY-23	1.660	ug/L
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Flush180	24-MAY-23	1.030	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Initial	24-MAY-23	1.580	ug/L
51271	51271-1-120-S12	1st Floor Inside Room Right, Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Flush180	24-MAY-23	1.050	ug/L
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Initial	24-MAY-23	1.000	ug/L
51271	51271-1-KIT-KS03	1st Floor Kitchen Sink North Wall , Sink	Initial	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS02	1st Floor Kitchen Sink South Wall Center Faucet, S	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS02	1st Floor Kitchen Sink South Wall Center Faucet, S	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS02	1st Floor Kitchen Sink South Wall Center Faucet, S	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS02	1st Floor Kitchen Sink South Wall Center Faucet, S	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS02	1st Floor Kitchen Sink South Wall Center Faucet, S	Initial	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS04	1st Floor Kitchen Sink South Wall Left Faucet, Sin	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS04	1st Floor Kitchen Sink South Wall Left Faucet, Sin	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS04	1st Floor Kitchen Sink South Wall Left Faucet, Sin	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS04	1st Floor Kitchen Sink South Wall Left Faucet, Sin	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS04	1st Floor Kitchen Sink South Wall Left Faucet, Sin	Initial	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS01	1st Floor Kitchen Sink South Wall Right Faucet, Si	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS01	1st Floor Kitchen Sink South Wall Right Faucet, Si	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS01	1st Floor Kitchen Sink South Wall Right Faucet, Si	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS01	1st Floor Kitchen Sink South Wall Right Faucet, Si	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS01	1st Floor Kitchen Sink South Wall Right Faucet, Si	Flush180	18-AUG-20	1.000	ug/L
51271	51271-1-KIT-KS01	1st Floor Kitchen Sink South Wall Right Faucet, Si	Initial	23-SEP-16	1.000	ppb
51271	51271-1-KIT-KS01	1st Floor Kitchen Sink South Wall Right Faucet, Si	Initial	18-AUG-20	1.000	ug/L
51271	51271-1-HAL-WC16	1st Floor Outside Boys/Girls Bathroom, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-HAL-WC16	1st Floor Outside Boys/Girls Bathroom, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-HAL-WC16	1st Floor Outside Boys/Girls Bathroom, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-1-HAL-WC16	1st Floor Outside Boys/Girls Bathroom, Fountain	Flush180	23-SEP-16	1.000	ppb

Water Quality Assessment
Josefa Ortiz De Dominguez Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51271	51271-1-HAL-WC16	1st Floor Outside Boys/Girls Bathroom, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-2-HAL-RBF01	2nd Floor Across Electrical Room	Flush180	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-RBF01	2nd Floor Across Electrical Room	Flush180	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-RBF01	2nd Floor Across Electrical Room	Flush180	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-RBF01	2nd Floor Across Electrical Room	Flush180	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-RBF01	2nd Floor Across Electrical Room	Initial	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Flush180	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Flush180	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Flush180	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Flush180	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Flush180	23-SEP-16	1.000	ppb
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Flush180	18-AUG-20	1.000	ug/L
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Initial	24-MAY-23	1.000	ug/L
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Initial	23-SEP-16	1.000	ppb
51271	51271-2-HAL-WC01	2nd Floor Adjacent to Boys Bathroom Left, Fountain	Initial	18-AUG-20	1.000	ug/L
51271	51271-1-HAL-RBF01	2nd Floor By Electrical Room, Retrofitted Bottle Filler	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-HAL-RBF01	2nd Floor By Electrical Room, Retrofitted Bottle Filler	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-HAL-RBF01	2nd Floor By Electrical Room, Retrofitted Bottle Filler	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-HAL-RBF01	2nd Floor By Electrical Room, Retrofitted Bottle Filler	Flush180	24-MAY-23	1.000	ug/L
51271	51271-1-HAL-RBF01	2nd Floor By Electrical Room, Retrofitted Bottle Filler	Initial	24-MAY-23	1.000	ug/L