



**Sep 10, 2024**

**OTIS**

**525 N ARMOUR ST, Chicago IL 60642.**

Dear **OTIS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**OTIS**

**525 N ARMOUR ST, Chicago IL 60642.**

Estimadas familias de **OTIS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51143	51143-3-W-HAL-F04		Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F04		Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F04		Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F04		Flush180	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F03		Flush180	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F03		Flush180	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F03		Flush180	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F03		Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F04		Initial	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F03		Initial	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	04-AUG-23	6.930	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	04-AUG-23	2.310	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	04-AUG-23	2.120	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	04-AUG-23	3.110	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Initial	04-AUG-23	25.800	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Initial	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Initial	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F02	Across From Room 313, North Fountain 1	Initial	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	04-AUG-23	6.910	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	04-AUG-23	1.370	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	04-AUG-23	1.110	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	08-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Initial	04-AUG-23	4.110	ug/L
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Initial	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F03	Across From Room 313, South Fountain 2	Initial	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	04-AUG-23	1.010	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	04-AUG-23	1.000	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	04-AUG-23	1.000	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	04-AUG-23	1.000	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Initial	04-AUG-23	5.150	ug/L
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Initial	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F01	Across From Room 404, North Fountain 1	Initial	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-RBF01	Across From Room 404, Right Retrofit Bottle Filler	Flush180	04-AUG-23	5.510	ug/L
51143	51143-4-E-HAL-RBF01	Across From Room 404, Right Retrofit Bottle Filler	Flush180	04-AUG-23	2.820	ug/L
51143	51143-4-E-HAL-RBF01	Across From Room 404, Right Retrofit Bottle Filler	Flush180	04-AUG-23	1.710	ug/L
51143	51143-4-E-HAL-RBF01	Across From Room 404, Right Retrofit Bottle Filler	Flush180	04-AUG-23	1.920	ug/L
51143	51143-4-E-HAL-RBF01	Across From Room 404, Right Retrofit Bottle Filler	Initial	04-AUG-23	20.900	ug/L
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Initial	08-JUN-16	1.000	ppb
51143	51143-4-E-HAL-F02	Across From Room 404, South Fountain 2	Initial	07-JUN-19	1.000	ug/L
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Flush180	04-AUG-23	3.950	ug/L
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Flush180	04-AUG-23	8.380	ug/L
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Flush180	04-AUG-23	7.160	ug/L
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Flush180	04-AUG-23	6.430	ug/L
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Flush180	08-JUN-16	10.800	ppb
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Initial	04-AUG-23	1.210	ug/L
51143	51143-4-HAL-F04	Across From Room 413, South Left Fountain	Initial	08-JUN-16	10.700	ppb
51143	51143-4-HAL-F05	Across From Room 413, South Right Fountain	Flush180	04-AUG-23	5.470	ug/L
51143	51143-4-HAL-F05	Across From Room 413, South Right Fountain	Flush180	04-AUG-23	4.930	ug/L
51143	51143-4-HAL-F05	Across From Room 413, South Right Fountain	Flush180	04-AUG-23	4.230	ug/L
51143	51143-4-HAL-F05	Across From Room 413, South Right Fountain	Flush180	04-AUG-23	3.620	ug/L
51143	51143-4-HAL-F05	Across From Room 413, South Right Fountain	Initial	04-AUG-23	5.640	ug/L
51143	51143-4-S-HAL-F05	Hallway	Flush180	18-AUG-20	1.000	ug/L
51143	51143-4-S-HAL-F05	Hallway	Initial	18-AUG-20	1.000	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	04-AUG-23	2.990	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	04-AUG-23	1.000	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	04-AUG-23	1.000	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	04-AUG-23	1.000	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	07-JUN-19	1.270	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	07-JUN-19	2.750	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	07-JUN-19	1.690	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Flush180	07-JUN-19	1.620	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Initial	04-AUG-23	1.000	ug/L
51143	51143-2-W-213-S01	Inside Room 213, Sink	Initial	08-JUN-16	1.000	ppb
51143	51143-2-W-213-S01	Inside Room 213, Sink	Initial	07-JUN-19	1.900	ug/L
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-	Kitchen, Center Sink 2	Flush180	08-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS02					
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Initial	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS02	Kitchen, Center Sink 2	Initial	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Initial	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS01	Kitchen, North Sink 1	Initial	07-JUN-19	3.710	ug/L
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Initial	08-JUN-16	1.000	ppb
51143	51143-1-W-KIT-KS03	Kitchen, South Sink 3	Initial	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	04-AUG-23	2.260	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	04-AUG-23	2.450	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	04-AUG-23	3.550	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	04-AUG-23	2.370	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	CAF-F01					
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Initial	04-AUG-23	4.200	ug/L
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Initial	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F01	Lunchroom B, North Fountain 1	Initial	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	04-AUG-23	5.320	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	04-AUG-23	3.820	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	04-AUG-23	6.030	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	04-AUG-23	4.040	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Flush180	07-JUN-19	1.000	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Initial	04-AUG-23	3.420	ug/L
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Initial	08-JUN-16	1.000	ppb
51143	51143-1-W-CAF-F02	Lunchroom B, South Fountain 2	Initial	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	04-AUG-23	21.600	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	04-AUG-23	7.170	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	04-AUG-23	7.590	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	04-AUG-23	8.540	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Flush180	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Initial	04-AUG-23	1.000	ug/L
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Initial	08-JUN-16	1.000	ppb
51143	51143-3-W-HAL-F01	Ouside Room 304, Fountain	Initial	07-JUN-19	1.000	ug/L
51143	51143-3-W-HAL-RBF01	Ouside Room 304, Left Retrofit Bottle Filler	Flush180	04-AUG-23	1.800	ug/L
51143	51143-3-W-HAL-RBF01	Ouside Room 304, Left Retrofit Bottle Filler	Flush180	04-AUG-23	1.660	ug/L
51143	51143-3-W-HAL-RBF01	Ouside Room 304, Left Retrofit Bottle Filler	Flush180	04-AUG-23	2.720	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51143	51143-3-W-HAL-RBF01	Outside Room 304, Left Retrofit Bottle Filler	Flush180	04-AUG-23	2.360	ug/L
51143	51143-3-W-HAL-RBF01	Outside Room 304, Left Retrofit Bottle Filler	Flush180	01-SEP-23	1.000	ug/L
51143	51143-3-W-HAL-RBF01	Outside Room 304, Left Retrofit Bottle Filler	Flush180	01-SEP-23	1.000	ug/L
51143	51143-3-W-HAL-RBF01	Outside Room 304, Left Retrofit Bottle Filler	Flush180	01-SEP-23	1.000	ug/L
51143	51143-3-W-HAL-RBF01	Outside Room 304, Left Retrofit Bottle Filler	Flush180	01-SEP-23	1.000	ug/L
51143	51143-3-W-HAL-RBF01	Outside Room 304, Left Retrofit Bottle Filler	Initial	04-AUG-23	5.040	ug/L
51143	51143-3-W-HAL-RBF01	Outside Room 304, Left Retrofit Bottle Filler	Initial	01-SEP-23	1.000	ug/L
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Flush180	04-AUG-23	7.940	ug/L
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Flush180	04-AUG-23	6.700	ug/L
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Flush180	04-AUG-23	6.090	ug/L
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Flush180	04-AUG-23	5.140	ug/L
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Initial	04-AUG-23	1.100	ug/L
51143	51143-2-W-HAL-F02	Outside Room 201, Fountain	Initial	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Flush180	04-AUG-23	1.910	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Flush180	04-AUG-23	4.150	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Flush180	04-AUG-23	3.490	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Flush180	04-AUG-23	2.470	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Flush180	01-SEP-23	1.000	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Flush180	01-SEP-23	1.000	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Flush180	01-SEP-23	3.730	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Flush180	01-SEP-23	1.000	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Initial	04-AUG-23	11.000	ug/L
51143	51143-2-W-HAL-RBF01	Outside Room 204 Retrofit Bottle Filler	Initial	01-SEP-23	1.000	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	04-AUG-23	3.730	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	04-AUG-23	2.530	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	04-AUG-23	3.010	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	04-AUG-23	3.300	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	07-JUN-19	1.000	ug/L



**Water Quality Assessment  
James Otis Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Flush180	18-AUG-20	1.000	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Initial	04-AUG-23	8.030	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Initial	08-JUN-16	1.000	ppb
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Initial	07-JUN-19	1.000	ug/L
51143	51143-2-W-HAL-F01	Outside Room 204, Fountain left	Initial	18-AUG-20	1.850	ug/L