



Sep 10, 2024

OWENS

12302 S STATE ST, Chicago IL 60628.

Dear **OWENS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

OWENS

12302 S STATE ST, Chicago IL 60628.

Estimadas familias de **OWENS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	14-JUN-16	0.463	ppb
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	14-JUN-16	0.480	ppb
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	14-JUN-16	0.446	ppb
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	14-JUN-16	0.500	ppb
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	19-AUG-20	1.000	ug/L
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Initial	14-JUN-16	0.483	ppb
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Initial	19-AUG-20	1.000	ug/L
51504	51504-1-HAL-F01	South- 1st Floor By Boys Washroom, Left Fountain	Initial	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Flush180	14-JUN-16	0.656	ppb
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Flush180	14-JUN-16	0.583	ppb
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Flush180	14-JUN-16	0.503	ppb
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Flush180	14-JUN-16	0.541	ppb
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Initial	14-JUN-16	0.309	ppb
51504	51504-1-HAL-F02	South- 1st Floor By Boys Washroom, Right Fountain	Initial	02-FEB-22	1.400	ug/L
51504	51504-1-109-F07	South- 1st Floor By Room 109, Fountain	Flush180	14-JUN-16	6.140	ppb
51504	51504-1-109-F07	South- 1st Floor By Room 109, Fountain	Flush180	14-JUN-16	1.160	ppb
51504	51504-1-109-F07	South- 1st Floor By Room 109, Fountain	Flush180	14-JUN-16	2.840	ppb
51504	51504-1-109-F07	South- 1st Floor By Room 109, Fountain	Flush180	14-JUN-16	1.480	ppb
51504	51504-1-109-F07	South- 1st Floor By Room 109, Fountain	Initial	14-JUN-16	1.340	ppb
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Flush180	14-JUN-16	1.600	ppb
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Flush180	14-JUN-16	2.670	ppb
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Flush180	14-JUN-16	1.950	ppb
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Flush180	14-JUN-16	2.500	ppb
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Flush180	02-FEB-22	1.420	ug/L
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Flush180	02-FEB-22	1.740	ug/L
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Flush180	02-FEB-22	2.940	ug/L
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Flush180	02-FEB-22	1.580	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Initial	14-JUN-16	1.190	ppb
51504	51504-1-102-S06	South- 1st Floor Inside Room 102, Sink	Initial	02-FEB-22	1.920	ug/L
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Flush180	14-JUN-16	1.840	ppb
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Flush180	14-JUN-16	1.730	ppb
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Flush180	14-JUN-16	2.900	ppb
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Flush180	14-JUN-16	1.050	ppb
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Flush180	02-FEB-22	1.550	ug/L
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Flush180	02-FEB-22	1.370	ug/L
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Flush180	02-FEB-22	2.450	ug/L
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Flush180	02-FEB-22	1.610	ug/L
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Initial	14-JUN-16	3.270	ppb
51504	51504-1-KIT-KS03	South- 1st Floor Kitchen, Sink	Initial	02-FEB-22	1.940	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	14-JUN-16	14.900	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	14-JUN-16	132.000	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	14-JUN-16	13.200	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	14-JUN-16	10.000	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	10-AUG-16	3.100	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	10-AUG-16	1.000	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	10-AUG-16	1.000	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	10-AUG-16	6.100	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	02-FEB-22	6.540	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	02-FEB-22	4.360	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	02-FEB-22	5.510	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	02-FEB-22	8.140	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	03-MAR-22	1.830	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	03-MAR-22	3.270	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	03-MAR-22	5.090	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	03-MAR-22	3.640	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	25-MAR-22	1.010	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	25-MAR-22	1.270	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	25-MAR-22	2.400	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Flush180	25-MAR-22	3.510	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Initial	14-JUN-16	12.500	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Initial	10-AUG-16	1.000	ppb
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Initial	02-FEB-22	22.200	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Initial	03-MAR-22	4.780	ug/L
51504	51504-1-TL-S05	South- 1st Floor Teacher's Staff Lounge, Sink	Initial	25-MAR-22	1.990	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Flush180	14-JUN-16	5.430	ppb
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Flush180	14-JUN-16	2.720	ppb
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Flush180	14-JUN-16	1.050	ppb
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Flush180	14-JUN-16	1.260	ppb
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Flush180	02-FEB-22	1.880	ug/L
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Flush180	02-FEB-22	1.070	ug/L
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Flush180	02-FEB-22	1.860	ug/L
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Initial	14-JUN-16	2.750	ppb
51504	51504-1-TL-S04	South- 1st Floor Teachers Lounge, Sink	Initial	02-FEB-22	1.000	ug/L
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	14-JUN-16	4.600	ppb
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	14-JUN-16	3.240	ppb
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	14-JUN-16	4.570	ppb
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	14-JUN-16	3.810	ppb
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	19-AUG-20	4.080	ug/L
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	08-OCT-20	2.320	ug/L
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	08-OCT-20	2.310	ug/L
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	08-OCT-20	2.510	ug/L
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Flush180	08-OCT-20	2.550	ug/L
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Initial	14-JUN-16	4.090	ppb
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Initial	19-AUG-20	6.430	ug/L
51504	51504-2-HAL-F03	South- 2nd Floor By Room 207, Fountain	Initial	08-OCT-20	3.130	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	14-JUN-16	1.760	ppb
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	14-JUN-16	5.070	ppb
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	14-JUN-16	1.670	ppb
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	14-JUN-16	1.780	ppb
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	02-FEB-22	33.400	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	02-FEB-22	4.790	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	02-FEB-22	5.030	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	02-FEB-22	4.310	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	03-MAR-22	3.150	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	03-MAR-22	3.070	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	03-MAR-22	2.940	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	03-MAR-22	2.630	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	25-MAR-22	1.000	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	25-MAR-22	1.000	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	25-MAR-22	1.000	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Flush180	25-MAR-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Fountain				
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Initial	14-JUN-16	1.680	ppb
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Initial	02-FEB-22	3.020	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Initial	03-MAR-22	10.900	ug/L
51504	51504-2-HAL-F01	South- 2nd Floor By Room 213, Fountain	Initial	25-MAR-22	2.630	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	14-JUN-16	5.080	ppb
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	14-JUN-16	5.230	ppb
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	14-JUN-16	5.980	ppb
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	14-JUN-16	6.170	ppb
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	02-FEB-22	4.140	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	02-FEB-22	4.820	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	02-FEB-22	4.870	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	02-FEB-22	4.120	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	03-MAR-22	4.800	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	03-MAR-22	5.260	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	03-MAR-22	4.360	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	03-MAR-22	4.060	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	25-MAR-22	1.000	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	25-MAR-22	1.000	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	25-MAR-22	1.000	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Flush180	25-MAR-22	1.000	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Initial	14-JUN-16	4.750	ppb
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Initial	02-FEB-22	7.290	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Initial	03-MAR-22	6.740	ug/L
51504	51504-2-HAL-F02	South- 2nd Floor By Room 221, Fountain	Initial	25-MAR-22	2.400	ug/L
51504	51504-1-101-BF01	South- Room 101, Bottle Filler	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-BF01	South- Room 101, Bottle Filler	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-BF01	South- Room 101, Bottle Filler	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-BF01	South- Room 101, Bottle Filler	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-BF01	South- Room 101, Bottle Filler	Initial	24-JAN-23	1.000	ug/L
51504	51504-1-101-F01	South- Room 101, Fountain	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-F01	South- Room 101, Fountain	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-F01	South- Room 101, Fountain	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-F01	South- Room 101, Fountain	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-F01	South- Room 101, Fountain	Initial	24-JAN-23	1.000	ug/L
51504	51504-1-101-S01	South- Room 101, Left Sink	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-S01	South- Room 101, Left Sink	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-	South- Room 101, Left Sink	Flush180	24-JAN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51504	51504-1-101-S01	South- Room 101, Left Sink	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-S01	South- Room 101, Left Sink	Initial	24-JAN-23	1.000	ug/L
51504	51504-1-101-S02	South- Room 101, Right Sink	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-S02	South- Room 101, Right Sink	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-S02	South- Room 101, Right Sink	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-101-S02	South- Room 101, Right Sink	Initial	24-JAN-23	1.000	ug/L
51504	51504-1-102-BF01	South- Room 102, Bottle Filler	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-BF01	South- Room 102, Bottle Filler	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-BF01	South- Room 102, Bottle Filler	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-BF01	South- Room 102, Bottle Filler	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-BF01	South- Room 102, Bottle Filler	Initial	24-JAN-23	1.000	ug/L
51504	51504-1-102-F01	South- Room 102, Fountain	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-F01	South- Room 102, Fountain	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-F01	South- Room 102, Fountain	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-F01	South- Room 102, Fountain	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-F01	South- Room 102, Fountain	Initial	24-JAN-23	1.000	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Flush180	24-JAN-23	3.140	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Flush180	24-JAN-23	1.610	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Flush180	24-JAN-23	5.690	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Flush180	24-JAN-23	3.900	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Flush180	10-FEB-23	1.160	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Flush180	10-FEB-23	1.000	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Flush180	10-FEB-23	1.000	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Flush180	10-FEB-23	1.000	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Initial	24-JAN-23	3.020	ug/L
51504	51504-1-102-S01	South- Room 102, Left Sink	Initial	10-FEB-23	1.000	ug/L
51504	51504-1-102-S02	South- Room 102, Right Sink	Flush180	24-JAN-23	1.050	ug/L
51504	51504-1-102-S02	South- Room 102, Right Sink	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-S02	South- Room 102, Right Sink	Flush180	24-JAN-23	1.000	ug/L
51504	51504-1-102-S02	South- Room 102, Right Sink	Flush180	24-JAN-23	1.150	ug/L
51504	51504-1-102-S02	South- Room 102, Right Sink	Initial	24-JAN-23	1.000	ug/L
51504	51504-1-KIT-KS04	inside kitchen right	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-KIT-KS04	inside kitchen right	Flush180	02-FEB-22	1.000	ug/L
51504	51504-1-KIT-KS04	inside kitchen right	Flush180	02-FEB-22	1.240	ug/L
51504	51504-1-KIT-KS04	inside kitchen right	Flush180	02-FEB-22	1.770	ug/L
51504	51504-1-KIT-KS04	inside kitchen right	Initial	02-FEB-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51504	51504-2-HAL-RBF02	retrofitted bottle filler outside 207	Flush180	02-FEB-22	1.860	ug/L
51504	51504-2-HAL-RBF02	retrofitted bottle filler outside 207	Flush180	02-FEB-22	1.620	ug/L
51504	51504-2-HAL-RBF02	retrofitted bottle filler outside 207	Flush180	02-FEB-22	1.650	ug/L
51504	51504-2-HAL-RBF02	retrofitted bottle filler outside 207	Flush180	02-FEB-22	1.710	ug/L
51504	51504-2-HAL-RBF02	retrofitted bottle filler outside 207	Initial	02-FEB-22	2.040	ug/L
51504	51504-1-HAL-RBF01	retrofitted bottle filler outside room 109	Flush180	02-FEB-22	1.260	ug/L
51504	51504-1-HAL-RBF01	retrofitted bottle filler outside room 109	Flush180	02-FEB-22	1.370	ug/L
51504	51504-1-HAL-RBF01	retrofitted bottle filler outside room 109	Flush180	02-FEB-22	1.330	ug/L
51504	51504-1-HAL-RBF01	retrofitted bottle filler outside room 109	Flush180	02-FEB-22	1.390	ug/L
51504	51504-1-HAL-RBF01	retrofitted bottle filler outside room 109	Initial	02-FEB-22	1.800	ug/L
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Flush180	14-JUN-16	1.280	ppb
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Flush180	14-JUN-16	1.220	ppb
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Flush180	14-JUN-16	1.430	ppb
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Flush180	14-JUN-16	1.790	ppb
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Flush180	28-JAN-22	2.430	ug/L
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Flush180	28-JAN-22	1.960	ug/L
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Flush180	28-JAN-22	1.590	ug/L
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Flush180	28-JAN-22	1.410	ug/L
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Initial	14-JUN-16	1.620	ppb
51506	51506-1-HAL-F03	North- 1st Floor By Boys Wash Room, Fountain 1	Initial	28-JAN-22	2.130	ug/L
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Flush180	14-JUN-16	1.620	ppb
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Flush180	14-JUN-16	2.190	ppb
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Flush180	14-JUN-16	1.990	ppb
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Flush180	14-JUN-16	1.620	ppb
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Flush180	28-JAN-22	2.430	ug/L
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Flush180	28-JAN-22	2.310	ug/L
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Flush180	28-JAN-22	2.680	ug/L
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Flush180	28-JAN-22	2.530	ug/L
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Initial	14-JUN-16	1.560	ppb
51506	51506-1-HAL-F04	North- 1st Floor By Boys Wash Room, Fountain 2	Initial	28-JAN-22	2.150	ug/L
51506	51506-1-HAL-F07	North- 1st Floor By Men's Washroom, Fountain	Flush180	14-JUN-16	1.000	ppb
51506	51506-1-HAL-F07	North- 1st Floor By Men's Washroom, Fountain	Flush180	14-JUN-16	1.000	ppb
51506	51506-1-HAL-F07	North- 1st Floor By Men's Washroom, Fountain	Flush180	14-JUN-16	1.000	ppb
51506	51506-1-HAL-F07	North- 1st Floor By Men's Washroom, Fountain	Initial	14-JUN-16	1.000	ppb
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	14-JUN-16	2.460	ppb
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	14-JUN-16	4.970	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	14-JUN-16	3.120	ppb
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	14-JUN-16	11.600	ppb
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	19-AUG-20	2.990	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	28-JAN-22	9.090	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	28-JAN-22	5.830	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	28-JAN-22	3.580	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	28-JAN-22	2.840	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	11-MAR-22	1.780	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	11-MAR-22	1.900	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	11-MAR-22	1.660	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Flush180	11-MAR-22	1.550	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Initial	14-JUN-16	2.450	ppb
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Initial	19-AUG-20	2.730	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Initial	28-JAN-22	10.400	ug/L
51506	51506-1-HAL-F01	North- 1st Floor By Room 110, Fountain 1	Initial	11-MAR-22	2.020	ug/L
51506	51506-1-HAL-F02	North- 1st Floor By Room 110, Fountain 2	Flush180	14-JUN-16	1.200	ppb
51506	51506-1-HAL-F02	North- 1st Floor By Room 110, Fountain 2	Flush180	14-JUN-16	1.040	ppb
51506	51506-1-HAL-F02	North- 1st Floor By Room 110, Fountain 2	Flush180	14-JUN-16	0.243	ppb
51506	51506-1-HAL-F02	North- 1st Floor By Room 110, Fountain 2	Flush180	14-JUN-16	0.163	ppb
51506	51506-1-HAL-F02	North- 1st Floor By Room 110, Fountain 2	Initial	14-JUN-16	1.520	ppb
51506	51506-1-HAL-RBF01	North- 1st Floor By Room 110, Retrofitted Bottle Filler	Flush180	28-JAN-22	2.940	ug/L
51506	51506-1-HAL-RBF01	North- 1st Floor By Room 110, Retrofitted Bottle Filler	Flush180	28-JAN-22	2.980	ug/L
51506	51506-1-HAL-RBF01	North- 1st Floor By Room 110, Retrofitted Bottle Filler	Flush180	28-JAN-22	2.460	ug/L
51506	51506-1-HAL-RBF01	North- 1st Floor By Room 110, Retrofitted Bottle Filler	Flush180	28-JAN-22	2.190	ug/L
51506	51506-1-HAL-RBF01	North- 1st Floor By Room 110, Retrofitted Bottle Filler	Initial	28-JAN-22	2.770	ug/L
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Flush180	14-JUN-16	0.611	ppb
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Flush180	14-JUN-16	1.130	ppb
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Flush180	14-JUN-16	0.746	ppb
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Flush180	14-JUN-16	0.895	ppb
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Flush180	28-JAN-22	1.000	ug/L
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Flush180	28-JAN-22	1.000	ug/L
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Flush180	28-JAN-22	1.000	ug/L
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Initial	14-JUN-16	0.123	ppb
51506	51506-2-HAL-F01	North- 1st Floor By Room 206, Fountain 1	Initial	28-JAN-22	1.000	ug/L
51506	51506-2-HAL-F02	North- 1st Floor By Room 206, Fountain 2	Flush180	14-JUN-16	1.070	ppb
51506	51506-2-HAL-F02	North- 1st Floor By Room 206, Fountain 2	Flush180	14-JUN-16	1.420	ppb
51506	51506-2-HAL-F02	North- 1st Floor By Room 206, Fountain 2	Flush180	14-JUN-16	0.973	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Fountain 2				
51506	51506-2-HAL-F02	North- 1st Floor By Room 206, Fountain 2	Flush180	14-JUN-16	0.971	ppb
51506	51506-2-HAL-F02	North- 1st Floor By Room 206, Fountain 2	Initial	14-JUN-16	1.270	ppb
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	14-JUN-16	1.400	ppb
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	14-JUN-16	1.560	ppb
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	14-JUN-16	1.430	ppb
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	14-JUN-16	1.450	ppb
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	19-AUG-20	14.600	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	08-OCT-20	3.100	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	08-OCT-20	3.370	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	08-OCT-20	3.080	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	08-OCT-20	3.050	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	28-JAN-22	2.850	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	28-JAN-22	2.680	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	28-JAN-22	2.470	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	28-JAN-22	2.680	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	28-JAN-22	4.150	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	28-JAN-22	4.430	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	28-JAN-22	4.420	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Flush180	28-JAN-22	4.090	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Initial	14-JUN-16	1.570	ppb
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Initial	19-AUG-20	3.860	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Initial	08-OCT-20	2.900	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Initial	28-JAN-22	2.470	ug/L
51506	51506-2-HAL-F03	North- 1st Floor By Room 224, Fountain 1	Initial	28-JAN-22	3.580	ug/L
51506	51506-2-HAL-F04	North- 1st Floor By Room 224, Fountain 2	Flush180	14-JUN-16	1.820	ppb
51506	51506-2-HAL-F04	North- 1st Floor By Room 224, Fountain 2	Flush180	14-JUN-16	2.030	ppb
51506	51506-2-HAL-F04	North- 1st Floor By Room 224, Fountain 2	Flush180	14-JUN-16	1.870	ppb
51506	51506-2-HAL-F04	North- 1st Floor By Room 224, Fountain 2	Flush180	14-JUN-16	2.020	ppb
51506	51506-2-HAL-F04	North- 1st Floor By Room 224, Fountain 2	Initial	14-JUN-16	1.510	ppb
51506	51506-1-CAF-F06	North- 1st Floor In Lunchroom, Fountain	Flush180	14-JUN-16	1.000	ppb
51506	51506-1-CAF-F06	North- 1st Floor In Lunchroom, Fountain	Flush180	14-JUN-16	1.000	ppb
51506	51506-1-CAF-F06	North- 1st Floor In Lunchroom, Fountain	Flush180	14-JUN-16	1.000	ppb
51506	51506-1-CAF-F06	North- 1st Floor In Lunchroom, Fountain	Initial	14-JUN-16	1.000	ppb
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Flush180	14-JUN-16	2.180	ppb
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Flush180	14-JUN-16	0.477	ppb
51506	51506-1-KIT-	North- 1st Floor Kitchen, Left Sink	Flush180	14-JUN-16	0.579	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS05					
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Flush180	14-JUN-16	0.585	ppb
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Initial	14-JUN-16	1.000	ppb
51506	51506-1-KIT-KS05	North- 1st Floor Kitchen, Left Sink	Initial	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS06	North- 1st Floor Kitchen, Right Sink	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS06	North- 1st Floor Kitchen, Right Sink	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS06	North- 1st Floor Kitchen, Right Sink	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS06	North- 1st Floor Kitchen, Right Sink	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-KIT-KS06	North- 1st Floor Kitchen, Right Sink	Initial	28-JAN-22	3.070	ug/L
51506	51506-2-HAL-RBF01	North- 2nd Floor By Room 206, Retrofitted Bottle Filler	Flush180	28-JAN-22	1.260	ug/L
51506	51506-2-HAL-RBF01	North- 2nd Floor By Room 206, Retrofitted Bottle Filler	Flush180	28-JAN-22	1.070	ug/L
51506	51506-2-HAL-RBF01	North- 2nd Floor By Room 206, Retrofitted Bottle Filler	Flush180	28-JAN-22	1.130	ug/L
51506	51506-2-HAL-RBF01	North- 2nd Floor By Room 206, Retrofitted Bottle Filler	Flush180	28-JAN-22	1.000	ug/L
51506	51506-2-HAL-RBF01	North- 2nd Floor By Room 206, Retrofitted Bottle Filler	Initial	28-JAN-22	1.040	ug/L
51506	51506-1-CAF-F01	North- In Cafeteria By Men's Washroom, Fountain	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-F01	North- In Cafeteria By Men's Washroom, Fountain	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-F01	North- In Cafeteria By Men's Washroom, Fountain	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-F01	North- In Cafeteria By Men's Washroom, Fountain	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-F01	North- In Cafeteria By Men's Washroom, Fountain	Initial	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-RBF01	North- In Cafeteria By Men's Washroom, Retrofitted Bottle Filler	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-RBF01	North- In Cafeteria By Men's Washroom, Retrofitted Bottle Filler	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-RBF01	North- In Cafeteria By Men's Washroom, Retrofitted Bottle Filler	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-RBF01	North- In Cafeteria By Men's Washroom, Retrofitted Bottle Filler	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-RBF01	North- In Cafeteria By Men's Washroom, Retrofitted Bottle Filler	Initial	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-S01	North- Sink in Cafeteria	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-S01	North- Sink in Cafeteria	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-S01	North- Sink in Cafeteria	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-S01	North- Sink in Cafeteria	Flush180	28-JAN-22	1.000	ug/L
51506	51506-1-CAF-S01	North- Sink in Cafeteria	Initial	28-JAN-22	1.000	ug/L