



Sep 10, 2024

PARK MANOR

7037 S RHODES AVE, Chicago IL 60637.

Dear **PARK MANOR** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

PARK MANOR

7037 S RHODES AVE, Chicago IL 60637.

Estimadas familias de **PARK MANOR**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51382	51382-2-HAL-F03	Across From room 201 (South), Fountain 3	Flush180	18-JUN-16	0.284	ppb
51382	51382-2-HAL-F03	Across From room 201 (South), Fountain 3	Flush180	18-JUN-16	0.370	ppb
51382	51382-2-HAL-F03	Across From room 201 (South), Fountain 3	Flush180	18-JUN-16	1.180	ppb
51382	51382-2-HAL-F03	Across From room 201 (South), Fountain 3	Flush180	18-JUN-16	0.286	ppb
51382	51382-2-HAL-F03	Across From room 201 (South), Fountain 3	Initial	18-JUN-16	0.181	ppb
51382	51382-2-HAL-RBF01	Across From room 201 (South), Fountain 3	Flush180	10-NOV-21	2.810	ug/L
51382	51382-2-HAL-RBF01	Across From room 201 (South), Fountain 3	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-RBF01	Across From room 201 (South), Fountain 3	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-RBF01	Across From room 201 (South), Fountain 3	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-RBF01	Across From room 201 (South), Fountain 3	Initial	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Flush180	18-JUN-16	0.266	ppb
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Flush180	18-JUN-16	0.230	ppb
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Flush180	18-JUN-16	0.246	ppb
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Flush180	18-JUN-16	0.180	ppb
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Initial	18-JUN-16	1.000	ppb
51382	51382-2-HAL-F02	Across Room room 201 (Center), Fountain 2	Initial	10-NOV-21	1.000	ug/L
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Flush180	18-JUN-16	0.267	ppb
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Flush180	18-JUN-16	0.233	ppb
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Flush180	18-JUN-16	0.693	ppb
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Flush180	18-JUN-16	1.170	ppb
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Flush180	10-NOV-21	2.740	ug/L
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Flush180	10-NOV-21	1.860	ug/L
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Flush180	10-NOV-21	1.290	ug/L
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Flush180	10-NOV-21	1.140	ug/L
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Initial	18-JUN-16	1.220	ppb
51382	51382-1-HAL-F05	Across from Room 107, Fountain	Initial	10-NOV-21	5.320	ug/L
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Flush180	18-JUN-16	1.000	ppb
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Flush180	18-JUN-16	0.135	ppb
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Flush180	18-JUN-16	1.000	ppb
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Flush180	18-JUN-16	1.000	ppb
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Flush180	10-NOV-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Flush180	10-NOV-21	1.560	ug/L
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Initial	18-JUN-16	1.000	ppb
51382	51382-2-HAL-F01	Across from Room 201 (North), Fountain 1	Initial	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Flush180	18-JUN-16	0.400	ppb
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Flush180	18-JUN-16	0.421	ppb
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Flush180	18-JUN-16	0.205	ppb
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Flush180	18-JUN-16	0.306	ppb
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Flush180	10-NOV-21	1.390	ug/L
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Initial	18-JUN-16	0.280	ppb
51382	51382-3-HAL-F02	Across from Room 301 (Center), Fountain 2	Initial	10-NOV-21	1.160	ug/L
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Flush180	18-JUN-16	0.488	ppb
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Flush180	18-JUN-16	0.485	ppb
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Flush180	18-JUN-16	0.410	ppb
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Flush180	18-JUN-16	0.471	ppb
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Initial	18-JUN-16	0.187	ppb
51382	51382-3-HAL-F01	Across from Room 301 (North), Fountain 1	Initial	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F03	Across from Room 301 (South), Fountain 3	Flush180	18-JUN-16	0.153	ppb
51382	51382-3-HAL-F03	Across from Room 301 (South), Fountain 3	Flush180	18-JUN-16	0.139	ppb
51382	51382-3-HAL-F03	Across from Room 301 (South), Fountain 3	Flush180	18-JUN-16	0.152	ppb
51382	51382-3-HAL-F03	Across from Room 301 (South), Fountain 3	Flush180	18-JUN-16	0.183	ppb
51382	51382-3-HAL-F03	Across from Room 301 (South), Fountain 3	Initial	18-JUN-16	0.147	ppb
51382	51382-3-HAL-RBF01	Across from Room 301 (South), Fountain 3	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-RBF01	Across from Room 301 (South), Fountain 3	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-RBF01	Across from Room 301 (South), Fountain 3	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-RBF01	Across from Room 301 (South), Fountain 3	Initial	10-NOV-21	2.760	ug/L
51382	51382-1-KIT-KS02	Kitchen, Sink (Center)	Flush180	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS02	Kitchen, Sink (Center)	Flush180	10-NOV-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51382	51382-1-KIT-KS02	Kitchen, Sink (Center)	Flush180	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS02	Kitchen, Sink (Center)	Flush180	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS02	Kitchen, Sink (Center)	Initial	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Flush180	18-JUN-16	0.652	ppb
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Flush180	18-JUN-16	0.394	ppb
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Flush180	18-JUN-16	0.622	ppb
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Flush180	18-JUN-16	0.378	ppb
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Flush180	10-NOV-21	1.160	ug/L
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Flush180	10-NOV-21	1.120	ug/L
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Flush180	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Flush180	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Initial	18-JUN-16	0.202	ppb
51382	51382-1-KIT-KS01	Kitchen, Sink (North)	Initial	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS03	Kitchen, Sink (South)	Flush180	10-NOV-21	1.020	ug/L
51382	51382-1-KIT-KS03	Kitchen, Sink (South)	Flush180	10-NOV-21	1.270	ug/L
51382	51382-1-KIT-KS03	Kitchen, Sink (South)	Flush180	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS03	Kitchen, Sink (South)	Flush180	10-NOV-21	1.000	ug/L
51382	51382-1-KIT-KS03	Kitchen, Sink (South)	Initial	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Flush180	18-JUN-16	6.550	ppb
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Flush180	18-JUN-16	5.250	ppb
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Flush180	18-JUN-16	5.680	ppb
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Flush180	18-JUN-16	2.640	ppb
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Flush180	17-JUL-20	1.510	ug/L
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Flush180	10-NOV-21	1.670	ug/L
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Flush180	10-NOV-21	1.000	ug/L
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Initial	18-JUN-16	0.843	ppb
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Initial	17-JUL-20	3.010	ug/L
51382	51382-3-HAL-F04	Outside Boys Bathroom, Fountain	Initial	10-NOV-21	2.030	ug/L
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Flush180	18-JUN-16	4.440	ppb
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Flush180	18-JUN-16	1.050	ppb
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Flush180	18-JUN-16	0.554	ppb
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Flush180	18-JUN-16	0.696	ppb
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Flush180	10-NOV-21	1.000	ug/L
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Flush180	10-NOV-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Initial	18-JUN-16	1.940	ppb
51382	51382-2-HAL-F04	Outside Boys Washroom, Fountain	Initial	10-NOV-21	1.000	ug/L
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Flush180	18-JUN-16	0.287	ppb
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Flush180	18-JUN-16	0.595	ppb
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Flush180	18-JUN-16	0.322	ppb
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Flush180	18-JUN-16	0.378	ppb
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Flush180	10-NOV-21	2.100	ug/L
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Flush180	10-NOV-21	1.920	ug/L
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Flush180	10-NOV-21	1.510	ug/L
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Flush180	10-NOV-21	2.670	ug/L
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Initial	18-JUN-16	1.010	ppb
51382	51382-1-HAL-F03	Outside Lunchroom (Center), Fountain 2	Initial	10-NOV-21	2.620	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	22-SEP-22	6.550	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	22-SEP-22	1.000	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	22-SEP-22	2.460	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	22-SEP-22	1.450	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	18-JUN-16	0.853	ppb
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	18-JUN-16	0.473	ppb
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	18-JUN-16	0.618	ppb
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	18-JUN-16	0.375	ppb
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	17-JUL-20	1.170	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	10-NOV-21	1.260	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	10-NOV-21	5.560	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	10-NOV-21	2.180	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	10-NOV-21	3.480	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	24-AUG-22	2.160	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	24-AUG-22	1.360	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	24-AUG-22	1.000	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Flush180	24-AUG-22	1.720	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Initial	22-SEP-22	4.590	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Initial	18-JUN-16	1.670	ppb
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Initial	17-JUL-20	3.240	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Initial	10-NOV-21	3.840	ug/L
51382	51382-1-HAL-F02	Outside Lunchroom (North), Fountain 1	Initial	24-AUG-22	6.350	ug/L
51382	51382-1-HAL-F04	Outside Lunchroom (South), Fountain 3	Flush180	18-JUN-16	1.910	ppb
51382	51382-1-HAL-F04	Outside Lunchroom (South), Fountain 3	Flush180	18-JUN-16	1.040	ppb
51382	51382-1-HAL-F04	Outside Lunchroom (South), Fountain 3	Flush180	18-JUN-16	1.120	ppb

**Water Quality Assessment
Park Manor Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Fountain 3				
51382	51382-1-HAL-F04	Outside Lunchroom (South), Fountain 3	Flush180	18-JUN-16	1.350	ppb
51382	51382-1-HAL-F04	Outside Lunchroom (South), Fountain 3	Initial	18-JUN-16	7.560	ppb
51382	51382-1-HAL-RBF01	Outside Lunchroom (South), Fountain 3	Flush180	10-NOV-21	3.390	ug/L
51382	51382-1-HAL-RBF01	Outside Lunchroom (South), Fountain 3	Flush180	10-NOV-21	2.510	ug/L
51382	51382-1-HAL-RBF01	Outside Lunchroom (South), Fountain 3	Flush180	10-NOV-21	1.880	ug/L
51382	51382-1-HAL-RBF01	Outside Lunchroom (South), Fountain 3	Flush180	10-NOV-21	1.640	ug/L
51382	51382-1-HAL-RBF01	Outside Lunchroom (South), Fountain 3	Initial	10-NOV-21	2.530	ug/L