



Sep 10, 2024

PARKER

6800 S STEWART AVE, Chicago IL 60621.

Dear **PARKER** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

PARKER

6800 S STEWART AVE, Chicago IL 60621.

Estimadas familias de **PARKER**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51381	51381-1-HAL-F05	1st Floor North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F05	1st Floor North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F05	1st Floor North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F05	1st Floor North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F05	1st Floor North End Hall Left Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F06	1st Floor North End Hall Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F06	1st Floor North End Hall Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F06	1st Floor North End Hall Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F06	1st Floor North End Hall Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F06	1st Floor North End Hall Right Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-RBF01	2nd Floor North End Hall Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-RBF01	2nd Floor North End Hall Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-RBF01	2nd Floor North End Hall Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-RBF01	2nd Floor North End Hall Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-RBF01	2nd Floor North End Hall Bottle Filler	Initial	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F03	2nd Floor North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F03	2nd Floor North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F03	2nd Floor North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F03	2nd Floor North End Hall Left Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F05	2nd Floor South End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F05	2nd Floor South End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F05	2nd Floor South End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F05	2nd Floor South End Hall Left Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F06	2nd Floor South End Hall Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F06	2nd Floor South End Hall Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F06	2nd Floor South End Hall Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-2-HAL-F06	2nd Floor South End Hall Right Bottle Filler	Initial	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F03	3rd Floor North End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F03	3rd Floor North End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F03	3rd Floor North End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F03	3rd Floor North End Left Fountain	Initial	26-JAN-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51381	51381-3-HAL-RBF01	3rd Floor North End Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-RBF01	3rd Floor North End Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-RBF01	3rd Floor North End Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-RBF01	3rd Floor North End Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-RBF01	3rd Floor North End Right Bottle Filler	Initial	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F05	3rd Floor South End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F05	3rd Floor South End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F05	3rd Floor South End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F05	3rd Floor South End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F05	3rd Floor South End Left Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F06	3rd Floor South End Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F06	3rd Floor South End Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F06	3rd Floor South End Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F06	3rd Floor South End Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-HAL-F06	3rd Floor South End Right Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-BF04	4TH FLOOR	Flush180	07-JAN-21	1.000	ug/L
51381	51381-4-HAL-BF04	4TH FLOOR	Flush180	05-FEB-21	1.000	ug/L
51381	51381-4-HAL-BF04	4TH FLOOR	Flush180	05-FEB-21	1.000	ug/L
51381	51381-4-HAL-BF04	4TH FLOOR	Flush180	05-FEB-21	1.000	ug/L
51381	51381-4-HAL-BF04	4TH FLOOR	Flush180	05-FEB-21	1.000	ug/L
51381	51381-4-HAL-BF04	4TH FLOOR	Initial	07-JAN-21	12.800	ug/L
51381	51381-4-HAL-BF04	4TH FLOOR	Initial	05-FEB-21	3.080	ug/L
51381	51381-4-HAL-F03	4th Floor Hall North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F03	4th Floor Hall North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F03	4th Floor Hall North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F03	4th Floor Hall North End Hall Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F03	4th Floor Hall North End Hall Left Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-RBF01	4th Floor Hall North End Hall Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-RBF01	4th Floor Hall North End Hall Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-RBF01	4th Floor Hall North End Hall Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-RBF01	4th Floor Hall North End Hall Right Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-RBF01	4th Floor Hall North End Hall Right Bottle Filler	Initial	26-JAN-2024	1.920	ug/L
51381	51381-4-HAL-F05	4th Floor South End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F05	4th Floor South End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F05	4th Floor South End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F05	4th Floor South End Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F05	4th Floor South End Left Fountain	Initial	26-JAN-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51381	51381-4-HAL-F06	4th Floor South End Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F06	4th Floor South End Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F06	4th Floor South End Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F06	4th Floor South End Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-4-HAL-F06	4th Floor South End Right Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Flush180	13-SEP-16	6.720	ppb
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Flush180	13-SEP-16	8.690	ppb
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Flush180	13-SEP-16	5.980	ppb
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Flush180	24-SEP-20	49.100	ug/L
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Flush180	24-SEP-20	23.600	ug/L
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Flush180	24-SEP-20	25.500	ug/L
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Flush180	24-SEP-20	24.200	ug/L
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Initial	13-SEP-16	9.700	ppb
51381	51381-1-NEHALL-F01	Across Room 124 Left Fountain	Initial	24-SEP-20	34.000	ug/L
51381	51381-1-NEHALL-F02	Across Room 124 Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NEHALL-F02	Across Room 124 Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NEHALL-F02	Across Room 124 Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NEHALL-F02	Across Room 124 Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NEHALL-F02	Across Room 124 Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-2-NEHALL-F01	Across Room 224 Left Foutain	Flush180	13-SEP-16	5.090	ppb
51381	51381-2-NEHALL-F01	Across Room 224 Left Foutain	Flush180	13-SEP-16	5.080	ppb
51381	51381-2-NEHALL-F01	Across Room 224 Left Foutain	Flush180	13-SEP-16	7.480	ppb
51381	51381-2-NEHALL-F01	Across Room 224 Left Foutain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NEHALL-F01	Across Room 224 Left Foutain	Initial	13-SEP-16	1.000	ppb
51381	51381-2-NEHALL-F02	Across Room 224 Right Fountain	Flush180	13-SEP-16	6.240	ppb
51381	51381-2-NEHALL-F02	Across Room 224 Right Fountain	Flush180	13-SEP-16	7.440	ppb
51381	51381-2-NEHALL-F02	Across Room 224 Right Fountain	Flush180	13-SEP-16	9.480	ppb
51381	51381-2-NEHALL-F02	Across Room 224 Right Fountain	Flush180	13-SEP-16	8.930	ppb
51381	51381-2-NEHALL-F02	Across Room 224 Right Fountain	Initial	13-SEP-16	6.280	ppb
51381	51381-3-NEHALL-F02	Across Room 324 Left Fountain	Flush180	13-SEP-16	5.350	ppb
51381	51381-3-NEHALL-F02	Across Room 324 Left Fountain	Flush180	13-SEP-16	5.580	ppb
51381	51381-3-NEHALL-F02	Across Room 324 Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-NEHALL-F02	Across Room 324 Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-NEHALL-F02	Across Room 324 Left Fountain	Initial	13-SEP-16	7.050	ppb
51381	51381-1-KIT-KSO5	BY ICE MACHINE	Flush180	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KSO5	BY ICE MACHINE	Initial	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-	By Ice Machine Sink	Flush	26-JAN-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS09					
51381	51381-1-KIT-KS09	By Ice Machine Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS09	By Ice Machine Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS09	By Ice Machine Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS09	By Ice Machine Sink	Initial	26-JAN-2024	1.000	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	13-SEP-16	6.970	ppb
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	13-SEP-16	8.730	ppb
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	13-SEP-16	10.400	ppb
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	13-SEP-16	6.200	ppb
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	07-JAN-21	15.600	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	07-JAN-21	9.700	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	07-JAN-21	6.030	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	07-JAN-21	5.610	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	02-OCT-20	55.700	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	02-OCT-20	10.100	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	02-OCT-20	7.400	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	02-OCT-20	7.310	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	05-FEB-21	8.320	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	05-FEB-21	3.390	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	05-FEB-21	5.450	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	05-FEB-21	3.670	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Flush180	26-AUG-20	35.000	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Initial	13-SEP-16	10.800	ppb
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Initial	07-JAN-21	12.700	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Initial	02-OCT-20	30.600	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Initial	05-FEB-21	7.310	ug/L
51381	51381-4-NEHALL-F01	By Room 416 Left Fountain	Initial	26-AUG-20	597.000	ug/L
51381	51381-4-NEHALL-F02	By Room 416 Right Fountain	Flush180	13-SEP-16	7.260	ppb
51381	51381-4-NEHALL-F02	By Room 416 Right Fountain	Flush180	13-SEP-16	8.130	ppb
51381	51381-4-NEHALL-F02	By Room 416 Right Fountain	Flush180	13-SEP-16	8.900	ppb
51381	51381-4-NEHALL-F02	By Room 416 Right Fountain	Flush180	13-SEP-16	6.060	ppb
51381	51381-4-NEHALL-F02	By Room 416 Right Fountain	Initial	13-SEP-16	7.720	ppb
51381	51396-1-002-F01	CPC - Room 002 Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51396-1-002-F01	CPC - Room 002 Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51396-1-002-F01	CPC - Room 002 Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51396-1-002-F01	CPC - Room 002 Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51396-1-002-F01	CPC - Room 002 Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-3-317-	Central Gym	Flush	26-JAN-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51381	51381-3-317-F01	Central Gym	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-317-F01	Central Gym	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-317-F01	Central Gym	Flush	26-JAN-2024	1.000	ug/L
51381	51381-3-317-F01	Central Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-317-F01	Central Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-317-F01	Central Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-317-F01	Central Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-317-F01	Central Gym	Initial	13-SEP-16	1.000	ppb
51381	51381-3-317-F01	Central Gym	Initial	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS04	Central Island Right Faucet	Flush180	17-FEB-17	0.460	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Flush180	17-FEB-17	2.900	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Flush180	17-FEB-17	0.950	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Flush180	17-FEB-17	0.420	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Flush180	19-OCT-16	25.000	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Flush180	19-OCT-16	18.000	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Flush180	19-OCT-16	23.000	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Flush180	19-OCT-16	16.000	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Initial	17-FEB-17	0.910	ppb
51381	51381-1-KIT-KS04	Central Island Right Faucet	Initial	19-OCT-16	18.000	ppb
51381	51381-3-313-F01	East Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-313-F01	East Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-313-F01	East Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-313-F01	East Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-313-F01	East Gym	Initial	13-SEP-16	1.000	ppb
51381	51381-1-119-S01	Faculty Lounge Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-119-S01	Faculty Lounge Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-119-S01	Faculty Lounge Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-119-S01	Faculty Lounge Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-119-S01	Faculty Lounge Sink	Initial	26-JAN-2024	1.000	ug/L
51381	51381-3-GYM-F01	Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-GYM-F01	Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-GYM-F01	Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-GYM-F01	Gym	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-GYM-F01	Gym	Initial	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS02	IN BACK ROOM BY COOLER 129H	Flush180	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KS02	IN BACK ROOM BY COOLER 129H	Initial	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KS02	In Back Room By Cooler Right Sink	Flush	26-JAN-2024	1.670	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51381	51381-1-KIT-KS02	In Back Room By Cooler Right Sink	Flush	26-JAN-2024	1.450	ug/L
51381	51381-1-KIT-KS02	In Back Room By Cooler Right Sink	Flush	26-JAN-2024	1.170	ug/L
51381	51381-1-KIT-KS02	In Back Room By Cooler Right Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS02	In Back Room By Cooler Right Sink	Initial	26-JAN-2024	1.850	ug/L
51381	51381-1-KIT-KS01	Kitchen Left Sink on East Wal l	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS01	Kitchen Left Sink on East Wal l	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS01	Kitchen Left Sink on East Wal l	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS01	Kitchen Left Sink on East Wal l	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS01	Kitchen Left Sink on East Wal l	Flush180	07-JAN-21	1.000	ug/L
51381	51381-1-KIT-KS01	Kitchen Left Sink on East Wal l	Initial	13-SEP-16	5.660	ppb
51381	51381-1-KIT-KS01	Kitchen Left Sink on East Wal l	Initial	07-JAN-21	13.600	ug/L
51381	51381-1-MKIT-KS01	Kitchen North Wall Left Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-MKIT-KS01	Kitchen North Wall Left Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-MKIT-KS01	Kitchen North Wall Left Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-MKIT-KS01	Kitchen North Wall Left Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-MKIT-KS01	Kitchen North Wall Left Sink	Initial	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS02	Kitchen Right Sink East Wall	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS02	Kitchen Right Sink East Wall	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS02	Kitchen Right Sink East Wall	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS02	Kitchen Right Sink East Wall	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KS02	Kitchen Right Sink East Wall	Initial	13-SEP-16	6.680	ppb
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Flush	09-FEB-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Flush	09-FEB-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Flush	09-FEB-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Flush	09-FEB-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Initial	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS06	Kitchen Sink by Ice Machine	Initial	09-FEB-2024	1.000	ug/L
51381	51381-1-KIT-KSO1	MAIN SINK BACK WALL, DISH WASH	Flush180	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KSO1	MAIN SINK BACK WALL, DISH WASH	Flush180	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KSO1	MAIN SINK BACK WALL, DISH WASH	Flush180	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KSO1	MAIN SINK BACK WALL, DISH WASH	Flush180	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KSO1	MAIN SINK BACK WALL, DISH WASH	Initial	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KSO4	MIDDLE ILE SINK, INFRONT OF KITCHEN	Flush180	05-FEB-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51381	51381-1-KIT-KS04	MIDDLE ILE SINK, INFRONT OF KITCHEN	Initial	05-FEB-21	1.000	ug/L
51381	51381-1-KIT-KS03	Main Sink Near Window, Left Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS03	Main Sink Near Window, Left Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS03	Main Sink Near Window, Left Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS03	Main Sink Near Window, Left Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS03	Main Sink Near Window, Left Sink	Initial	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS04	Main Sink Near Window, Right Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS04	Main Sink Near Window, Right Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS04	Main Sink Near Window, Right Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS04	Main Sink Near Window, Right Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS04	Main Sink Near Window, Right Sink	Initial	26-JAN-2024	1.010	ug/L
51381	51381-1-KIT-KS05	Middle Island Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS05	Middle Island Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS05	Middle Island Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS05	Middle Island Sink	Initial	26-JAN-2024	1.920	ug/L
51381	51381-4-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F01	North End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-NHALL-F01	North End Hall Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-3-NHALL-F01	North End Hall Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F01	North End Hall Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F01	North End Hall Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	NHALL-F02					
51381	51381-3-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F02	North End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F02	North End Hall Right Fountain	Flush180	26-AUG-20	1.000	ug/L
51381	51381-3-NHALL-F02	North End Hall Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F02	North End Hall Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-2-NHALL-F02	North End Hall Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-1-NHALL-F02	North End Hall Right Fountain	Initial	26-AUG-20	1.000	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Flush	09-FEB-2024	1.000	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Flush	09-FEB-2024	2.510	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Flush	09-FEB-2024	1.000	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Flush	09-FEB-2024	1.000	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Flush	26-JAN-2024	5.250	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-MKIT-KS02	North Wall Middle Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-MKIT-KS02	North Wall Middle Sink	Flush180	13-SEP-16	8.160	ppb
51381	51381-1-MKIT-KS02	North Wall Middle Sink	Flush180	13-SEP-16	29.300	ppb
51381	51381-1-MKIT-KS02	North Wall Middle Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-MKIT-KS02	North Wall Middle Sink	Initial	13-SEP-16	50.300	ppb
51381	51381-1-KIT-KS07	North Wall Middle Sink	Initial	09-FEB-2024	1.540	ug/L
51381	51381-1-KIT-KS07	North Wall Middle Sink	Initial	26-JAN-2024	28.000	ug/L
51381	51381-1-NCAF-F01	North Wall of Cafeteria	Flush180	13-SEP-16	62.400	ppb
51381	51381-1-NCAF-F01	North Wall of Cafeteria	Flush180	13-SEP-16	6.240	ppb
51381	51381-1-CAF-F03	North Wall of Cafeteria	Flush180	19-OCT-16	6.700	ppb
51381	51381-1-CAF-F03	North Wall of Cafeteria	Flush180	19-OCT-16	9.300	ppb
51381	51381-1-CAF-F03	North Wall of Cafeteria	Flush180	19-OCT-16	5.300	ppb
51381	51381-1-CAF-F03	North Wall of Cafeteria	Flush180	19-OCT-16	3.500	ppb
51381	51381-1-NCAF-F01	North Wall of Cafeteria	Flush180	13-SEP-16	11.400	ppb
51381	51381-1-	North Wall of Cafeteria	Flush180	13-SEP-16	27.300	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	NCAF-F01					
51381	51381-1-CAF-F03	North Wall of Cafeteria	Initial	19-OCT-16	8.200	ppb
51381	51381-1-NC51381-1-NCAF-F01	North Wall of Cafeteria	Initial	13-SEP-16	7.450	ppb
51381	51381-1-WKIT-KS01	Northwest Corner Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WKIT-KS01	Northwest Corner Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WKIT-KS01	Northwest Corner Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WKIT-KS01	Northwest Corner Sink	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WKIT-KS01	Northwest Corner Sink	Initial	13-SEP-16	1.000	ppb
51381	51381-1-KIT-KSO3	PREP SINK NEXT TO MAIN SINK BY WINDOW	Flush180	05-FEB-21	1.320	ug/L
51381	51381-1-KIT-KSO3	PREP SINK NEXT TO MAIN SINK BY WINDOW	Initial	05-FEB-21	2.030	ug/L
51381	51381-1-129G-KS02	Room 129G Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-129G-KS02	Room 129G Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-129G-KS02	Room 129G Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-129G-KS02	Room 129G Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-129G-KS02	Room 129G Left Fountain	Initial	13-SEP-16	5.930	ppb
51381	51381-1-129G-KS01	Room 129G Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-129G-KS01	Room 129G Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-129G-KS01	Room 129G Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-129G-KS01	Room 129G Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-129G-KS01	Room 129G Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F01	South End Hall Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F01	South End Hall Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F01	South End Hall Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F01	South End Hall Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-1-HAL-RBF01	South End Hall Outside BR, Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-RBF01	South End Hall Outside BR, Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-	South End Hall Outside BR, Bottle	Flush	26-JAN-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF01	Filler				
51381	51381-1-HAL-RBF01	South End Hall Outside BR, Bottle Filler	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-RBF01	South End Hall Outside BR, Bottle Filler	Initial	26-JAN-2024	1.000	ug/L
51381	51381-4-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F02	South End Hall Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-4-SHALL-F02	South End Hall Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-3-SHALL-F02	South End Hall Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-2-SHALL-F02	South End Hall Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F02	South End Hall outside BR Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F02	South End Hall outside BR Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F02	South End Hall outside BR Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F02	South End Hall outside BR Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F02	South End Hall outside BR Right Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush	26-JAN-2024	1.000	ug/L
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Flush180	26-AUG-20	1.000	ug/L
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Initial	26-AUG-20	1.000	ug/L
51381	51381-1-HAL-F01	South end Hall outside BR Left Fountain	Initial	26-JAN-2024	1.000	ug/L
51381	51381-1-CAF-F01	West Wall Left Fountain	Flush	26-JAN-2024	1.760	ug/L
51381	51381-1-CAF-F01	West Wall Left Fountain	Flush	26-JAN-2024	1.130	ug/L
51381	51381-1-CAF-F01	West Wall Left Fountain	Flush	26-JAN-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51381	51381-1-CAF-F01	West Wall Left Fountain	Flush	26-JAN-2024	1.470	ug/L
51381	51381-1-CAF-F01	West Wall Left Fountain	Initial	26-JAN-2024	1.870	ug/L
51381	51381-1-CAF-F02	West Wall Right Fountain	Flush	26-JAN-2024	1.920	ug/L
51381	51381-1-CAF-F02	West Wall Right Fountain	Flush	26-JAN-2024	1.980	ug/L
51381	51381-1-CAF-F02	West Wall Right Fountain	Flush	26-JAN-2024	1.930	ug/L
51381	51381-1-CAF-F02	West Wall Right Fountain	Flush	26-JAN-2024	1.840	ug/L
51381	51381-1-CAF-F02	West Wall Right Fountain	Initial	26-JAN-2024	1.860	ug/L
51381	51381-1-WCAF-F02	West Wall of Cafeteria Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WCAF-F02	West Wall of Cafeteria Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WCAF-F02	West Wall of Cafeteria Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WCAF-F02	West Wall of Cafeteria Left Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WCAF-F02	West Wall of Cafeteria Left Fountain	Initial	13-SEP-16	1.000	ppb
51381	51381-1-WCAF-F01	West Wall of Cafeteria Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WCAF-F01	West Wall of Cafeteria Right Fountain	Flush180	13-SEP-16	1.000	ppb
51381	51381-1-WCAF-F01	West Wall of Cafeteria Right Fountain	Flush180	13-SEP-16	5.150	ppb
51381	51381-1-WCAF-F01	West Wall of Cafeteria Right Fountain	Flush180	13-SEP-16	7.770	ppb
51381	51381-1-WCAF-F01	West Wall of Cafeteria Right Fountain	Initial	13-SEP-16	7.680	ppb
51396	51396-1-KIT-KS01	CPC - Kitchen Left Sink	Flush	09-FEB-2024	1.000	ug/L
51396	51396-1-KIT-KS01	CPC - Kitchen Left Sink	Flush	09-FEB-2024	1.000	ug/L
51396	51396-1-KIT-KS01	CPC - Kitchen Left Sink	Flush	09-FEB-2024	1.000	ug/L
51396	51396-1-KIT-KS01	CPC - Kitchen Left Sink	Flush	09-FEB-2024	1.000	ug/L
51396	51396-1-KIT-KS01	CPC - Kitchen Left Sink	Initial	09-FEB-2024	1.300	ug/L
51396	51396-1-KIT-KS02	CPC - Kitchen Middle Sink	Flush	26-JAN-2024	1.060	ug/L
51396	51396-1-KIT-KS02	CPC - Kitchen Middle Sink	Flush	26-JAN-2024	1.160	ug/L
51396	51396-1-KIT-KS02	CPC - Kitchen Middle Sink	Flush	26-JAN-2024	1.320	ug/L
51396	51396-1-KIT-KS02	CPC - Kitchen Middle Sink	Flush	26-JAN-2024	1.320	ug/L
51396	51396-1-KIT-KS02	CPC - Kitchen Middle Sink	Initial	26-JAN-2024	1.030	ug/L
51396	51396-1-HAL-F01	CPC - Main Hallway Fountain	Flush	26-JAN-2024	1.050	ug/L
51396	51396-1-HAL-F01	CPC - Main Hallway Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-HAL-F01	CPC - Main Hallway Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-HAL-F01	CPC - Main Hallway Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-HAL-F01	CPC - Main Hallway Fountain	Initial	26-JAN-2024	1.230	ug/L
51396	51396-1-001-S01	CPC - RM 001 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-001-S01	CPC - RM 001 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-001-S01	CPC - RM 001 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-001-S01	CPC - RM 001 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-001-S01	CPC - RM 001 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-001-S01	CPC - RM 001 Sink	Initial	26-JAN-2024	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51396	51396-1-002-S01	CPC - RM 002 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-002-S01	CPC - RM 002 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-002-S01	CPC - RM 002 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-002-S01	CPC - RM 002 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-002-S01	CPC - RM 002 Sink	Initial	26-JAN-2024	1.000	ug/L
51396	51396-1-003-S01	CPC - RM 003 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-003-S01	CPC - RM 003 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-003-S01	CPC - RM 003 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-003-S01	CPC - RM 003 Sink	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-003-S01	CPC - RM 003 Sink	Initial	26-JAN-2024	1.000	ug/L
51396	51396-1-004-S01	CPC - RM 004 Sink	Flush	09-FEB-2024	1.000	ug/L
51396	51396-1-004-S01	CPC - RM 004 Sink	Flush	09-FEB-2024	1.000	ug/L
51396	51396-1-004-S01	CPC - RM 004 Sink	Flush	09-FEB-2024	1.400	ug/L
51396	51396-1-004-S01	CPC - RM 004 Sink	Flush	09-FEB-2024	1.260	ug/L
51396	51396-1-004-S01	CPC - RM 004 Sink	Initial	09-FEB-2024	1.210	ug/L
51396	51396-1-005-S01	CPC - RM 005 Sink	Flush	26-JAN-2024	1.770	ug/L
51396	51396-1-005-S01	CPC - RM 005 Sink	Flush	26-JAN-2024	1.610	ug/L
51396	51396-1-005-S01	CPC - RM 005 Sink	Flush	26-JAN-2024	1.880	ug/L
51396	51396-1-005-S01	CPC - RM 005 Sink	Flush	26-JAN-2024	1.970	ug/L
51396	51396-1-005-S01	CPC - RM 005 Sink	Initial	26-JAN-2024	2.000	ug/L
51396	51396-1-006-S01	CPC - RM 006 Sink	Flush	09-FEB-2024	1.350	ug/L
51396	51396-1-006-S01	CPC - RM 006 Sink	Flush	09-FEB-2024	1.970	ug/L
51396	51396-1-006-S01	CPC - RM 006 Sink	Flush	09-FEB-2024	2.640	ug/L
51396	51396-1-006-S01	CPC - RM 006 Sink	Flush	09-FEB-2024	1.850	ug/L
51396	51396-1-006-S01	CPC - RM 006 Sink	Initial	09-FEB-2024	1.410	ug/L
51396	51396-1-KIT-KS03	CPC - Right Kitchen Sink	Flush	26-JAN-2024	1.800	ug/L
51396	51396-1-KIT-KS03	CPC - Right Kitchen Sink	Flush	26-JAN-2024	1.140	ug/L
51396	51396-1-KIT-KS03	CPC - Right Kitchen Sink	Flush	26-JAN-2024	1.030	ug/L
51396	51396-1-KIT-KS03	CPC - Right Kitchen Sink	Flush	26-JAN-2024	1.160	ug/L
51396	51396-1-KIT-KS03	CPC - Right Kitchen Sink	Initial	26-JAN-2024	2.440	ug/L
51396	51396-1-001-F01	CPC - Room 001 Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-001-F01	CPC - Room 001 Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-001-F01	CPC - Room 001 Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-001-F01	CPC - Room 001 Fountain	Initial	26-JAN-2024	1.000	ug/L
51396	51396-1-003-F01	CPC - Room 003 Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-003-F01	CPC - Room 003 Fountain	Flush	26-JAN-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51396	51396-1-003-F01	CPC - Room 003 Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-003-F01	CPC - Room 003 Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-003-F01	CPC - Room 003 Fountain	Initial	26-JAN-2024	1.000	ug/L
51396	51396-1-004-F01	CPC - Room 004 Fountain	Flush	26-JAN-2024	3.650	ug/L
51396	51396-1-004-F01	CPC - Room 004 Fountain	Flush	26-JAN-2024	4.540	ug/L
51396	51396-1-004-F01	CPC - Room 004 Fountain	Flush	26-JAN-2024	4.660	ug/L
51396	51396-1-004-F01	CPC - Room 004 Fountain	Flush	26-JAN-2024	4.510	ug/L
51396	51396-1-004-F01	CPC - Room 004 Fountain	Initial	26-JAN-2024	1.290	ug/L
51396	51396-1-006-F01	CPC - Room 006 Fountain	Flush	26-JAN-2024	1.000	ug/L
51396	51396-1-006-F01	CPC - Room 006 Fountain	Flush	26-JAN-2024	1.730	ug/L
51396	51396-1-006-F01	CPC - Room 006 Fountain	Flush	26-JAN-2024	1.980	ug/L
51396	51396-1-006-F01	CPC - Room 006 Fountain	Flush	26-JAN-2024	1.730	ug/L
51396	51396-1-006-F01	CPC - Room 006 Fountain	Initial	26-JAN-2024	1.000	ug/L
51396	51396-1-TL-S01	CPC - Teachers Lounge Sink	Flush	26-JAN-2024	1.080	ug/L
51396	51396-1-TL-S01	CPC - Teachers Lounge Sink	Flush	26-JAN-2024	1.330	ug/L
51396	51396-1-TL-S01	CPC - Teachers Lounge Sink	Flush	26-JAN-2024	1.540	ug/L
51396	51396-1-TL-S01	CPC - Teachers Lounge Sink	Flush	26-JAN-2024	1.970	ug/L
51396	51396-1-TL-S01	CPC - Teachers Lounge Sink	Initial	26-JAN-2024	1.150	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Flush	20-MAR-2024	1.000	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Flush	20-MAR-2024	1.000	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Flush	20-MAR-2024	1.000	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Flush	20-MAR-2024	1.000	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Flush	09-FEB-2024	12.800	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Flush	09-FEB-2024	11.600	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Flush	09-FEB-2024	5.520	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Flush	09-FEB-2024	1.400	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Initial	20-MAR-2024	1.440	ug/L
51396	51396-1-005-F01	CPC -RM 005 Fountain	Initial	09-FEB-2024	2.280	ug/L
51396	51396-1-KIT-KS01	Kitchen Left Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS01	Kitchen Left Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS01	Kitchen Left Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS01	Kitchen Left Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS01	Kitchen Left Sink	Initial	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS02	Kitchen Middle Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS02	Kitchen Middle Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS02	Kitchen Middle Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS02	Kitchen Middle Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS02	Kitchen Middle Sink	Initial	13-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02					
51396	51396-1-KIT-KS03	Kitchen Right Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS03	Kitchen Right Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS03	Kitchen Right Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS03	Kitchen Right Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-KIT-KS03	Kitchen Right Sink	Initial	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F02	NE Hall across PR Left Fountain	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F02	NE Hall across PR Left Fountain	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F02	NE Hall across PR Left Fountain	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F02	NE Hall across PR Left Fountain	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F02	NE Hall across PR Left Fountain	Initial	13-SEP-16	1.000	ppb
51396	51396-NHAL-F01	NE Hall across PR Right Fountain	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F01	NE Hall across PR Right Fountain	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F01	NE Hall across PR Right Fountain	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F01	NE Hall across PR Right Fountain	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-NHAL-F01	NE Hall across PR Right Fountain	Initial	13-SEP-16	1.000	ppb
51396	51396-1-PR-S01	Parents Room	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-PR-S01	Parents Room	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-PR-S01	Parents Room	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-PR-S01	Parents Room	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-PR-S01	Parents Room	Initial	13-SEP-16	1.000	ppb
51396	51396-1-001-S01	RM 001 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-001-S01	RM 001 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-001-S01	RM 001 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-001-S01	RM 001 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-001-S01	RM 001 Sink	Initial	13-SEP-16	1.000	ppb
51396	51396-1-002-S01	RM 002 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-002-S01	RM 002 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-002-S01	RM 002 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-002-S01	RM 002 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-002-S01	RM 002 Sink	Initial	13-SEP-16	1.000	ppb
51396	51396-1-003-S01	RM 003 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-003-S01	RM 003 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-003-S01	RM 003 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-003-S01	RM 003 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-003-S01	RM 003 Sink	Initial	13-SEP-16	1.000	ppb
51396	51396-1-004-S01	RM 004 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-004-S01	RM 004 Sink	Flush180	13-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51396	51396-1-004-S01	RM 004 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-004-S01	RM 004 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-004-S01	RM 004 Sink	Flush180	26-AUG-20	1.560	ug/L
51396	51396-1-004-S01	RM 004 Sink	Initial	13-SEP-16	1.000	ppb
51396	51396-1-004-S01	RM 004 Sink	Initial	26-AUG-20	3.360	ug/L
51396	51396-1-005-S01	RM 005 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-005-S01	RM 005 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-005-S01	RM 005 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-005-S01	RM 005 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-005-S01	RM 005 Sink	Initial	13-SEP-16	1.000	ppb
51396	51396-1-006-S01	RM 006 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-006-S01	RM 006 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-006-S01	RM 006 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-006-S01	RM 006 Sink	Flush180	13-SEP-16	1.000	ppb
51396	51396-1-006-S01	RM 006 Sink	Initial	13-SEP-16	1.000	ppb