



**Sep 10, 2024**

**PENN**

**1616 S AVERS AVE, Chicago IL 60623.**

Dear **PENN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**PENN**

**1616 S AVERS AVE, Chicago IL 60623.**

Estimadas familias de **PENN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Flush180	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Flush180	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Initial	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Initial	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Initial	15-NOV-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Initial	15-NOV-19	1.000	ug/L
51212	51212-1-HAL-BF1	1st Floor Across From Lunchroom	Initial	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F07	1st Floor Across From Lunchroom	Initial	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F06	1st Floor Across From Lunchroom	Initial	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F05	1st Floor Across From Lunchroom	Initial	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	08-JUN-16	1.000	ppb
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	08-JUN-16	0.211	ppb
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	08-JUN-16	0.212	ppb
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	08-JUN-16	0.194	ppb
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	23-FEB-22	46.100	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	23-FEB-22	7.850	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	23-FEB-22	32.500	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	23-FEB-22	22.400	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	18-MAR-22	2.670	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	18-MAR-22	3.020	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	18-MAR-22	2.600	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Flush180	18-MAR-22	1.980	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Initial	08-JUN-16	0.231	ppb
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Initial	23-FEB-22	103.000	ug/L
51212	51212-1-HAL-F04	1st Floor by Room 107 East, Right	Initial	18-MAR-22	3.840	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	08-JUN-16	0.201	ppb
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	08-JUN-16	0.218	ppb
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	08-JUN-16	0.174	ppb
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	08-JUN-16	0.194	ppb
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	23-FEB-22	2.910	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	23-FEB-22	2.310	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	23-FEB-22	2.610	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	23-FEB-22	2.520	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	18-MAR-22	3.690	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	18-MAR-22	5.060	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	18-MAR-22	5.800	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	08-APR-22	1.000	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	08-APR-22	1.000	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	08-APR-22	1.000	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	08-APR-22	1.000	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Flush180	18-MAR-22	1.000	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Initial	08-JUN-16	0.199	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Initial	23-FEB-22	5.510	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Initial	08-APR-22	1.000	ug/L
51212	51212-1-HAL-F03	1st Floor by Room 107 West, Left	Initial	18-MAR-22	1.000	ug/L
51212	51212-1-HAL-F02	1st Floor by Room 110 East, Right	Flush180	08-JUN-16	0.411	ppb
51212	51212-1-HAL-F02	1st Floor by Room 110 East, Right	Flush180	08-JUN-16	1.000	ppb
51212	51212-1-HAL-F02	1st Floor by Room 110 East, Right	Flush180	08-JUN-16	0.269	ppb
51212	51212-1-HAL-F02	1st Floor by Room 110 East, Right	Flush180	08-JUN-16	0.148	ppb
51212	51212-1-HAL-F02	1st Floor by Room 110 East, Right	Initial	08-JUN-16	0.239	ppb
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Flush180	08-JUN-16	0.211	ppb
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Flush180	08-JUN-16	0.191	ppb
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Flush180	08-JUN-16	0.290	ppb
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Flush180	08-JUN-16	0.166	ppb
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Flush180	23-FEB-22	5.710	ug/L
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Flush180	23-FEB-22	6.560	ug/L
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Flush180	23-FEB-22	7.810	ug/L
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Flush180	23-FEB-22	5.910	ug/L
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Initial	08-JUN-16	0.446	ppb
51212	51212-1-HAL-F01	1st Floor by Room 110 West, Left	Initial	23-FEB-22	1.000	ug/L
51212	51212-1-HAL-F08	1st Floor by Room 110, Left Fountain	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F08	1st Floor by Room 110, Left Fountain	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F08	1st Floor by Room 110, Left Fountain	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F08	1st Floor by Room 110, Left Fountain	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F08	1st Floor by Room 110, Left Fountain	Initial	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-BF03	1st Floor by Room 110, Right Bottle Filler	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-BF03	1st Floor by Room 110, Right Bottle Filler	Flush180	15-SEP-23	1.170	ug/L
51212	51212-1-HAL-BF03	1st Floor by Room 110, Right Bottle Filler	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-BF03	1st Floor by Room 110, Right Bottle Filler	Flush180	15-SEP-23	1.010	ug/L
51212	51212-1-HAL-BF03	1st Floor by Room 110, Right Bottle Filler	Initial	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F09	1st Floor by Room 110, Right Fountain	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F09	1st Floor by Room 110, Right Fountain	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F09	1st Floor by Room 110, Right Fountain	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F09	1st Floor by Room 110, Right Fountain	Flush180	15-SEP-23	1.000	ug/L
51212	51212-1-HAL-F09	1st Floor by Room 110, Right Fountain	Initial	15-SEP-23	1.000	ug/L
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Flush180	08-JUN-16	0.631	ppb
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Flush180	08-JUN-16	0.720	ppb
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Flush180	08-JUN-16	1.650	ppb
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Flush180	08-JUN-16	0.614	ppb
51212	51212-1-115-	1st floor Inside Room 115, Sink	Flush180	23-FEB-22	1.120	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S05					
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Flush180	23-FEB-22	1.490	ug/L
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Flush180	23-FEB-22	1.210	ug/L
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Flush180	23-FEB-22	1.480	ug/L
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Initial	08-JUN-16	0.578	ppb
51212	51212-1-115-S05	1st floor Inside Room 115, Sink	Initial	23-FEB-22	1.630	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Flush180	23-FEB-22	4.620	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Flush180	23-FEB-22	2.620	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Flush180	23-FEB-22	1.470	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Flush180	23-FEB-22	1.510	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Flush180	18-MAR-22	3.010	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Flush180	18-MAR-22	1.630	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Flush180	18-MAR-22	1.170	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Flush180	18-MAR-22	1.350	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Initial	23-FEB-22	5.270	ug/L
51212	51212-1-HAL-BF02	1st floor by room 110 east, fountain 2 right	Initial	18-MAR-22	4.660	ug/L
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Flush180	08-JUN-16	0.581	ppb
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Flush180	08-JUN-16	0.588	ppb
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Flush180	08-JUN-16	0.447	ppb
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Flush180	08-JUN-16	0.563	ppb
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Flush180	23-FEB-22	3.850	ug/L
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Flush180	23-FEB-22	3.680	ug/L
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Flush180	23-FEB-22	3.770	ug/L
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Flush180	23-FEB-22	3.440	ug/L
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Initial	08-JUN-16	0.374	ppb
51212	51212-2-HAL-F04	2nd Floor by Room 207 East, Right	Initial	23-FEB-22	4.240	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	08-JUN-16	0.621	ppb
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	08-JUN-16	1.020	ppb
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	08-JUN-16	0.371	ppb
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	08-JUN-16	0.413	ppb
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	23-FEB-22	17.900	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	23-FEB-22	14.000	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	23-FEB-22	10.700	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	23-FEB-22	6.930	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	18-MAR-22	1.000	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	18-MAR-22	1.580	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	18-MAR-22	1.980	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Flush180	18-MAR-22	1.960	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Initial	08-JUN-16	0.490	ppb
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Initial	23-FEB-22	7.470	ug/L
51212	51212-2-HAL-F03	2nd Floor by Room 207 West, Left	Initial	18-MAR-22	1.000	ug/L
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Flush180	08-JUN-16	1.300	ppb
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Flush180	08-JUN-16	1.820	ppb
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Flush180	08-JUN-16	1.720	ppb
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Flush180	08-JUN-16	1.650	ppb
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Flush180	23-FEB-22	1.860	ug/L
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Flush180	23-FEB-22	2.180	ug/L
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Flush180	23-FEB-22	2.080	ug/L
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Flush180	23-FEB-22	2.080	ug/L
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Initial	08-JUN-16	1.590	ppb
51212	51212-3-HAL-F04	3rd Floor by Room 307 East, Right	Initial	23-FEB-22	1.960	ug/L
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Flush180	08-JUN-16	1.650	ppb
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Flush180	08-JUN-16	1.590	ppb
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Flush180	08-JUN-16	1.800	ppb
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Flush180	08-JUN-16	1.470	ppb
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Flush180	23-FEB-22	1.930	ug/L
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Flush180	23-FEB-22	2.060	ug/L
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Flush180	23-FEB-22	2.410	ug/L
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Flush180	23-FEB-22	2.080	ug/L
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Initial	08-JUN-16	1.160	ppb
51212	51212-3-HAL-F03	3rd Floor by Room 307 West, Left	Initial	23-FEB-22	1.780	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	08-JUN-16	0.819	ppb
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	08-JUN-16	0.659	ppb
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	08-JUN-16	0.407	ppb
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	08-JUN-16	0.409	ppb
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	23-FEB-22	10.800	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	23-FEB-22	10.300	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	23-FEB-22	5.400	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	23-FEB-22	7.160	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	18-MAR-22	1.590	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	18-MAR-22	1.370	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	18-MAR-22	1.040	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Flush180	18-MAR-22	1.000	ug/L
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Initial	08-JUN-16	0.543	ppb
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Initial	23-FEB-22	17.200	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51212	51212-3-HAL-F02	3rd Floor by Room 308 East, Right	Initial	18-MAR-22	2.390	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	08-JUN-16	0.416	ppb
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	08-JUN-16	0.843	ppb
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	08-JUN-16	0.564	ppb
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	08-JUN-16	0.382	ppb
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	23-FEB-22	10.800	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	23-FEB-22	23.600	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	23-FEB-22	27.500	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	23-FEB-22	22.300	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	16-OCT-20	2.810	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	18-MAR-22	2.540	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	18-MAR-22	3.400	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	18-MAR-22	2.690	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Flush180	18-MAR-22	2.220	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Initial	08-JUN-16	0.768	ppb
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Initial	23-FEB-22	3.200	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Initial	16-OCT-20	3.370	ug/L
51212	51212-3-HAL-F01	3rd Floor by Room 308 West, Left	Initial	18-MAR-22	1.600	ug/L
51212	51212-3-HAL-F05	Across from Room 310, 3rd Floor, Left	Flush180	06-JAN-23	1.000	ug/L
51212	51212-3-HAL-F05	Across from Room 310, 3rd Floor, Left	Flush180	06-JAN-23	1.130	ug/L
51212	51212-3-HAL-F05	Across from Room 310, 3rd Floor, Left	Flush180	06-JAN-23	1.240	ug/L
51212	51212-3-HAL-F05	Across from Room 310, 3rd Floor, Left	Flush180	06-JAN-23	1.200	ug/L
51212	51212-3-HAL-F05	Across from Room 310, 3rd Floor, Left	Initial	06-JAN-23	1.000	ug/L
51212	51212-3-HAL-F06	Across from Room 310, 3rd Floor, Right	Flush180	06-JAN-23	1.000	ug/L
51212	51212-3-HAL-F06	Across from Room 310, 3rd Floor, Right	Flush180	06-JAN-23	1.000	ug/L
51212	51212-3-HAL-F06	Across from Room 310, 3rd Floor, Right	Flush180	06-JAN-23	1.000	ug/L
51212	51212-3-HAL-F06	Across from Room 310, 3rd Floor, Right	Flush180	06-JAN-23	1.000	ug/L
51212	51212-3-HAL-BF01	Across from Room 310, 3rd Floor, Right	Flush180	06-JAN-23	1.020	ug/L
51212	51212-3-HAL-BF01	Across from Room 310, 3rd Floor, Right	Flush180	06-JAN-23	1.450	ug/L
51212	51212-3-HAL-BF01	Across from Room 310, 3rd Floor, Right	Flush180	06-JAN-23	1.650	ug/L
51212	51212-3-HAL-BF01	Across from Room 310, 3rd Floor, Right	Flush180	06-JAN-23	1.840	ug/L
51212	51212-3-HAL-F06	Across from Room 310, 3rd Floor, Right	Initial	06-JAN-23	1.090	ug/L
51212	51212-3-HAL-BF01	Across from Room 310, 3rd Floor, Right	Initial	06-JAN-23	1.000	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	08-JUN-16	1.510	ppb
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	08-JUN-16	1.290	ppb
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	08-JUN-16	1.870	ppb
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	08-JUN-16	1.760	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	23-FEB-22	124.000	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	23-FEB-22	23.100	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	23-FEB-22	15.900	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	23-FEB-22	19.500	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	10-JUN-22	2.090	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	10-JUN-22	2.080	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	10-JUN-22	1.160	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	10-JUN-22	1.670	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	08-APR-22	2.870	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	08-APR-22	1.950	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	08-APR-22	1.940	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	18-MAR-22	14.500	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	18-MAR-22	21.200	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	18-MAR-22	24.500	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	18-MAR-22	13.800	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Flush180	08-APR-22	5.430	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Initial	08-JUN-16	1.670	ppb
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Initial	23-FEB-22	8.110	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Initial	10-JUN-22	4.240	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Initial	18-MAR-22	20.900	ug/L
51212	51212-B-HAL-F05	Basement by Engineer's Office North, Fountain 1	Initial	08-APR-22	10.000	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	08-JUN-16	10.200	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	08-JUN-16	6.520	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	08-JUN-16	4.210	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	08-JUN-16	5.610	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	13-JUL-16	1.640	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	13-JUL-16	1.440	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	13-JUL-16	1.240	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	13-JUL-16	1.520	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	23-FEB-22	24.100	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	23-FEB-22	24.400	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	16-OCT-20	1.000	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	23-FEB-22	14.600	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	23-FEB-22	13.500	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	10-JUN-22	1.000	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	10-JUN-22	1.000	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	10-JUN-22	1.000	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	10-JUN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	North, Fountain 2				
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	08-APR-22	2.250	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	08-APR-22	1.870	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	08-APR-22	3.350	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	08-APR-22	1.230	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	18-MAR-22	9.410	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	18-MAR-22	14.400	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	18-MAR-22	9.560	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Flush180	18-MAR-22	11.500	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Initial	08-JUN-16	15.900	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Initial	13-JUL-16	1.710	ppb
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Initial	16-OCT-20	1.790	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Initial	23-FEB-22	24.300	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Initial	10-JUN-22	1.000	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Initial	08-APR-22	47.100	ug/L
51212	51212-B-HAL-F06	Basement by Engineer's Office North, Fountain 2	Initial	18-MAR-22	48.500	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Flush180	27-JUL-23	1.950	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Flush180	27-JUL-23	1.500	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Flush180	27-JUL-23	1.960	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Flush180	27-JUL-23	1.240	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Flush180	18-AUG-23	153.000	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Flush180	18-AUG-23	74.000	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Flush180	18-AUG-23	36.800	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Flush180	18-AUG-23	30.600	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Initial	27-JUL-23	6.000	ug/L
51212	51212-B-HAL-F07	Basement by Engineer's Office North, Fountain 3	Initial	18-AUG-23	64.600	ug/L
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Flush180	08-JUN-16	3.980	ppb
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Flush180	08-JUN-16	9.050	ppb
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Flush180	08-JUN-16	1.820	ppb
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Flush180	08-JUN-16	2.020	ppb
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Flush180	23-FEB-22	310.000	ug/L
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Flush180	23-FEB-22	360.000	ug/L
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Flush180	23-FEB-22	210.000	ug/L
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Flush180	23-FEB-22	90.800	ug/L
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Initial	08-JUN-16	6.260	ppb
51212	51212-B-HAL-F08	Basement by Engineer's Office North, Fountain 4	Initial	23-FEB-22	170.000	ug/L
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Flush180	18-AUG-23	146.000	ug/L
51212	51212-B-HAL-	Basement by Engineer's Office	Flush180	18-AUG-23	71.500	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09	North, Fountain 5				
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Flush180	18-AUG-23	31.700	ug/L
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Flush180	18-AUG-23	28.100	ug/L
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Flush180	27-JUL-23	372.000	ug/L
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Flush180	27-JUL-23	634.000	ug/L
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Flush180	27-JUL-23	466.000	ug/L
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Flush180	27-JUL-23	231.000	ug/L
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Initial	18-AUG-23	27.900	ug/L
51212	51212-B-HAL-F09	Basement by Engineer's Office North, Fountain 5	Initial	27-JUL-23	17.200	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	08-JUN-16	9.100	ppb
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	08-JUN-16	3.570	ppb
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	08-JUN-16	3.030	ppb
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	08-JUN-16	3.010	ppb
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	23-FEB-22	13.600	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	23-FEB-22	13.500	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	23-FEB-22	14.600	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	23-FEB-22	12.900	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	10-JUN-22	1.420	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	10-JUN-22	1.820	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	10-JUN-22	2.430	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	10-JUN-22	2.230	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	08-APR-22	2.070	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	08-APR-22	2.710	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	08-APR-22	2.640	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	08-APR-22	1.950	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	18-MAR-22	15.100	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	18-MAR-22	36.600	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	18-MAR-22	33.200	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Flush180	18-MAR-22	27.400	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Initial	08-JUN-16	3.280	ppb
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Initial	23-FEB-22	21.800	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Initial	10-JUN-22	3.100	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Initial	08-APR-22	6.780	ug/L
51212	51212-B-HAL-F10	Basement by Engineer's Office North, Fountain 6	Initial	18-MAR-22	16.500	ug/L
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Flush180	08-JUN-16	5.970	ppb
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Flush180	08-JUN-16	6.660	ppb
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Flush180	08-JUN-16	5.860	ppb
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Flush180	08-JUN-16	6.550	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Flush180	23-FEB-22	1.660	ug/L
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Flush180	23-FEB-22	2.760	ug/L
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Flush180	23-FEB-22	2.650	ug/L
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Flush180	23-FEB-22	3.420	ug/L
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Initial	08-JUN-16	5.580	ppb
51212	51212-B-HAL-F03	Basement by Room # 8 North, Fountain 3	Initial	23-FEB-22	2.430	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	08-JUN-16	5.470	ppb
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	08-JUN-16	5.610	ppb
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	08-JUN-16	6.620	ppb
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	08-JUN-16	13.400	ppb
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	23-FEB-22	8.290	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	23-FEB-22	4.560	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	23-FEB-22	4.840	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	23-FEB-22	7.750	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	18-MAR-22	2.490	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	18-MAR-22	1.330	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	18-MAR-22	3.260	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Flush180	18-MAR-22	1.790	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Initial	08-JUN-16	5.630	ppb
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Initial	23-FEB-22	4.320	ug/L
51212	51212-B-HAL-F04	Basement by Room # 8 North, Fountain 4	Initial	18-MAR-22	4.340	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	08-JUN-16	1.700	ppb
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	08-JUN-16	8.270	ppb
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	08-JUN-16	13.100	ppb
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	08-JUN-16	2.180	ppb
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	23-FEB-22	5.560	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	23-FEB-22	3.440	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	23-FEB-22	5.300	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	23-FEB-22	5.980	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	18-MAR-22	1.890	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	18-MAR-22	1.930	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	18-MAR-22	2.040	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Flush180	18-MAR-22	2.110	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Initial	08-JUN-16	3.300	ppb
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Initial	23-FEB-22	3.370	ug/L
51212	51212-B-HAL-F01	Basement by Room # 8 North, Left	Initial	18-MAR-22	1.030	ug/L
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	08-JUN-16	5.060	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	08-JUN-16	26.900	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	08-JUN-16	11.600	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	08-JUN-16	7.030	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	13-JUL-16	3.660	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	13-JUL-16	3.510	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	13-JUL-16	3.730	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	13-JUL-16	3.740	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	23-FEB-22	1.900	ug/L
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	23-FEB-22	2.210	ug/L
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	23-FEB-22	2.130	ug/L
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Flush180	23-FEB-22	1.400	ug/L
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Initial	08-JUN-16	7.130	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Initial	13-JUL-16	4.770	ppb
51212	51212-B-HAL-F02	Basement by Room # 8 North, Right	Initial	23-FEB-22	4.020	ug/L
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Flush180	08-JUN-16	0.522	ppb
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Flush180	08-JUN-16	0.474	ppb
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Flush180	08-JUN-16	0.577	ppb
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Flush180	08-JUN-16	0.485	ppb
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Flush180	23-FEB-22	3.070	ug/L
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Flush180	23-FEB-22	2.320	ug/L
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Flush180	23-FEB-22	2.400	ug/L
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Flush180	23-FEB-22	1.960	ug/L
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Initial	08-JUN-16	0.563	ppb
51212	51212-B-KIT-KS11	Inside Kitchen, Sink	Initial	23-FEB-22	1.690	ug/L
51212	51212-B-KIT-KS12	inside kitchen center sink	Flush180	23-FEB-22	1.490	ug/L
51212	51212-B-KIT-KS12	inside kitchen center sink	Flush180	23-FEB-22	1.580	ug/L
51212	51212-B-KIT-KS12	inside kitchen center sink	Flush180	23-FEB-22	1.290	ug/L
51212	51212-B-KIT-KS12	inside kitchen center sink	Flush180	23-FEB-22	1.260	ug/L
51212	51212-B-KIT-KS12	inside kitchen center sink	Initial	23-FEB-22	1.740	ug/L
51212	51212-B-KIT-KS13	inside kitchen right sink	Flush180	23-FEB-22	1.000	ug/L
51212	51212-B-KIT-KS13	inside kitchen right sink	Flush180	23-FEB-22	1.000	ug/L
51212	51212-B-KIT-KS13	inside kitchen right sink	Flush180	23-FEB-22	1.000	ug/L
51212	51212-B-KIT-KS13	inside kitchen right sink	Flush180	23-FEB-22	1.000	ug/L
51212	51212-B-KIT-KS13	inside kitchen right sink	Initial	23-FEB-22	1.000	ug/L