



Nov 15, 2023

PERSPECTIVES - MATH & SCI HS

3663 S WABASH AVE, Chicago IL 60653.

Dear **PERSPECTIVES - MATH & SCI HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb. These fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Nov 15, 2023

PERSPECTIVES - MATH & SCI HS

3663 S WABASH AVE, Chicago IL 60653.

Estimadas familias de **PERSPECTIVES - MATH & SCI HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anejo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52311	52311-1-HAL-F04	Main- Across From Room 107, Left Fountain	Flush180	05-OCT-16	2.800	ppb
52311	52311-1-HAL-F04	Main- Across From Room 107, Left Fountain	Flush180	05-OCT-16	2.800	ppb
52311	52311-1-HAL-F04	Main- Across From Room 107, Left Fountain	Flush180	05-OCT-16	2.900	ppb
52311	52311-1-HAL-F04	Main- Across From Room 107, Left Fountain	Flush180	05-OCT-16	2.800	ppb
52311	52311-1-HAL-F04	Main- Across From Room 107, Left Fountain	Initial	05-OCT-16	2.600	ppb
52311	52311-1-HAL-F05	Main- Across From Room 107, Right Fountain	Flush180	05-OCT-16	2.800	ppb
52311	52311-1-HAL-F05	Main- Across From Room 107, Right Fountain	Flush180	05-OCT-16	3.100	ppb
52311	52311-1-HAL-F05	Main- Across From Room 107, Right Fountain	Flush180	05-OCT-16	2.900	ppb
52311	52311-1-HAL-F05	Main- Across From Room 107, Right Fountain	Flush180	05-OCT-16	2.800	ppb
52311	52311-1-HAL-F05	Main- Across From Room 107, Right Fountain	Initial	05-OCT-16	2.300	ppb
52311	52311-1-HAL-F02	Main- Across From Room 117, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-1-HAL-F02	Main- Across From Room 117, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-1-HAL-F02	Main- Across From Room 117, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-1-HAL-F02	Main- Across From Room 117, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-1-HAL-F02	Main- Across From Room 117, Right Fountain	Initial	05-OCT-16	1.000	ppb
52311	52311-2-HAL-F01	Main- Across From Room 217, Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-2-HAL-F01	Main- Across From Room 217, Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-2-HAL-F01	Main- Across From Room 217, Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-2-HAL-F01	Main- Across From Room 217, Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-2-HAL-F01	Main- Across From Room 217, Fountain	Initial	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F05	Main- Across From Room 304, Left Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F05	Main- Across From Room 304, Left Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F05	Main- Across From Room 304, Left Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F05	Main- Across From Room 304, Left Fountain	Initial	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F04	Main- Across From Room 304, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F04	Main- Across From Room 304, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F04	Main- Across From Room 304, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F04	Main- Across From Room 304, Right Fountain	Initial	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F01	Main- Across From Room 317, Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F01	Main- Across From Room 317, Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F01	Main- Across From Room 317, Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F01	Main- Across From Room 317, Fountain	Initial	05-OCT-16	1.000	ppb

**Water Quality Assessment
Perspectives - Math and Science Academy**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52311	52311-3-HAL-F03	Main- Outside of Room 310, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F03	Main- Outside of Room 310, Right Fountain	Flush180	05-OCT-16	1.000	ppb
52311	52311-3-HAL-F03	Main- Outside of Room 310, Right Fountain	Initial	05-OCT-16	1.000	ppb