



Sep 10, 2024

PICCOLO

1040 N KEELER AVE, Chicago IL 60651.

Dear **PICCOLO** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

PICCOLO

1040 N KEELER AVE, Chicago IL 60651.

Estimadas familias de **PICCOLO**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-1-W-102-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F04		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F04		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F05		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F05		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F05		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F05		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-S-HAL-F11		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-S-HAL-F07		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-S-HAL-F07		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-S-HAL-F07		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-S-HAL-F07		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-S01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-N-HAL-F01		Flush180	30-AUG-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-2-N-HAL-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-N-HAL-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-N-HAL-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F03		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F03		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F03		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F03		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F04		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F04		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-S-HAL-F11		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-S-HAL-F11		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-S-HAL-F11		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F13		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F13		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F13		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F13		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F14		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F14		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F14		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F14		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F15		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F15		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F15		Flush180	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F15		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-111-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-111-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-111-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-111-F01		Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-S01		Flush180	30-AUG-19	6.790	ug/L
51127	51127-1-E-111-S01		Flush180	30-AUG-19	3.850	ug/L
51127	51127-1-E-111-S01		Flush180	30-AUG-19	2.050	ug/L
51127	51127-1-E-111-S01		Flush180	30-AUG-19	1.470	ug/L
51127	51127-1-E-111-S01		Flush180	30-AUG-19	1.580	ug/L
51127	51127-1-E-111-S01		Flush180	26-SEP-19	1.000	ug/L
51127	51127-1-E-111-S01		Flush180	26-SEP-19	1.000	ug/L
51127	51127-1-E-111-S01		Flush180	26-SEP-19	1.740	ug/L
51127	51127-1-E-111-S01		Flush180	26-SEP-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-2-S-HAL-F11		Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-S-HAL-F11		Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-S-HAL-F11		Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-S-HAL-F11		Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-W-103-F01		Initial	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F05		Initial	30-AUG-19	1.000	ug/L
51127	51127-2-S-HAL-F11		Initial	30-AUG-19	1.000	ug/L
51127	51127-1-E-111-S01		Initial	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-S01		Initial	30-AUG-19	4.000	ug/L
51127	51127-1-S-HAL-F07		Initial	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-F01		Initial	30-AUG-19	1.000	ug/L
51127	51127-1-W-102-S01		Initial	30-AUG-19	1.000	ug/L
51127	51127-2-N-HAL-F01		Initial	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F03		Initial	30-AUG-19	1.000	ug/L
51127	51127-2-NW-HAL-F04		Initial	30-AUG-19	1.000	ug/L
51127	51127-1-W-103-S01		Initial	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F13		Initial	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F14		Initial	30-AUG-19	1.000	ug/L
51127	51127-2-SW-HAL-F15		Initial	30-AUG-19	1.000	ug/L
51127	51127-1-E-111-F01		Initial	30-AUG-19	1.000	ug/L
51127	51127-1-E-112-F01		Initial	30-AUG-19	1.000	ug/L
51127	51127-1-E-111-S01		Initial	26-SEP-19	1.470	ug/L
51127	51127-2-S-HAL-F11		Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F04	1st Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-HAL-F04	1st Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-HAL-F04	1st Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.133	ppb
51127	51127-1-HAL-F03	1st Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-HAL-F03	1st Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-HAL-F03	1st Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-HAL-F03	1st Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-HAL-F04	1st Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-HAL-F03	1st Fl. Corridor Between North Boys & Girls Toilet	Initial	08-JUN-16	0.138	ppb
51127	51127-1-HAL-F04	1st Fl. Corridor Between North Boys & Girls Toilet	Initial	08-JUN-16	0.449	ppb
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Flush180	08-JUN-16	0.159	ppb
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Flush180	08-JUN-16	0.136	ppb
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Flush180	08-JUN-16	0.131	ppb
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Flush180	08-JUN-16	0.133	ppb
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Flush180	09-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07	Boys & Girls Toilet				
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Initial	08-JUN-16	0.492	ppb
51127	51127-1-HAL-F07	1st Fl. Corridor Between South Boys & Girls Toilet	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-WC05	1st Fl. Corridor Near Room 115, Fountain 1	Flush180	08-JUN-16	0.194	ppb
51127	51127-1-HAL-WC05	1st Fl. Corridor Near Room 115, Fountain 1	Flush180	08-JUN-16	0.135	ppb
51127	51127-1-HAL-WC05	1st Fl. Corridor Near Room 115, Fountain 1	Flush180	08-JUN-16	0.172	ppb
51127	51127-1-HAL-WC05	1st Fl. Corridor Near Room 115, Fountain 1	Flush180	08-JUN-16	0.209	ppb
51127	51127-1-HAL-WC05	1st Fl. Corridor Near Room 115, Fountain 1	Initial	08-JUN-16	1.000	ppb
51127	51127-1-HAL-WC06	1st Fl. Corridor Near Room 115, Fountain 2	Flush180	08-JUN-16	0.245	ppb
51127	51127-1-HAL-WC06	1st Fl. Corridor Near Room 115, Fountain 2	Flush180	08-JUN-16	0.277	ppb
51127	51127-1-HAL-WC06	1st Fl. Corridor Near Room 115, Fountain 2	Flush180	08-JUN-16	0.258	ppb
51127	51127-1-HAL-WC06	1st Fl. Corridor Near Room 115, Fountain 2	Flush180	08-JUN-16	0.231	ppb
51127	51127-1-HAL-WC06	1st Fl. Corridor Near Room 115, Fountain 2	Initial	08-JUN-16	0.212	ppb
51127	51127-1-HAL-F01	1st Fl. Corridor Near Room 127, Fountain	Flush180	08-JUN-16	1.500	ppb
51127	51127-1-HAL-F01	1st Fl. Corridor Near Room 127, Fountain	Flush180	08-JUN-16	1.190	ppb
51127	51127-1-HAL-F01	1st Fl. Corridor Near Room 127, Fountain	Flush180	08-JUN-16	1.060	ppb
51127	51127-1-HAL-F01	1st Fl. Corridor Near Room 127, Fountain	Flush180	08-JUN-16	1.250	ppb
51127	51127-1-HAL-F01	1st Fl. Corridor Near Room 127, Fountain	Initial	08-JUN-16	1.980	ppb
51127	51127-1-HAL-F15	1st Floor Corridor Across Room 110, Fountain 1	Flush180	08-JUN-16	1.150	ppb
51127	51127-1-HAL-F15	1st Floor Corridor Across Room 110, Fountain 1	Flush180	08-JUN-16	1.030	ppb
51127	51127-1-HAL-F15	1st Floor Corridor Across Room 110, Fountain 1	Flush180	08-JUN-16	1.100	ppb
51127	51127-1-HAL-F15	1st Floor Corridor Across Room 110, Fountain 1	Flush180	08-JUN-16	0.858	ppb
51127	51127-1-HAL-F15	1st Floor Corridor Across Room 110, Fountain 1	Initial	08-JUN-16	0.389	ppb
51127	51127-1-HAL-F16	1st Floor Corridor Across Room 110, Fountain 2	Flush180	08-JUN-16	0.181	ppb
51127	51127-1-HAL-F16	1st Floor Corridor Across Room 110, Fountain 2	Flush180	08-JUN-16	0.265	ppb
51127	51127-1-HAL-F16	1st Floor Corridor Across Room 110, Fountain 2	Flush180	08-JUN-16	0.143	ppb
51127	51127-1-HAL-F16	1st Floor Corridor Across Room 110, Fountain 2	Flush180	08-JUN-16	0.121	ppb
51127	51127-1-HAL-F16	1st Floor Corridor Across Room 110, Fountain 2	Initial	08-JUN-16	0.563	ppb
51127	51127-1-HAL-F17	1st Floor Corridor Across Room 110, Fountain 3	Flush180	08-JUN-16	0.257	ppb
51127	51127-1-HAL-F17	1st Floor Corridor Across Room 110, Fountain 3	Flush180	08-JUN-16	0.239	ppb
51127	51127-1-HAL-F17	1st Floor Corridor Across Room 110, Fountain 3	Flush180	08-JUN-16	0.311	ppb
51127	51127-1-HAL-F17	1st Floor Corridor Across Room 110, Fountain 3	Flush180	08-JUN-16	0.320	ppb
51127	51127-1-HAL-F17	1st Floor Corridor Across Room 110, Fountain 3	Initial	08-JUN-16	0.382	ppb
51127	51127-1-HAL-F12	1st Floor Corridor by Room 102, Fountain 1	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-HAL-	1st Floor Corridor by Room 102,	Flush180	08-JUN-16	0.998	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F12	Fountain 1				
51127	51127-1-HAL-F12	1st Floor Corridor by Room 102, Fountain 1	Flush180	08-JUN-16	0.994	ppb
51127	51127-1-HAL-F12	1st Floor Corridor by Room 102, Fountain 1	Flush180	08-JUN-16	1.100	ppb
51127	51127-1-HAL-F12	1st Floor Corridor by Room 102, Fountain 1	Initial	08-JUN-16	1.070	ppb
51127	51127-1-HAL-F13	1st Floor Corridor by Room 102, Fountain 2	Flush180	08-JUN-16	0.843	ppb
51127	51127-1-HAL-F13	1st Floor Corridor by Room 102, Fountain 2	Flush180	08-JUN-16	0.667	ppb
51127	51127-1-HAL-F13	1st Floor Corridor by Room 102, Fountain 2	Flush180	08-JUN-16	0.615	ppb
51127	51127-1-HAL-F13	1st Floor Corridor by Room 102, Fountain 2	Flush180	08-JUN-16	0.750	ppb
51127	51127-1-HAL-F13	1st Floor Corridor by Room 102, Fountain 2	Initial	08-JUN-16	0.876	ppb
51127	51127-1-HAL-F14	1st Floor Corridor by Room 102, Fountain 3	Flush180	08-JUN-16	0.602	ppb
51127	51127-1-HAL-F14	1st Floor Corridor by Room 102, Fountain 3	Flush180	08-JUN-16	0.601	ppb
51127	51127-1-HAL-F14	1st Floor Corridor by Room 102, Fountain 3	Flush180	08-JUN-16	0.616	ppb
51127	51127-1-HAL-F14	1st Floor Corridor by Room 102, Fountain 3	Flush180	08-JUN-16	0.621	ppb
51127	51127-1-HAL-F14	1st Floor Corridor by Room 102, Fountain 3	Initial	08-JUN-16	0.485	ppb
51127	51127-1-110-F19	1st Floor Inside Room 110, Fountain	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-110-F19	1st Floor Inside Room 110, Fountain	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-110-F19	1st Floor Inside Room 110, Fountain	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-110-F19	1st Floor Inside Room 110, Fountain	Flush180	08-JUN-16	1.000	ppb
51127	51127-1-110-F19	1st Floor Inside Room 110, Fountain	Initial	08-JUN-16	0.136	ppb
51127	51127-1-110-S18	1st Floor Inside Room 110, Sink	Flush180	08-JUN-16	0.155	ppb
51127	51127-1-110-S18	1st Floor Inside Room 110, Sink	Flush180	08-JUN-16	0.304	ppb
51127	51127-1-110-S18	1st Floor Inside Room 110, Sink	Flush180	08-JUN-16	0.177	ppb
51127	51127-1-110-S18	1st Floor Inside Room 110, Sink	Flush180	08-JUN-16	0.238	ppb
51127	51127-1-110-S18	1st Floor Inside Room 110, Sink	Initial	08-JUN-16	0.625	ppb
51127	51127-1-N-HAL-F04	1st Floor, North End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-N-HAL-F04	1st Floor, North End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-N-HAL-F04	1st Floor, North End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-N-HAL-F04	1st Floor, North End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-N-HAL-F04	1st Floor, North End, Hallway	Initial	30-AUG-19	1.000	ug/L
51127	51127-1-E-HAL-F01	1st Floor, North Hallway Near Storage Closet, Left Fountain	Flush180	18-AUG-20	1.000	ug/L
51127	51127-1-E-HAL-F01	1st Floor, North Hallway Near Storage Closet, Left Fountain	Initial	18-AUG-20	1.000	ug/L
51127	51127-1-NW-HAL-F01	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F01	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F01	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F01	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F01	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F02	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F02	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F02	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-1-NW-HAL-F02	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F03	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F03	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F03	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F03	1st Floor, Northwest End, Hallway	Flush180	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F01	1st Floor, Northwest End, Hallway	Initial	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F02	1st Floor, Northwest End, Hallway	Initial	30-AUG-19	1.000	ug/L
51127	51127-1-NW-HAL-F03	1st Floor, Northwest End, Hallway	Initial	30-AUG-19	1.000	ug/L
51127	51127-2-HAL-F01	2nd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.472	ppb
51127	51127-2-HAL-F01	2nd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.421	ppb
51127	51127-2-HAL-F01	2nd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.635	ppb
51127	51127-2-HAL-F02	2nd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.207	ppb
51127	51127-2-HAL-F02	2nd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.000	ppb
51127	51127-2-HAL-F02	2nd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.122	ppb
51127	51127-2-HAL-F02	2nd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.389	ppb
51127	51127-2-HAL-F01	2nd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.808	ppb
51127	51127-2-HAL-F01	2nd Fl. Corridor Between North Boys & Girls Toilet	Initial	08-JUN-16	0.699	ppb
51127	51127-2-HAL-F02	2nd Fl. Corridor Between North Boys & Girls Toilet	Initial	08-JUN-16	0.404	ppb
51127	51127-2-HAL-F05	2nd Fl. Corridor Near Room 207, Fountain 1	Flush180	08-JUN-16	0.502	ppb
51127	51127-2-HAL-F05	2nd Fl. Corridor Near Room 207, Fountain 1	Flush180	08-JUN-16	0.504	ppb
51127	51127-2-HAL-F05	2nd Fl. Corridor Near Room 207, Fountain 1	Flush180	08-JUN-16	0.502	ppb
51127	51127-2-HAL-F05	2nd Fl. Corridor Near Room 207, Fountain 1	Flush180	08-JUN-16	0.565	ppb
51127	51127-2-HAL-F05	2nd Fl. Corridor Near Room 207, Fountain 1	Initial	08-JUN-16	0.371	ppb
51127	51127-2-HAL-F07	2nd Fl. Corridor Near Room 207, Fountain 2	Flush180	08-JUN-16	0.433	ppb
51127	51127-2-HAL-F07	2nd Fl. Corridor Near Room 207, Fountain 2	Flush180	08-JUN-16	0.397	ppb
51127	51127-2-HAL-F07	2nd Fl. Corridor Near Room 207, Fountain 2	Flush180	08-JUN-16	0.412	ppb
51127	51127-2-HAL-F07	2nd Fl. Corridor Near Room 207, Fountain 2	Flush180	08-JUN-16	0.459	ppb
51127	51127-2-HAL-F07	2nd Fl. Corridor Near Room 207, Fountain 2	Initial	08-JUN-16	0.254	ppb
51127	51127-2-HAL-F13	2nd Fl. Corridor Near Room 215, Fountain 1	Flush180	08-JUN-16	0.725	ppb
51127	51127-2-HAL-F13	2nd Fl. Corridor Near Room 215, Fountain 1	Flush180	08-JUN-16	0.718	ppb
51127	51127-2-HAL-F13	2nd Fl. Corridor Near Room 215, Fountain 1	Flush180	08-JUN-16	0.681	ppb
51127	51127-2-HAL-F13	2nd Fl. Corridor Near Room 215, Fountain 1	Flush180	08-JUN-16	0.716	ppb
51127	51127-2-HAL-F13	2nd Fl. Corridor Near Room 215, Fountain 1	Initial	08-JUN-16	1.010	ppb
51127	51127-2-HAL-F03	2nd Fl. Corridor Near Room 227, Fountain 1	Flush180	08-JUN-16	1.080	ppb
51127	51127-2-HAL-F03	2nd Fl. Corridor Near Room 227, Fountain 1	Flush180	08-JUN-16	0.926	ppb
51127	51127-2-HAL-F03	2nd Fl. Corridor Near Room 227, Fountain 1	Flush180	08-JUN-16	1.610	ppb
51127	51127-2-HAL-F03	2nd Fl. Corridor Near Room 227, Fountain 1	Flush180	08-JUN-16	1.320	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-2-HAL-F03	2nd Fl. Corridor Near Room 227, Fountain 1	Initial	08-JUN-16	1.240	ppb
51127	51127-2-HAL-F04	2nd Fl. Corridor Near Room 227, Fountain 2	Flush180	08-JUN-16	1.630	ppb
51127	51127-2-HAL-F04	2nd Fl. Corridor Near Room 227, Fountain 2	Flush180	08-JUN-16	1.380	ppb
51127	51127-2-HAL-F04	2nd Fl. Corridor Near Room 227, Fountain 2	Flush180	08-JUN-16	1.640	ppb
51127	51127-2-HAL-F04	2nd Fl. Corridor Near Room 227, Fountain 2	Flush180	08-JUN-16	0.968	ppb
51127	51127-2-HAL-F04	2nd Fl. Corridor Near Room 227, Fountain 2	Initial	08-JUN-16	2.520	ppb
51127	51127-2-HAL-F10	2nd Floor By Gym, Left Fountain	Flush180	18-AUG-20	1.000	ug/L
51127	51127-2-HAL-F10	2nd Floor By Gym, Left Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F10	2nd Floor By Gym, Left Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F10	2nd Floor By Gym, Left Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F10	2nd Floor By Gym, Left Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F10	2nd Floor By Gym, Left Fountain	Initial	18-AUG-20	1.000	ug/L
51127	51127-2-HAL-F10	2nd Floor By Gym, Left Fountain	Initial	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF04	2nd Floor by Gym, Left Bottle Filler	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF04	2nd Floor by Gym, Left Bottle Filler	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF04	2nd Floor by Gym, Left Bottle Filler	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF04	2nd Floor by Gym, Left Bottle Filler	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF04	2nd Floor by Gym, Left Bottle Filler	Initial	09-MAY-23	1.000	ug/L
51127	51127-3-HAL-F01	3rd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.650	ppb
51127	51127-3-HAL-F02	3rd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	4.000	ppb
51127	51127-3-HAL-F02	3rd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	4.720	ppb
51127	51127-3-HAL-F02	3rd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	2.840	ppb
51127	51127-3-HAL-F02	3rd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	7.370	ppb
51127	51127-3-HAL-F01	3rd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.550	ppb
51127	51127-3-HAL-F01	3rd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	0.404	ppb
51127	51127-3-HAL-F01	3rd Fl. Corridor Between North Boys & Girls Toilet	Flush180	08-JUN-16	1.070	ppb
51127	51127-3-HAL-F01	3rd Fl. Corridor Between North Boys & Girls Toilet	Initial	08-JUN-16	2.640	ppb
51127	51127-3-HAL-F02	3rd Fl. Corridor Between North Boys & Girls Toilet	Initial	08-JUN-16	3.280	ppb
51127	51127-3-HAL-F08	3rd Fl. Corridor Between South Boys & Girls Toilet	Flush180	08-JUN-16	5.120	ppb
51127	51127-3-HAL-F08	3rd Fl. Corridor Between South Boys & Girls Toilet	Flush180	08-JUN-16	4.780	ppb
51127	51127-3-HAL-F08	3rd Fl. Corridor Between South Boys & Girls Toilet	Flush180	08-JUN-16	3.050	ppb
51127	51127-3-HAL-F08	3rd Fl. Corridor Between South Boys & Girls Toilet	Flush180	08-JUN-16	4.360	ppb
51127	51127-3-HAL-F08	3rd Fl. Corridor Between South Boys & Girls Toilet	Initial	08-JUN-16	6.630	ppb
51127	51127-3-HAL-F05	3rd Fl. Corridor By Room 308, Fountain	Flush180	08-JUN-16	2.650	ppb
51127	51127-3-HAL-F05	3rd Fl. Corridor By Room 308, Fountain	Flush180	08-JUN-16	2.790	ppb
51127	51127-3-HAL-F05	3rd Fl. Corridor By Room 308, Fountain	Flush180	08-JUN-16	3.270	ppb
51127	51127-3-HAL-F05	3rd Fl. Corridor By Room 308, Fountain	Flush180	08-JUN-16	2.920	ppb
51127	51127-3-HAL-	3rd Fl. Corridor By Room 308,	Initial	08-JUN-16	2.100	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Fountain				
51127	51127-3-HAL-F09	3rd Fl. Corridor Near Room 315. Fountain	Flush180	08-JUN-16	1.880	ppb
51127	51127-3-HAL-F09	3rd Fl. Corridor Near Room 315. Fountain	Flush180	08-JUN-16	1.850	ppb
51127	51127-3-HAL-F09	3rd Fl. Corridor Near Room 315. Fountain	Flush180	08-JUN-16	2.200	ppb
51127	51127-3-HAL-F09	3rd Fl. Corridor Near Room 315. Fountain	Flush180	08-JUN-16	2.550	ppb
51127	51127-3-HAL-F09	3rd Fl. Corridor Near Room 315. Fountain	Initial	08-JUN-16	2.820	ppb
51127	51127-3-HAL-WC03	3rd Fl. Corridor Near Room 327. Fountain	Flush180	08-JUN-16	1.670	ppb
51127	51127-3-HAL-WC03	3rd Fl. Corridor Near Room 327. Fountain	Flush180	08-JUN-16	0.762	ppb
51127	51127-3-HAL-WC03	3rd Fl. Corridor Near Room 327. Fountain	Flush180	08-JUN-16	1.140	ppb
51127	51127-3-HAL-WC03	3rd Fl. Corridor Near Room 327. Fountain	Flush180	08-JUN-16	0.674	ppb
51127	51127-3-HAL-WC03	3rd Fl. Corridor Near Room 327. Fountain	Initial	08-JUN-16	0.423	ppb
51127	51127-1-HAL-F23	Across from Room 110	Flush180	03-JAN-23	6.700	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	03-JAN-23	5.420	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	03-JAN-23	5.180	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	03-JAN-23	5.650	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	03-JAN-23	8.550	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	03-JAN-23	5.370	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	03-JAN-23	3.270	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	03-JAN-23	3.910	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Flush180	03-JAN-23	3.120	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Flush180	03-JAN-23	2.550	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Flush180	03-JAN-23	2.360	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Flush180	03-JAN-23	2.350	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	09-MAY-23	1.070	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Flush180	09-MAY-23	1.320	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Flush180	09-MAY-23	1.560	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Flush180	09-MAY-23	1.570	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-	Across from Room 110	Flush180	12-APR-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F23					
51127	51127-1-HAL-F24	Across from Room 110	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Flush180	09-MAY-23	1.310	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Initial	03-JAN-23	2.120	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Initial	03-JAN-23	9.530	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Initial	03-JAN-23	2.870	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Initial	09-MAY-23	1.050	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-RBF01	Across from Room 110	Initial	09-MAY-23	1.360	ug/L
51127	51127-1-HAL-F23	Across from Room 110	Initial	12-APR-23	1.240	ug/L
51127	51127-1-HAL-F24	Across from Room 110	Initial	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F33	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F33	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F33	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F33	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF01	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF01	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF01	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF01	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F35	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F35	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F35	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F35	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F35	Across from Room 238	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F33	Across from Room 238	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF01	Across from Room 238	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F35	Across from Room 238	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Initial	03-JAN-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-2-HAL-F43	Between Janitor and Storage Rooms	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Flush180	03-JAN-23	1.300	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Flush180	03-JAN-23	1.450	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Flush180	03-JAN-23	1.580	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Flush180	03-JAN-23	1.650	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Flush180	09-MAY-23	2.990	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Flush180	09-MAY-23	3.570	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Flush180	09-MAY-23	1.540	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Flush180	09-MAY-23	1.810	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F31	Hallway near Computer Room	Initial	09-MAY-23	1.860	ug/L
51127	51127-1-HAL-F32	Hallway near Computer Room	Initial	09-MAY-23	2.970	ug/L
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Flush180	08-JUN-16	1.560	ppb
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Flush180	08-JUN-16	1.670	ppb
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Flush180	08-JUN-16	1.770	ppb
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Flush180	08-JUN-16	1.230	ppb
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Initial	08-JUN-16	1.140	ppb
51127	51127-1-KIT-KS09	Kitchen, (Center), Sink 2	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS10	Kitchen, (North wall), Sink 1	Flush180	08-JUN-16	0.644	ppb
51127	51127-1-KIT-KS10	Kitchen, (North wall), Sink 1	Flush180	08-JUN-16	0.555	ppb
51127	51127-1-KIT-KS10	Kitchen, (North wall), Sink 1	Flush180	08-JUN-16	2.270	ppb
51127	51127-1-KIT-KS10	Kitchen, (North wall), Sink 1	Flush180	08-JUN-16	0.687	ppb
51127	51127-1-KIT-KS10	Kitchen, (North wall), Sink 1	Initial	08-JUN-16	0.629	ppb
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Flush180	08-JUN-16	0.193	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Flush180	08-JUN-16	0.183	ppb
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Flush180	08-JUN-16	0.429	ppb
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Flush180	08-JUN-16	0.357	ppb
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Initial	08-JUN-16	0.626	ppb
51127	51127-1-KIT-KS11	Kitchen, (South wall), Sink 3	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-BF01	Near Room 128	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F29	Near Room 128	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F27	Near Room 128	Initial	09-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
51127	51127-1-HAL-F29	Near Room 128	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F26	Near Room 129	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F26	Near Room 129	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F26	Near Room 129	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F26	Near Room 129	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F26	Near Room 129	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F44	Near Room 228	Initial	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F45	Near Room 228	Initial	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-BF03	Near Room 228	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-	Next to Rm 102, Middle Fountain	Flush180	09-MAY-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F21					
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	03-JAN-23	15.700	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	03-JAN-23	18.600	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	03-JAN-23	19.900	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	03-JAN-23	16.000	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	12-APR-23	6.940	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	12-APR-23	2.160	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	12-APR-23	1.320	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Initial	03-JAN-23	12.100	ug/L
51127	51127-1-HAL-F21	Next to Rm 102, Middle Fountain	Initial	12-APR-23	5.220	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	03-JAN-23	9.420	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	03-JAN-23	4.600	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	03-JAN-23	6.760	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	03-JAN-23	5.350	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	12-APR-23	6.820	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	12-APR-23	3.270	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	12-APR-23	1.310	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Initial	03-JAN-23	6.180	ug/L
51127	51127-1-HAL-F22	Next to Rm 102, Right Fountain	Initial	12-APR-23	107.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	03-JAN-23	12.500	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	03-JAN-23	13.900	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	03-JAN-23	9.340	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	03-JAN-23	4.260	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	09-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Initial	03-JAN-23	4.890	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F20	Next to Room 102, Left Fountain	Initial	12-APR-23	1.020	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	03-JAN-23	9.100	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Flush180	03-JAN-23	4.500	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Flush180	03-JAN-23	3.670	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Flush180	03-JAN-23	3.150	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Flush180	03-JAN-23	2.540	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	03-JAN-23	9.070	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	03-JAN-23	10.300	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	03-JAN-23	11.300	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	03-JAN-23	19.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	03-JAN-23	15.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	03-JAN-23	9.290	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	03-JAN-23	5.780	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Flush180	09-MAY-23	2.810	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	12-APR-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-2-HAL-F37	Next to Room 202	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Initial	03-JAN-23	2.410	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Initial	03-JAN-23	1.600	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Initial	03-JAN-23	9.730	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Initial	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Initial	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-RBF01	Next to Room 202	Initial	09-MAY-23	3.070	ug/L
51127	51127-2-HAL-F38	Next to Room 202	Initial	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F37	Next to Room 202	Initial	12-APR-23	1.270	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	03-JAN-23	8.410	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	03-JAN-23	8.750	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	03-JAN-23	8.900	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	03-JAN-23	9.270	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	03-JAN-23	7.410	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	03-JAN-23	5.680	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	03-JAN-23	3.890	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	03-JAN-23	2.800	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Flush180	03-JAN-23	1.830	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Flush180	03-JAN-23	1.530	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Flush180	03-JAN-23	1.450	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Flush180	03-JAN-23	1.700	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Flush180	12-APR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F40					
51127	51127-2-HAL-F41	Next to Room 208	Flush180	12-APR-23	1.180	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	12-APR-23	1.240	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	12-APR-23	1.190	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Flush180	12-APR-23	1.110	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Initial	03-JAN-23	3.440	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Initial	03-JAN-23	5.850	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Initial	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F42	Next to Room 208	Initial	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Initial	09-MAY-23	2.130	ug/L
51127	51127-2-HAL-F40	Next to Room 208	Initial	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F41	Next to Room 208	Initial	12-APR-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Flush180	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Flush180	09-MAY-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Initial	03-JAN-23	1.000	ug/L
51127	51127-2-HAL-F36	Next to Room 214	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-HAL-F30	Next to Teachers Resource Room	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F30	Next to Teachers Resource Room	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F30	Next to Teachers Resource Room	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F30	Next to Teachers Resource Room	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-HAL-F30	Next to Teachers Resource Room	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-102-F01	Room 102	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-102-F01	Room 102	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-102-F01	Room 102	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-102-F01	Room 102	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-102-S01	Room 102	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-102-S01	Room 102	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-102-S01	Room 102	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-102-F01	Room 102	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-102-	Room 102	Flush180	03-JAN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51127	51127-1-102-F01	Room 102	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-102-F01	Room 102	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-102-S01	Room 102	Flush180	03-JAN-23	2.650	ug/L
51127	51127-1-102-S01	Room 102	Flush180	03-JAN-23	3.480	ug/L
51127	51127-1-102-S01	Room 102	Flush180	03-JAN-23	3.710	ug/L
51127	51127-1-102-S01	Room 102	Flush180	03-JAN-23	4.550	ug/L
51127	51127-1-102-F01	Room 102	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-102-S01	Room 102	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-102-F01	Room 102	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-102-S01	Room 102	Initial	03-JAN-23	2.020	ug/L
51127	51127-1-103-F02	Room 103	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-103-S03	Room 103	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-103-S03	Room 103	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-103-S03	Room 103	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-103-S03	Room 103	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-103-S03	Room 103	Flush180	03-JAN-23	2.350	ug/L
51127	51127-1-103-S03	Room 103	Flush180	03-JAN-23	2.380	ug/L
51127	51127-1-103-S03	Room 103	Flush180	03-JAN-23	2.560	ug/L
51127	51127-1-103-S03	Room 103	Flush180	03-JAN-23	3.080	ug/L
51127	51127-1-103-S03	Room 103	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Initial	09-MAY-23	1.000	ug/L
51127	51127-1-103-F02	Room 103	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-103-S03	Room 103	Initial	03-JAN-23	2.300	ug/L
51127	51127-1-110-F04	Room 110	Flush180	09-MAY-23	2.610	ug/L
51127	51127-1-110-F04	Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-110-F04	Room 110	Flush180	09-MAY-23	1.150	ug/L
51127	51127-1-110-F04	Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-110-S04	Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-110-S04	Room 110	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-110-S04	Room 110	Flush180	09-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-1-110-S04	Room 110	Flush180	09-MAY-23	2.510	ug/L
51127	51127-1-110-F04	Room 110	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-110-F04	Room 110	Flush180	03-JAN-23	1.220	ug/L
51127	51127-1-110-F04	Room 110	Flush180	03-JAN-23	1.370	ug/L
51127	51127-1-110-F04	Room 110	Flush180	03-JAN-23	1.200	ug/L
51127	51127-1-110-S04	Room 110	Flush180	03-JAN-23	2.650	ug/L
51127	51127-1-110-S04	Room 110	Flush180	03-JAN-23	3.010	ug/L
51127	51127-1-110-S04	Room 110	Flush180	03-JAN-23	4.200	ug/L
51127	51127-1-110-S04	Room 110	Flush180	03-JAN-23	3.920	ug/L
51127	51127-1-110-F04	Room 110	Initial	09-MAY-23	3.080	ug/L
51127	51127-1-110-S04	Room 110	Initial	09-MAY-23	4.220	ug/L
51127	51127-1-110-F04	Room 110	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-110-S04	Room 110	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	09-MAY-23	2.220	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	24-AUG-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	24-AUG-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	24-AUG-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	24-AUG-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Flush180	03-JAN-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Initial	09-MAY-23	5.900	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Initial	24-AUG-23	1.000	ug/L
51127	51127-1-111-F03	Room 111, Fountain	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	09-MAY-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	09-MAY-23	56.200	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	24-AUG-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	24-AUG-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	24-AUG-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	24-AUG-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	03-JAN-23	2.130	ug/L

**Water Quality Assessment
Brian Piccolo Elementary Specialty School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51127	51127-1-111-S04	Room 111, Sink	Flush180	03-JAN-23	1.700	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	03-JAN-23	11.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	03-JAN-23	2.930	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Flush180	12-APR-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Initial	09-MAY-23	1.040	ug/L
51127	51127-1-111-S04	Room 111, Sink	Initial	24-AUG-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Initial	03-JAN-23	1.000	ug/L
51127	51127-1-111-S04	Room 111, Sink	Initial	12-APR-23	1.000	ug/L