



Sep 10, 2024

PICKARD

2301 W 21ST PL, Chicago IL 60608.

Dear **PICKARD** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

PICKARD

2301 W 21ST PL, Chicago IL 60608.

Estimadas familias de **PICKARD**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-ADD-1-ART-F07	Addition - 1st Floor Art Room Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-ART-F07	Addition - 1st Floor Art Room Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-ART-F07	Addition - 1st Floor Art Room Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-ART-F07	Addition - 1st Floor Art Room Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-ART-F07	Addition - 1st Floor Art Room Fountain	Initial	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Flush180	01-SEP-20	1.000	ug/L
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Initial	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F04	Addition - 1st Floor Center Corridor, Left Fountain	Initial	01-SEP-20	1.000	ug/L
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-HAL-F05	Addition - 1st Floor Center Corridor, Right Fountain	Initial	10-JUN-16	1.000	ppb
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	02-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	02-FEB-23	1.370	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	02-FEB-23	1.980	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	02-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	21-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	21-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	21-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	21-FEB-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	12-JAN-23	1.610	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	12-JAN-23	1.240	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	12-JAN-23	1.490	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Flush180	12-JAN-23	1.030	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Initial	02-FEB-23	11.000	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Initial	21-FEB-23	1.500	ug/L
51248	51248-ADD-1-KIT-KS04	Addition - 1st Floor Kitchen Cooking Kettle	Initial	12-JAN-23	10.400	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Flush180	12-JAN-23	9.410	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Flush180	12-JAN-23	13.000	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Flush180	02-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Flush180	02-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Flush180	02-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Initial	02-FEB-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS05	Addition - 1st Floor Kitchen by ice machine	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Flush180	10-JUN-16	0.205	ppb
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Flush180	10-JUN-16	0.173	ppb
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Flush180	10-JUN-16	0.544	ppb
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Flush180	10-JUN-16	0.251	ppb
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS03	Addition - 1st Floor Kitchen by ovens	Initial	10-JUN-16	0.330	ppb
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Flush180	10-JUN-16	0.256	ppb
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Flush180	10-JUN-16	0.260	ppb
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Flush180	10-JUN-16	0.168	ppb
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Flush180	10-JUN-16	4.320	ppb
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Initial	12-JAN-23	2.800	ug/L
51248	51248-ADD-1-KIT-KS01	Addition - 1st Floor Kitchen, 2 basin, left sink	Initial	10-JUN-16	0.988	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-1-KIT-KS02	Addition - 1st Floor Kitchen, 2 basin, right sink	Initial	10-JUN-16	0.365	ppb
51248	51248-ADD-1-MULTI-F06	Addition - 1st Floor Small Multi-Purpose Room Foun	Flush180	10-JUN-16	0.647	ppb
51248	51248-ADD-1-MULTI-F06	Addition - 1st Floor Small Multi-Purpose Room Foun	Flush180	10-JUN-16	0.258	ppb
51248	51248-ADD-1-MULTI-F06	Addition - 1st Floor Small Multi-Purpose Room Foun	Flush180	10-JUN-16	0.508	ppb
51248	51248-ADD-1-MULTI-F06	Addition - 1st Floor Small Multi-Purpose Room Foun	Flush180	10-JUN-16	0.605	ppb
51248	51248-ADD-1-MULTI-F06	Addition - 1st Floor Small Multi-Purpose Room Foun	Initial	10-JUN-16	0.267	ppb
51248	51248-1-TL-HAL-S01	Addition - 1st Floor Teachers Lounge Sink (behind Nurse Office)	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-TL-HAL-S01	Addition - 1st Floor Teachers Lounge Sink (behind Nurse Office)	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-TL-HAL-S01	Addition - 1st Floor Teachers Lounge Sink (behind Nurse Office)	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-TL-HAL-S01	Addition - 1st Floor Teachers Lounge Sink (behind Nurse Office)	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-TL-HAL-S01	Addition - 1st Floor Teachers Lounge Sink (behind Nurse Office)	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F01	Addition - 2nd Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F01	Addition - 2nd Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F01	Addition - 2nd Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F01	Addition - 2nd Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-2-HAL-F01	Addition - 2nd Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-2-HAL-F01	Addition - 2nd Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-2-HAL-F01	Addition - 2nd Floor Center Corridor, Left Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F01	Addition - 2nd Floor Center Corridor, Left Fountain	Initial	10-JUN-16	1.000	ppb
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Corridor, Right Fountain				
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-2-HAL-F02	Addition - 2nd Floor Center Corridor, Right Fountain	Initial	10-JUN-16	1.000	ppb
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Flush180	01-SEP-20	1.000	ug/L
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Initial	10-JUN-16	1.000	ppb
51248	51248-ADD-3-HAL-F01	Addition - 3rd Floor Center Corridor, Left Fountain	Initial	01-SEP-20	1.000	ug/L
51248	51248-ADD-3-HAL-F02	Addition - 3rd Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-3-HAL-F02	Addition - 3rd Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-3-HAL-F02	Addition - 3rd Floor Center Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-ADD-3-HAL-F02	Addition - 3rd Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-3-HAL-F02	Addition - 3rd Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-3-HAL-F02	Addition - 3rd Floor Center Corridor, Right Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-ADD-3-HAL-F02	Addition - 3rd Floor Center Corridor, Right Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-ADD-3-HAL-F02	Addition - 3rd Floor Center Corridor, Right Fountain	Initial	10-JUN-16	1.000	ppb
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	02-FEB-23	35.000	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	02-FEB-23	39.000	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	02-FEB-23	22.700	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	02-FEB-23	16.500	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	10-JUN-16	0.852	ppb
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	10-JUN-16	1.010	ppb
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	10-JUN-16	0.748	ppb
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	10-JUN-16	0.725	ppb
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	01-SEP-20	1.470	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	21-FEB-23	2.570	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	21-FEB-23	9.280	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Flush180	21-FEB-23	12.500	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals	Flush180	21-FEB-23	7.900	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Office Founta				
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Initial	02-FEB-23	110.00 0	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Initial	10-JUN-16	1.490	ppb
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Initial	01-SEP-20	1.000	ug/L
51248	51248-1-OFF-F03	Main - 1st Floor Assitant Principals Office Founta	Initial	21-FEB-23	4.170	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	02-FEB-23	12.600	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	02-FEB-23	16.000	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	02-FEB-23	12.600	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	02-FEB-23	12.700	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	21-FEB-23	2.500	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	21-FEB-23	2.140	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	21-FEB-23	2.120	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	21-FEB-23	1.910	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	12-JAN-23	4.940	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	12-JAN-23	2.590	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	12-JAN-23	2.250	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	12-JAN-23	1.730	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	10-JUN-16	0.640	ppb
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	10-JUN-16	0.543	ppb
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	10-JUN-16	0.832	ppb
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Flush180	10-JUN-16	0.662	ppb
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Initial	02-FEB-23	14.800	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Initial	21-FEB-23	1.800	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Initial	12-JAN-23	5.110	ug/L
51248	51248-1-HAL-F02	Main - 1st Floor East Corridor, Left Fountain	Initial	10-JUN-16	1.040	ppb
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Flush180	12-JAN-23	2.000	ug/L
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Flush180	12-JAN-23	1.830	ug/L
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Flush180	12-JAN-23	1.620	ug/L
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Flush180	12-JAN-23	1.280	ug/L
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.652	ppb
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.554	ppb
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.593	ppb
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.650	ppb
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Initial	12-JAN-23	4.230	ug/L
51248	51248-1-HAL-F01	Main - 1st Floor East Corridor, Right Fountain	Initial	10-JUN-16	1.470	ppb
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Flush180	09-AUG-23	1.000	ug/L
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Flush180	09-AUG-23	1.000	ug/L
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Flush180	09-AUG-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Flush180	09-AUG-23	1.000	ug/L
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Flush180	18-JUL-23	1.000	ug/L
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Flush180	18-JUL-23	1.000	ug/L
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Flush180	18-JUL-23	1.120	ug/L
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Flush180	18-JUL-23	1.000	ug/L
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Initial	18-JUL-23	9.110	ug/L
51248	51248-1-OFF-F02	Main - 1st Floor Principals Office Fountain	Initial	09-AUG-23	1.000	ug/L
51248	51248-1-OFF-S01	Main - 1st Floor Principals Office Sink	Flush180	02-FEB-23	1.000	ug/L
51248	51248-1-OFF-S01	Main - 1st Floor Principals Office Sink	Flush180	02-FEB-23	1.170	ug/L
51248	51248-1-OFF-S01	Main - 1st Floor Principals Office Sink	Flush180	02-FEB-23	1.000	ug/L
51248	51248-1-OFF-S01	Main - 1st Floor Principals Office Sink	Flush180	02-FEB-23	1.000	ug/L
51248	51248-1-OFF-S01	Main - 1st Floor Principals Office Sink	Initial	02-FEB-23	1.620	ug/L
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Flush180	10-JUN-16	0.687	ppb
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Flush180	10-JUN-16	0.553	ppb
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Flush180	10-JUN-16	1.390	ppb
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Flush180	10-JUN-16	7.090	ppb
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Initial	12-JAN-23	1.130	ug/L
51248	51248-1-HAL-F04	Main - 1st Floor West Corridor, Left Fountain	Initial	10-JUN-16	1.160	ppb
51248	51248-1-HAL-F05	Main - 1st Floor West Corridor, Right Fountain	Flush180	10-JUN-16	0.365	ppb
51248	51248-1-HAL-F05	Main - 1st Floor West Corridor, Right Fountain	Flush180	10-JUN-16	0.358	ppb
51248	51248-1-HAL-F05	Main - 1st Floor West Corridor, Right Fountain	Flush180	10-JUN-16	0.477	ppb
51248	51248-1-HAL-F05	Main - 1st Floor West Corridor, Right Fountain	Flush180	10-JUN-16	0.328	ppb
51248	51248-1-HAL-F05	Main - 1st Floor West Corridor, Right Fountain	Initial	10-JUN-16	0.896	ppb
51248	51248-2-202A-S01	Main - 202A Teachers Lounge Sink	Flush180	12-JAN-23	2.300	ug/L
51248	51248-2-202A-S01	Main - 202A Teachers Lounge Sink	Flush180	12-JAN-23	2.490	ug/L
51248	51248-2-202A-S01	Main - 202A Teachers Lounge Sink	Flush180	12-JAN-23	2.700	ug/L
51248	51248-2-202A-S01	Main - 202A Teachers Lounge Sink	Flush180	12-JAN-23	2.280	ug/L
51248	51248-2-202A-S01	Main - 202A Teachers Lounge Sink	Initial	12-JAN-23	2.440	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	02-FEB-23	4.480	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	02-FEB-23	5.060	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	02-FEB-23	3.980	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	02-FEB-23	5.440	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	12-JAN-23	9.970	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	12-JAN-23	14.500	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	12-JAN-23	10.800	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	12-JAN-23	9.880	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	21-FEB-23	3.680	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	21-FEB-23	2.880	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	21-FEB-23	2.240	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	21-FEB-23	1.830	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.270	ppb
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.326	ppb
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.291	ppb
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.292	ppb
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Initial	02-FEB-23	29.000	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Initial	12-JAN-23	9.860	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Initial	21-FEB-23	3.970	ug/L
51248	51248-2-HAL-F01	Main - 2nd Floor East Corridor, Right Fountain	Initial	10-JUN-16	0.576	ppb
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	02-FEB-23	65.600	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	02-FEB-23	51.700	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	02-FEB-23	37.400	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	02-FEB-23	45.900	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	12-JAN-23	29.000	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	12-JAN-23	6.990	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	12-JAN-23	3.500	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	12-JAN-23	2.710	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	21-FEB-23	2.580	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	21-FEB-23	2.590	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	21-FEB-23	2.500	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Flush180	21-FEB-23	2.490	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Initial	02-FEB-23	100.000	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Initial	12-JAN-23	9.840	ug/L
51248	51248-2-HAL-RBF01	Main - 2nd Floor Next to Room 202, Left Retrofit BF	Initial	21-FEB-23	2.050	ug/L
51248	51248-2-HAL-F02	Main - 2nd Floor Next to Room 202, South Fountain	Flush180	31-AUG-16	2.000	ppb
51248	51248-2-HAL-F02	Main - 2nd Floor Next to Room 202, South Fountain	Flush180	31-AUG-16	1.000	ppb
51248	51248-2-HAL-F02	Main - 2nd Floor Next to Room 202, South Fountain	Flush180	31-AUG-16	1.000	ppb
51248	51248-2-HAL-F02	Main - 2nd Floor Next to Room 202, South Fountain	Flush180	31-AUG-16	1.000	ppb
51248	51248-2-HAL-F02	Main - 2nd Floor Next to Room 202, South Fountain	Initial	31-AUG-16	1.000	ppb
51248	51248-2-HAL-RBF02	Main - 2nd Floor West Corridor, Left Retrofit BF	Flush180	12-JAN-23	1.010	ug/L
51248	51248-2-HAL-RBF02	Main - 2nd Floor West Corridor, Left Retrofit BF	Flush180	12-JAN-23	1.000	ug/L
51248	51248-2-HAL-RBF02	Main - 2nd Floor West Corridor, Left Retrofit BF	Flush180	12-JAN-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF02	Left Retrofit BF				
51248	51248-2-HAL-RBF02	Main - 2nd Floor West Corridor, Left Retrofit BF	Flush180	12-JAN-23	1.000	ug/L
51248	51248-2-HAL-RBF02	Main - 2nd Floor West Corridor, Left Retrofit BF	Initial	12-JAN-23	1.000	ug/L
51248	51248-2-HAL-F03	Main - 2nd Floor West Corridor, North Fountain 1	Flush180	10-JUN-16	3.040	ppb
51248	51248-2-HAL-F03	Main - 2nd Floor West Corridor, North Fountain 1	Flush180	10-JUN-16	9.000	ppb
51248	51248-2-HAL-F03	Main - 2nd Floor West Corridor, North Fountain 1	Flush180	10-JUN-16	2.540	ppb
51248	51248-2-HAL-F03	Main - 2nd Floor West Corridor, North Fountain 1	Flush180	10-JUN-16	2.100	ppb
51248	51248-2-HAL-F03	Main - 2nd Floor West Corridor, North Fountain 1	Initial	10-JUN-16	2.000	ppb
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Flush180	10-JUN-16	0.960	ppb
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Flush180	10-JUN-16	1.090	ppb
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Flush180	10-JUN-16	1.250	ppb
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Flush180	10-JUN-16	1.590	ppb
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Initial	12-JAN-23	1.440	ug/L
51248	51248-2-HAL-F04	Main - 2nd Floor West Corridor, Right Fountain	Initial	10-JUN-16	1.980	ppb
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	02-FEB-23	1.350	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	02-FEB-23	1.390	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	02-FEB-23	1.000	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	02-FEB-23	1.000	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	12-JAN-23	9.540	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	12-JAN-23	11.200	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	12-JAN-23	11.700	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	12-JAN-23	10.200	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	10-JUN-16	0.767	ppb
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	10-JUN-16	0.699	ppb
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	10-JUN-16	0.946	ppb
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Flush180	10-JUN-16	0.861	ppb
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Initial	02-FEB-23	1.690	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Initial	12-JAN-23	2.430	ug/L
51248	51248-3-HAL-F02	Main - 3rd Floor East Corridor, Left Fountain	Initial	10-JUN-16	2.480	ppb
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	02-FEB-23	8.280	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	02-FEB-23	8.830	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	02-FEB-23	3.760	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	02-FEB-23	4.850	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	12-JAN-23	7.040	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Right Fountain				
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	12-JAN-23	4.710	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	12-JAN-23	3.970	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	12-JAN-23	3.310	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.807	ppb
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.883	ppb
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.809	ppb
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	10-JUN-16	0.917	ppb
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	21-FEB-23	3.250	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	21-FEB-23	5.240	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	21-FEB-23	6.930	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Flush180	21-FEB-23	4.950	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Initial	02-FEB-23	45.000	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Initial	12-JAN-23	6.770	ug/L
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Initial	10-JUN-16	0.716	ppb
51248	51248-3-HAL-F01	Main - 3rd Floor East Corridor, Right Fountain	Initial	21-FEB-23	2.820	ug/L
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Flush180	12-JAN-23	1.440	ug/L
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Flush180	12-JAN-23	1.740	ug/L
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Flush180	12-JAN-23	1.740	ug/L
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Flush180	12-JAN-23	1.410	ug/L
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Flush180	10-JUN-16	1.370	ppb
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Flush180	10-JUN-16	1.560	ppb
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Flush180	10-JUN-16	1.770	ppb
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Flush180	10-JUN-16	1.450	ppb
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Initial	12-JAN-23	1.210	ug/L
51248	51248-3-HAL-F03	Main - 3rd Floor West Corridor, Left Fountain	Initial	10-JUN-16	2.130	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	26-AUG-16	2.100	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	26-AUG-16	2.200	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	26-AUG-16	2.400	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	10-JUN-16	4.700	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	10-JUN-16	15.100	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	10-JUN-16	10.100	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	10-JUN-16	16.900	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Flush180	26-AUG-16	2.800	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Initial	26-AUG-16	2.500	ppb
51248	51248-3-HAL-F04	Main - 3rd Floor West Corridor, Right Fountain	Initial	10-JUN-16	1.960	ppb
51248	51248-B-401-S04	Main - Basement Room 401, Sink	Flush180	10-JUN-16	0.544	ppb
51248	51248-B-401-S04	Main - Basement Room 401, Sink	Flush180	10-JUN-16	0.808	ppb
51248	51248-B-401-S04	Main - Basement Room 401, Sink	Flush180	10-JUN-16	0.868	ppb
51248	51248-B-401-S04	Main - Basement Room 401, Sink	Flush180	10-JUN-16	0.546	ppb
51248	51248-B-401-S04	Main - Basement Room 401, Sink	Initial	10-JUN-16	0.673	ppb
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Initial	21-SEP-22	1.000	ug/L
51248	51248-B-404A-BF01	Main - Basement Room 404A, Bottle Filler	Initial	12-JAN-23	1.000	ug/L
51248	51248-B-404A-F05	Main - Basement Room 404A, Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-B-404A-F05	Main - Basement Room 404A, Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-B-404A-F05	Main - Basement Room 404A, Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-B-404A-F05	Main - Basement Room 404A, Fountain	Flush180	10-JUN-16	1.000	ppb
51248	51248-B-404A-F05	Main - Basement Room 404A, Fountain	Initial	10-JUN-16	0.144	ppb
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Initial	21-SEP-22	1.000	ug/L
51248	51248-B-404A-F01	Main - Basement Room 404A, Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Flush180	21-SEP-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Initial	21-SEP-22	1.000	ug/L
51248	51248-B-404A-S01	Main - Basement Room 404A, Left Sink	Initial	12-JAN-23	1.020	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Initial	21-SEP-22	3.110	ug/L
51248	51248-B-404A-S02	Main - Basement Room 404A, Right Sink	Initial	12-JAN-23	1.100	ug/L
51248	51248-B-404A-S06	Main - Basement Room 404A, Sink	Flush180	10-JUN-16	0.252	ppb
51248	51248-B-404A-S06	Main - Basement Room 404A, Sink	Flush180	10-JUN-16	0.196	ppb
51248	51248-B-404A-S06	Main - Basement Room 404A, Sink	Flush180	10-JUN-16	1.320	ppb
51248	51248-B-404A-S06	Main - Basement Room 404A, Sink	Flush180	10-JUN-16	0.255	ppb
51248	51248-B-404A-S07	Main - Basement Room 404A, Sink	Flush180	10-JUN-16	0.121	ppb
51248	51248-B-404A-S07	Main - Basement Room 404A, Sink	Flush180	10-JUN-16	0.192	ppb
51248	51248-B-404A-S07	Main - Basement Room 404A, Sink	Flush180	10-JUN-16	0.148	ppb
51248	51248-B-404A-S07	Main - Basement Room 404A, Sink	Flush180	10-JUN-16	0.186	ppb
51248	51248-B-404A-S06	Main - Basement Room 404A, Sink	Initial	10-JUN-16	0.331	ppb
51248	51248-B-404A-S07	Main - Basement Room 404A, Sink	Initial	10-JUN-16	0.180	ppb
51248	51248-B-409A-S03	Main - Basement Room 409A Sink 2	Flush180	10-JUN-16	0.178	ppb
51248	51248-B-409A-S03	Main - Basement Room 409A Sink 2	Flush180	10-JUN-16	0.281	ppb
51248	51248-B-409A-S03	Main - Basement Room 409A Sink 2	Flush180	10-JUN-16	0.493	ppb
51248	51248-B-409A-S03	Main - Basement Room 409A Sink 2	Flush180	10-JUN-16	0.469	ppb
51248	51248-B-409A-S03	Main - Basement Room 409A Sink 2	Initial	10-JUN-16	0.288	ppb
51248	51248-B-409A-F01	Main - Basement Room 409A, Fountain	Flush180	10-JUN-16	0.336	ppb
51248	51248-B-409A-F01	Main - Basement Room 409A, Fountain	Flush180	10-JUN-16	0.413	ppb
51248	51248-B-409A-F01	Main - Basement Room 409A, Fountain	Flush180	10-JUN-16	0.375	ppb
51248	51248-B-409A-F01	Main - Basement Room 409A, Fountain	Flush180	10-JUN-16	0.380	ppb
51248	51248-B-409A-F01	Main - Basement Room 409A, Fountain	Initial	10-JUN-16	1.130	ppb
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Flush180	12-JAN-23	1.420	ug/L
51248	51248-B-	Main - Basement Room 409A,	Flush180	12-JAN-23	1.570	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	409A-S02	Sink 1				
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Flush180	12-JAN-23	2.260	ug/L
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Flush180	12-JAN-23	1.510	ug/L
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Flush180	10-JUN-16	0.559	ppb
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Flush180	10-JUN-16	0.563	ppb
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Flush180	10-JUN-16	0.660	ppb
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Flush180	10-JUN-16	0.583	ppb
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Initial	12-JAN-23	1.310	ug/L
51248	51248-B-409A-S02	Main - Basement Room 409A, Sink 1	Initial	10-JUN-16	0.231	ppb
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Initial	21-SEP-22	1.000	ug/L
51248	51248-1-112-S01	Main - Inside Room 112 , Left Sink	Initial	12-JAN-23	1.000	ug/L
51248	51248-1-112-S10	Main - Inside Room 112 North, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-112-S10	Main - Inside Room 112 North, Sink	Flush180	31-AUG-16	3.500	ppb
51248	51248-1-112-S10	Main - Inside Room 112 North, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-112-S10	Main - Inside Room 112 North, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-112-S10	Main - Inside Room 112 North, Sink	Initial	31-AUG-16	6.100	ppb
51248	51248-1-112-S09	Main - Inside Room 112 South, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-112-S09	Main - Inside Room 112 South, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-112-S09	Main - Inside Room 112 South, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-112-S09	Main - Inside Room 112 South, Sink	Initial	31-AUG-16	3.500	ppb
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	03-NOV-22	1.000	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	03-NOV-22	1.000	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	03-NOV-22	1.000	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	21-SEP-22	13.700	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	21-SEP-22	18.500	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	21-SEP-22	12.500	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	21-SEP-22	12.400	ug/L
51248	51248-1-112-	Main - Inside Room 112, Bottle	Flush180	12-JAN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01	Filler				
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Flush180	12-JAN-23	1.310	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Initial	03-NOV-22	1.000	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Initial	21-SEP-22	8.560	ug/L
51248	51248-1-112-BF01	Main - Inside Room 112, Bottle Filler	Initial	12-JAN-23	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Initial	21-SEP-22	1.000	ug/L
51248	51248-1-112-F01	Main - Inside Room 112, Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	03-NOV-22	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	03-NOV-22	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	03-NOV-22	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	03-NOV-22	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	21-SEP-22	1.390	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Initial	03-NOV-22	1.800	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Initial	21-SEP-22	7.010	ug/L
51248	51248-1-112-S02	Main - Inside Room 112, Right Sink	Initial	12-JAN-23	1.310	ug/L
51248	51248-1-114-S12	Main - Inside Room 114 North, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-114-S12	Main - Inside Room 114 North, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-114-S12	Main - Inside Room 114 North, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-114-S12	Main - Inside Room 114 North, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-114-S12	Main - Inside Room 114 North, Sink	Initial	31-AUG-16	4.900	ppb
51248	51248-1-114-S11	Main - Inside Room 114 South, Sink	Flush180	31-AUG-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-1-114-S11	Main - Inside Room 114 South, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-114-S11	Main - Inside Room 114 South, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-114-S11	Main - Inside Room 114 South, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-114-S11	Main - Inside Room 114 South, Sink	Initial	31-AUG-16	13.000	ppb
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Flush180	21-SEP-22	1.040	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Initial	12-JAN-23	1.000	ug/L
51248	51248-1-114-BF01	Main - Inside Room 114, Bottle Filler	Initial	21-SEP-22	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Initial	12-JAN-23	1.000	ug/L
51248	51248-1-114-F01	Main - Inside Room 114, Fountain	Initial	21-SEP-22	1.000	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Flush180	12-JAN-23	1.750	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Initial	12-JAN-23	1.000	ug/L
51248	51248-1-114-S01	Main - Inside Room 114, Left Sink	Initial	21-SEP-22	1.000	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Flush180	12-JAN-23	1.300	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Flush180	12-JAN-23	2.730	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Flush180	12-JAN-23	1.000	ug/L

Water Quality Assessment Josiah Pickard Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Flush180	12-JAN-23	1.000	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Flush180	21-SEP-22	1.000	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Initial	12-JAN-23	3.590	ug/L
51248	51248-1-114-S02	Main - Inside Room 114, Right Sink	Initial	21-SEP-22	2.920	ug/L
51248	51248-1-KIT-KS08	Main - Kitchen Preperation, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-KIT-KS08	Main - Kitchen Preperation, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-KIT-KS08	Main - Kitchen Preperation, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-KIT-KS08	Main - Kitchen Preperation, Sink	Flush180	31-AUG-16	1.000	ppb
51248	51248-1-KIT-KS08	Main - Kitchen Preperation, Sink	Initial	31-AUG-16	1.000	ppb
51248	51248-3-HAL-F05	Main- 3rd Floor, East Corridor Right Fountain	Flush180	18-JUL-23	2.230	ug/L
51248	51248-3-HAL-F05	Main- 3rd Floor, East Corridor Right Fountain	Flush180	18-JUL-23	2.190	ug/L
51248	51248-3-HAL-F05	Main- 3rd Floor, East Corridor Right Fountain	Flush180	18-JUL-23	1.960	ug/L
51248	51248-3-HAL-F05	Main- 3rd Floor, East Corridor Right Fountain	Flush180	18-JUL-23	1.860	ug/L
51248	51248-3-HAL-F05	Main- 3rd Floor, East Corridor Right Fountain	Initial	18-JUL-23	2.930	ug/L