



Sep 10, 2024

PIRIE

650 E 85TH ST, Chicago IL 60619.

Dear **PIRIE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

PIRIE

650 E 85TH ST, Chicago IL 60619.

Estimadas familias de **PIRIE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Flush180	08-MAR-22	1.610	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Flush180	08-MAR-22	1.370	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Flush180	08-MAR-22	1.390	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Flush180	08-MAR-22	1.270	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Flush180	16-NOV-21	14.200	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Flush180	16-NOV-21	8.660	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Flush180	16-NOV-21	5.620	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Flush180	16-NOV-21	12.900	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Initial	08-MAR-22	2.170	ug/L
51477	51477-1-HAL-F10	Hallway between Girls & Boys Bathroom	Initial	16-NOV-21	3.340	ug/L
51477	51477-1-KIT-KS04	Main Lunchroom	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS04	Main Lunchroom	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS04	Main Lunchroom	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS04	Main Lunchroom	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS04	Main Lunchroom	Initial	16-NOV-21	1.350	ug/L
51477	51477-1-HAL-RBF01	Main, Across From Room 102 Hallway (Left),Retrofit BF	Flush180	16-NOV-21	3.080	ug/L
51477	51477-1-HAL-RBF01	Main, Across From Room 102 Hallway (Left),Retrofit BF	Flush180	16-NOV-21	1.500	ug/L
51477	51477-1-HAL-RBF01	Main, Across From Room 102 Hallway (Left),Retrofit BF	Flush180	16-NOV-21	1.600	ug/L
51477	51477-1-HAL-RBF01	Main, Across From Room 102 Hallway (Left),Retrofit BF	Flush180	16-NOV-21	2.930	ug/L
51477	51477-1-HAL-RBF01	Main, Across From Room 102 Hallway (Left),Retrofit BF	Initial	16-NOV-21	1.340	ug/L
51477	51477-1-HAL-F09	Main, Across From Room 102 Hallway (West), Fountain	Flush180	16-JUN-16	0.963	ppb
51477	51477-1-HAL-F09	Main, Across From Room 102 Hallway (West), Fountain	Flush180	16-JUN-16	0.764	ppb
51477	51477-1-HAL-F09	Main, Across From Room 102 Hallway (West), Fountain	Flush180	16-JUN-16	0.860	ppb
51477	51477-1-HAL-F09	Main, Across From Room 102 Hallway (West), Fountain	Flush180	16-JUN-16	1.470	ppb
51477	51477-1-HAL-F09	Main, Across From Room 102 Hallway (West), Fountain	Initial	16-JUN-16	1.670	ppb
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	16-JUN-16	0.794	ppb
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	16-JUN-16	0.717	ppb
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	16-JUN-16	0.736	ppb
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	16-JUN-16	0.649	ppb
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	17-JUL-20	5.400	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	29-OCT-20	1.230	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	29-OCT-20	1.120	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	29-OCT-20	1.140	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	29-OCT-20	1.030	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	08-MAR-22	4.210	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	08-MAR-22	4.380	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	08-MAR-22	4.080	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	08-MAR-22	2.750	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	16-NOV-21	2.850	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	16-NOV-21	2.860	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	16-NOV-21	4.840	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Flush180	16-NOV-21	4.440	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Initial	16-JUN-16	1.140	ppb
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Initial	17-JUL-20	8.740	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Initial	29-OCT-20	1.840	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Initial	08-MAR-22	4.790	ug/L
51477	51477-1-HAL-F08	Main, Across From Room 102 Hallway Right), Fountain	Initial	16-NOV-21	9.760	ug/L
51477	51477-1-HAL-F05	Main, Across From Room 115 Hallway (East), Fountai	Flush180	16-JUN-16	0.613	ppb
51477	51477-1-HAL-F05	Main, Across From Room 115 Hallway (East), Fountai	Flush180	16-JUN-16	0.599	ppb
51477	51477-1-HAL-F05	Main, Across From Room 115 Hallway (East), Fountai	Flush180	16-JUN-16	0.543	ppb
51477	51477-1-HAL-F05	Main, Across From Room 115 Hallway (East), Fountai	Flush180	16-JUN-16	1.210	ppb
51477	51477-1-HAL-F05	Main, Across From Room 115 Hallway (East), Fountai	Initial	16-JUN-16	2.170	ppb
51477	51477-1-HAL-F04	Main, Across From Room 115 Hallway (West), Fountai	Flush180	16-JUN-16	1.450	ppb
51477	51477-1-HAL-F04	Main, Across From Room 115 Hallway (West), Fountai	Flush180	16-JUN-16	1.860	ppb
51477	51477-1-HAL-F04	Main, Across From Room 115 Hallway (West), Fountai	Flush180	16-JUN-16	2.270	ppb
51477	51477-1-HAL-F04	Main, Across From Room 115 Hallway (West), Fountai	Flush180	16-JUN-16	0.886	ppb
51477	51477-1-HAL-F04	Main, Across From Room 115 Hallway (West), Fountai	Initial	16-JUN-16	1.660	ppb
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	12-AUG-16	4.600	ppb
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	12-AUG-16	5.100	ppb
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	12-AUG-16	5.600	ppb
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	12-AUG-16	4.500	ppb
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	08-MAR-22	38.300	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	08-MAR-22	41.000	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	08-MAR-22	3.680	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	08-MAR-22	2.530	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	16-NOV-21	12.100	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	16-NOV-21	4.880	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	16-NOV-21	5.100	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	16-NOV-21	4.910	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	09-SEP-22	2.790	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	09-SEP-22	1.210	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	09-SEP-22	1.540	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Flush180	09-SEP-22	2.730	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Initial	12-AUG-16	4.500	ppb
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Initial	08-MAR-22	19.900	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Initial	16-NOV-21	149.000	ug/L
51477	51477-1-108-S11	Main, Inside Room 108, Sink	Initial	09-SEP-22	4.700	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	12-AUG-16	3.200	ppb
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	12-AUG-16	4.500	ppb
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	08-MAR-22	20.400	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	08-MAR-22	3.530	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	08-MAR-22	13.800	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	08-MAR-22	8.100	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	16-NOV-21	4.820	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	16-NOV-21	4.580	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	16-NOV-21	4.610	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	16-NOV-21	4.940	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	09-SEP-22	7.790	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	09-SEP-22	7.280	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	09-SEP-22	2.810	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Flush180	09-SEP-22	25.800	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Initial	12-AUG-16	6.200	ppb
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Initial	08-MAR-22	15.600	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Initial	16-NOV-21	8.150	ug/L
51477	51477-1-109-S12	Main, Inside Room 109, Sink	Initial	09-SEP-22	110.000	ug/L
51477	51477-1-110-S13	Main, Inside Room 110, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-110-S13	Main, Inside Room 110, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-110-S13	Main, Inside Room 110, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-110-S13	Main, Inside Room 110, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-110-S13	Main, Inside Room 110, Sink	Initial	12-AUG-16	1.000	ppb
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	08-MAR-22	2.500	ug/L
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	08-MAR-22	1.200	ug/L
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	08-MAR-22	1.770	ug/L
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	08-MAR-22	2.320	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S14					
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	16-NOV-21	27.200	ug/L
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	16-NOV-21	8.120	ug/L
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	16-NOV-21	6.380	ug/L
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Flush180	16-NOV-21	7.020	ug/L
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Initial	12-AUG-16	1.000	ppb
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Initial	08-MAR-22	3.130	ug/L
51477	51477-1-112-S14	Main, Inside Room 112, Sink	Initial	16-NOV-21	52.900	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	12-AUG-16	2.100	ppb
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	12-AUG-16	2.700	ppb
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	08-MAR-22	4.840	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	08-MAR-22	1.890	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	08-MAR-22	3.120	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	08-MAR-22	2.050	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	16-NOV-21	9.250	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	16-NOV-21	5.580	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	16-NOV-21	5.070	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	16-NOV-21	3.930	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	09-SEP-22	78.000	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	09-SEP-22	9.900	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	09-SEP-22	10.700	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Flush180	09-SEP-22	7.590	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Initial	12-AUG-16	2.700	ppb
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Initial	08-MAR-22	30.100	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Initial	16-NOV-21	11.000	ug/L
51477	51477-1-113-S15	Main, Inside Room 113, Sink	Initial	09-SEP-22	156.000	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	12-AUG-16	3.700	ppb
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	12-AUG-16	2.700	ppb
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	12-AUG-16	2.700	ppb
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	12-AUG-16	3.500	ppb
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	08-MAR-22	2.240	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	08-MAR-22	1.020	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	08-MAR-22	1.590	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	08-MAR-22	1.000	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	16-NOV-21	33.000	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	16-NOV-21	32.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S16					
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	16-NOV-21	57.000	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	16-NOV-21	36.000	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	09-SEP-22	2.790	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	09-SEP-22	1.510	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	09-SEP-22	1.110	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Flush180	09-SEP-22	1.000	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Initial	12-AUG-16	4.400	ppb
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Initial	08-MAR-22	6.770	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Initial	16-NOV-21	34.000	ug/L
51477	51477-1-114-S16	Main, Inside Room 114, Sink	Initial	09-SEP-22	5.200	ug/L
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	25-AUG-16	1.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	16-NOV-16	1.300	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	16-NOV-16	1.070	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	16-NOV-16	1.110	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	16-NOV-16	1.820	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	12-AUG-16	41.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	12-AUG-16	31.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	12-AUG-16	28.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	25-AUG-16	1.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	25-AUG-16	1.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	25-AUG-16	1.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	16-JUN-16	27.700	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	16-JUN-16	25.900	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	16-JUN-16	22.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	12-AUG-16	26.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Flush180	16-JUN-16	26.600	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Initial	16-NOV-16	1.310	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Initial	25-AUG-16	1.000	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Initial	16-JUN-16	24.300	ppb
51477	51477-1-115-F10	Main, Inside Room 115, Fountain	Initial	12-AUG-16	28.000	ppb
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	12-AUG-16	5.000	ppb
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	12-AUG-16	3.400	ppb
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	12-AUG-16	3.900	ppb
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	12-AUG-16	3.400	ppb
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	08-MAR-22	150.000	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	08-MAR-22	85.000	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	08-MAR-22	39.200	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	08-MAR-22	35.000	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	16-NOV-21	8.890	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	16-NOV-21	8.840	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	16-NOV-21	7.600	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	16-NOV-21	6.650	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	09-SEP-22	130.000	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	09-SEP-22	89.000	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	09-SEP-22	120.000	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Flush180	09-SEP-22	43.000	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Initial	12-AUG-16	5.500	ppb
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Initial	08-MAR-22	32.400	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Initial	16-NOV-21	42.600	ug/L
51477	51477-1-116-S17	Main, Inside Room 116, Sink	Initial	09-SEP-22	310.000	ug/L
51477	51477-1-116-S18	Main, Inside Room 116, Toilet Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-116-S18	Main, Inside Room 116, Toilet Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-116-S18	Main, Inside Room 116, Toilet Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-116-S18	Main, Inside Room 116, Toilet Sink	Flush180	12-AUG-16	1.000	ppb
51477	51477-1-116-S18	Main, Inside Room 116, Toilet Sink	Flush180	17-JUL-20	1.980	ug/L
51477	51477-1-116-S18	Main, Inside Room 116, Toilet Sink	Initial	12-AUG-16	1.000	ppb
51477	51477-1-116-S18	Main, Inside Room 116, Toilet Sink	Initial	17-JUL-20	3.930	ug/L
51477	51477-1-126-F07	Main, Inside Room 126, Fountain	Flush180	16-JUN-16	0.987	ppb
51477	51477-1-126-F07	Main, Inside Room 126, Fountain	Flush180	16-JUN-16	0.883	ppb
51477	51477-1-126-F07	Main, Inside Room 126, Fountain	Flush180	16-JUN-16	0.957	ppb
51477	51477-1-126-F07	Main, Inside Room 126, Fountain	Flush180	16-JUN-16	0.849	ppb
51477	51477-1-126-F07	Main, Inside Room 126, Fountain	Initial	16-JUN-16	1.110	ppb
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Flush180	16-JUN-16	0.762	ppb
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Flush180	16-JUN-16	1.190	ppb
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Flush180	16-JUN-16	2.370	ppb
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Flush180	16-JUN-16	0.728	ppb
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Flush180	16-NOV-21	3.220	ug/L
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Flush180	16-NOV-21	3.000	ug/L
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Initial	16-JUN-16	0.745	ppb
51477	51477-1-KIT-KS02	Main, Kitchen (Center), Sink 2	Initial	16-NOV-21	2.120	ug/L
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Flush180	16-JUN-16	0.515	ppb
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Flush180	16-JUN-16	0.538	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Flush180	16-JUN-16	0.408	ppb
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Flush180	16-JUN-16	0.544	ppb
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Flush180	16-NOV-21	1.430	ug/L
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Flush180	16-NOV-21	1.830	ug/L
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Initial	16-JUN-16	0.657	ppb
51477	51477-1-KIT-KS01	Main, Kitchen (Left), Sink 1	Initial	16-NOV-21	1.830	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	16-JUN-16	2.230	ppb
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	16-JUN-16	0.895	ppb
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	16-JUN-16	0.762	ppb
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	16-JUN-16	4.260	ppb
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	08-MAR-22	1.000	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	08-MAR-22	1.000	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	08-MAR-22	1.000	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	16-NOV-21	3.920	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	16-NOV-21	2.020	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	16-NOV-21	1.000	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Flush180	08-MAR-22	1.000	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Initial	16-JUN-16	0.968	ppb
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Initial	16-NOV-21	16.700	ug/L
51477	51477-1-KIT-KS03	Main, Kitchen (Right), Sink 3	Initial	08-MAR-22	1.000	ug/L
51477	51477-1-HAL-F06	Main, Next to Room 126 Hallway, Fountain	Flush180	16-JUN-16	1.010	ppb
51477	51477-1-HAL-F06	Main, Next to Room 126 Hallway, Fountain	Flush180	16-JUN-16	0.584	ppb
51477	51477-1-HAL-F06	Main, Next to Room 126 Hallway, Fountain	Flush180	16-JUN-16	1.700	ppb
51477	51477-1-HAL-F06	Main, Next to Room 126 Hallway, Fountain	Flush180	16-JUN-16	0.770	ppb
51477	51477-1-HAL-F06	Main, Next to Room 126 Hallway, Fountain	Initial	16-JUN-16	2.140	ppb
53861	53861-1-HAL-F03	Modular - Hallway, Left Fountain	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F03	Modular - Hallway, Left Fountain	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F03	Modular - Hallway, Left Fountain	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F03	Modular - Hallway, Left Fountain	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F03	Modular - Hallway, Left Fountain	Initial	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-BF01	Modular - Hallway, Right Bottle Filler	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-BF01	Modular - Hallway, Right Bottle Filler	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-BF01	Modular - Hallway, Right Bottle Filler	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-BF01	Modular - Hallway, Right Bottle Filler	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-BF01	Modular - Hallway, Right Bottle Filler	Initial	07-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01	Filler				
53861	53861-1-HAL-F04	Modular - Hallway, Right Fountain	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F04	Modular - Hallway, Right Fountain	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F04	Modular - Hallway, Right Fountain	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F04	Modular - Hallway, Right Fountain	Flush180	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F04	Modular - Hallway, Right Fountain	Initial	07-SEP-23	1.000	ug/L
53861	53861-1-HAL-F01	Modular 1, Next to Room 202 Hallway (East), Founta	Flush180	16-JUN-16	0.177	ppb
53861	53861-1-HAL-F01	Modular 1, Next to Room 202 Hallway (East), Founta	Flush180	16-JUN-16	0.389	ppb
53861	53861-1-HAL-F01	Modular 1, Next to Room 202 Hallway (East), Founta	Flush180	16-JUN-16	0.161	ppb
53861	53861-1-HAL-F01	Modular 1, Next to Room 202 Hallway (East), Founta	Flush180	16-JUN-16	0.422	ppb
53861	53861-1-HAL-F01	Modular 1, Next to Room 202 Hallway (East), Founta	Initial	16-JUN-16	0.908	ppb
53861	53861-1-HAL-RBF02	Modular 1, Next to Room 202 Hallway (Left), Retrofit BF	Flush180	16-NOV-21	1.000	ug/L
53861	53861-1-HAL-RBF02	Modular 1, Next to Room 202 Hallway (Left), Retrofit BF	Flush180	16-NOV-21	1.000	ug/L
53861	53861-1-HAL-RBF02	Modular 1, Next to Room 202 Hallway (Left), Retrofit BF	Flush180	16-NOV-21	1.000	ug/L
53861	53861-1-HAL-RBF02	Modular 1, Next to Room 202 Hallway (Left), Retrofit BF	Flush180	16-NOV-21	1.000	ug/L
53861	53861-1-HAL-RBF02	Modular 1, Next to Room 202 Hallway (Left), Retrofit BF	Initial	16-NOV-21	1.000	ug/L
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Flush180	16-JUN-16	1.000	ppb
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Flush180	16-JUN-16	0.137	ppb
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Flush180	16-JUN-16	1.000	ppb
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Flush180	16-JUN-16	1.000	ppb
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Flush180	16-NOV-21	1.470	ug/L
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Flush180	16-NOV-21	1.650	ug/L
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Flush180	16-NOV-21	1.570	ug/L
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Flush180	16-NOV-21	1.390	ug/L
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Initial	16-JUN-16	1.000	ppb
53861	53861-1-HAL-F02	Modular 1, Next to Room 202 Hallway Right), Fountain	Initial	16-NOV-21	3.370	ug/L