



Sep 10, 2024

**POLARIS**

**620 N SAWYER AVE, Chicago IL 60624.**

Dear **POLARIS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**POLARIS**

**620 N SAWYER AVE, Chicago IL 60624.**

Estimadas familias de **POLARIS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago





Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51141	51141-1-HAL-F04	Annex- 1st Floor Corridor, Right Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F04	Annex- 1st Floor Corridor, Right Fountain	Initial	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F08	Annex- 2nd Floor Corridor, Center Fountain	Initial	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F09	Annex- 2nd Floor Corridor, Left Fountain	Initial	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F07	Annex- 2nd Floor Corridor, Right Fountain	Initial	20-SEP-19	1.000	ug/L
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Flush180	20-SEP-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Initial	20-SEP-16	1.000	ppb
51141	51141-1-118-S03	Annex- Cafeteria, South Wall Sink	Initial	20-SEP-19	1.000	ug/L
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Initial	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS01	Annex- Kitchen, East Wall, Left Sink	Initial	20-SEP-19	1.280	ug/L
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Initial	20-SEP-16	1.000	ppb
51141	51141-1-KIT-KS02	Annex- Kitchen, East Wall, Right Sink	Initial	20-SEP-19	1.000	ug/L
51141	51141-B-HAL-F01	Basement Hallway Fountain	Flush180	09-OCT-20	1.000	ug/L
51141	51141-B-HAL-F01	Basement Hallway Fountain	Initial	09-OCT-20	1.000	ug/L
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F08	Main- Outside Room 104, Left Fountain	Initial	20-SEP-19	1.280	ug/L
51141	51141-1-HAL-	Main- Outside Room 104, Right	Flush180	20-SEP-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07	Fountain				
51141	51141-1-HAL-F07	Main- Outside Room 104, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F07	Main- Outside Room 104, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F07	Main- Outside Room 104, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F07	Main- Outside Room 104, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-F07	Main- Outside Room 104, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-F07	Main- Outside Room 104, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-F07	Main- Outside Room 104, Right Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F07	Main- Outside Room 104, Right Fountain	Initial	20-SEP-19	1.380	ug/L
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC10	Main- Outside Room 110, Left Fountain	Initial	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Flush180	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-1-HAL-WC09	Main- Outside Room 110, Right Fountain	Initial	20-SEP-19	1.000	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	07-JUL-23	12.600	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	07-JUL-23	14.600	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	07-JUL-23	9.030	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	07-JUL-23	8.080	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	20-SEP-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F12	Fountain				
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	20-SEP-19	4.430	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	20-SEP-19	2.550	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	20-SEP-19	1.960	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Flush180	20-SEP-19	2.060	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Initial	07-JUL-23	7.920	ug/L
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Initial	20-SEP-16	2.700	ppb
51141	51141-1-HAL-F12	Main- Outside Room 116, Left Fountain	Initial	20-SEP-19	6.290	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	20-SEP-16	2.200	ppb
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	20-SEP-16	2.700	ppb
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	20-SEP-16	2.400	ppb
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	20-SEP-16	3.100	ppb
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	20-SEP-19	2.750	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	20-SEP-19	2.230	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	20-SEP-19	1.910	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	20-SEP-19	6.690	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	18-AUG-20	1.000	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	08-AUG-23	32.000	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	08-AUG-23	30.700	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	08-AUG-23	37.900	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Flush180	08-AUG-23	38.500	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Initial	20-SEP-16	6.400	ppb
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Initial	20-SEP-19	10.100	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Initial	18-AUG-20	1.490	ug/L
51141	51141-1-HAL-F11	Main- Outside Room 116, Right Fountain	Initial	08-AUG-23	170.000	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Flush180	07-JUL-23	11.500	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Flush180	07-JUL-23	11.500	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Flush180	07-JUL-23	12.000	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Flush180	07-JUL-23	11.500	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Flush180	08-AUG-23	24.300	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Flush180	08-AUG-23	178.000	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Flush180	08-AUG-23	165.000	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Flush180	08-AUG-23	23.400	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Initial	07-JUL-23	14.500	ug/L
51141	51141-1-HAL-RBF01	Main- Outside Room 116, Right Retrofit Bottle Filler	Initial	08-AUG-23	46.900	ug/L
51141	51141-2-HAL-F05	Main- Outside Room 202, Left Fountain	Flush180	20-SEP-16	2.200	ppb
51141	51141-2-HAL-F05	Main- Outside Room 202, Left Fountain	Flush180	20-SEP-16	3.300	ppb
51141	51141-2-HAL-F05	Main- Outside Room 202, Left Fountain	Flush180	20-SEP-16	2.100	ppb





Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51141	51141-2-HAL-WC04	Main- Outside Room 208, Right Fountain	Initial	20-SEP-16	1.000	ppb
51141	51141-2-HAL-WC04	Main- Outside Room 208, Right Fountain	Initial	20-SEP-19	1.000	ug/L
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Flush180	20-SEP-16	2.300	ppb
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Flush180	20-SEP-19	2.620	ug/L
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Flush180	20-SEP-19	2.150	ug/L
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Flush180	20-SEP-19	1.370	ug/L
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Flush180	20-SEP-19	1.450	ug/L
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Initial	20-SEP-16	3.700	ppb
51141	51141-2-HAL-F01	Main- Outside Room 214, Left Fountain	Initial	20-SEP-19	4.300	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	07-JUL-23	37.000	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	07-JUL-23	15.200	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	07-JUL-23	18.000	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	07-JUL-23	12.400	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	20-SEP-16	2.100	ppb
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	20-SEP-16	2.400	ppb
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	20-SEP-19	5.330	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	20-SEP-19	3.320	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	20-SEP-19	2.900	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	20-SEP-19	2.500	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	08-AUG-23	103.000	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	08-AUG-23	67.500	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	08-AUG-23	67.600	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Flush180	08-AUG-23	70.300	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Initial	07-JUL-23	19.800	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Initial	20-SEP-16	3.700	ppb
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Initial	20-SEP-19	7.710	ug/L
51141	51141-2-HAL-F02	Main- Outside Room 214, Right Fountain	Initial	08-AUG-23	56.100	ug/L