



Sep 10, 2024

PORTAGE PARK

5330 W BERTEAU AVE, Chicago IL 60641.

Dear **PORTAGE PARK** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

PORTAGE PARK

5330 W BERTEAU AVE, Chicago IL 60641.

Estimadas familias de **PORTAGE PARK:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Initial	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Initial	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F04	Annex- 1st Floor Hallway By Boys Toilet, East Foun	Initial	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-RBF01	Annex- 1st Floor Hallway By Boys Toilet, Retrofit Bottle Filler	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-RBF01	Annex- 1st Floor Hallway By Boys Toilet, Retrofit Bottle Filler	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-RBF01	Annex- 1st Floor Hallway By Boys Toilet, Retrofit Bottle Filler	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-RBF01	Annex- 1st Floor Hallway By Boys Toilet, Retrofit Bottle Filler	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-RBF01	Annex- 1st Floor Hallway By Boys Toilet, Retrofit Bottle Filler	Initial	26-APR-23	1.000	ug/L
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Initial	07-JUN-16	1.000	ppb
51028	51028-ANX-1-HAL-F05	Annex- 1st Floor Hallway By Boys Toilet, West Foun	Initial	04-OCT-19	1.000	ug/L
51028	51028-ANX-2-HAL-F01	Annex- 2nd Floor Hallway By Boys Toilet, West Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-2-HAL-F01	Annex- 2nd Floor Hallway By Boys Toilet, West Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-2-HAL-F01	Annex- 2nd Floor Hallway By Boys Toilet, West Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-2-HAL-F01	Annex- 2nd Floor Hallway By Boys Toilet, West Foun	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-2-HAL-F01	Annex- 2nd Floor Hallway By Boys Toilet, West Foun	Flush180	04-OCT-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51028	51028-ANX-3-HAL-F01	Annex- 3rd Floor Hallway By Boys Toilet, West Foun	Initial	07-JUN-16	1.000	ppb
51028	51028-ANX-3-HAL-F01	Annex- 3rd Floor Hallway By Boys Toilet, West Foun	Initial	04-OCT-19	1.000	ug/L
51028	51028-ANX-3-HAL-F01	Annex- 3rd Floor Hallway By Boys Toilet, West Foun	Initial	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS03	Annex- Kitchen, Double basin in Kitchen Island Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS03	Annex- Kitchen, Double basin in Kitchen Island Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS03	Annex- Kitchen, Double basin in Kitchen Island Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS03	Annex- Kitchen, Double basin in Kitchen Island Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS03	Annex- Kitchen, Double basin in Kitchen Island Sink	Initial	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	04-OCT-19	1.420	ug/L
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Initial	07-JUN-16	1.000	ppb
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Initial	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-KIT-KS01	Annex- Kitchen, West wall Cooking Sink	Initial	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS02	Annex- Kitchen, West wall Cooking Sink Right	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS02	Annex- Kitchen, West wall Cooking Sink Right	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS02	Annex- Kitchen, West wall Cooking Sink Right	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS02	Annex- Kitchen, West wall Cooking Sink Right	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS02	Annex- Kitchen, West wall Cooking Sink Right	Initial	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS04	Annex- Single basin sink across from KS03	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS04	Annex- Single basin sink across from KS03	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS04	Annex- Single basin sink across from KS03	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS04	Annex- Single basin sink across from KS03	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-KIT-KS04	Annex- Single basin sink across from KS03	Initial	26-APR-23	1.000	ug/L
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-2-	Annex-2nd Floor Hallway By Boys	Flush180	04-OCT-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Toilet, East Fount				
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Initial	07-JUN-16	1.000	ppb
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Initial	04-OCT-19	1.000	ug/L
51028	51028-ANX-2-HAL-F02	Annex-2nd Floor Hallway By Boys Toilet, East Fount	Initial	26-APR-23	1.000	ug/L
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Initial	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC02	Annex-Multi-Purpose Room, East Fountain 1	Initial	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Flush180	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Flush180	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-BF01	Annex-Multi-Purpose Room, West Fountain 2	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-BF01	Annex-Multi-Purpose Room, West Fountain 2	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-BF01	Annex-Multi-Purpose Room, West Fountain 2	Flush180	26-APR-23	1.000	ug/L
51028	51028-ANX-1-BF01	Annex-Multi-Purpose Room, West Fountain 2	Initial	07-JUN-16	1.000	ppb
51028	51028-ANX-1-MPR-WC03	Annex-Multi-Purpose Room, West Fountain 2	Initial	04-OCT-19	1.000	ug/L
51028	51028-ANX-1-BF01	Annex-Multi-Purpose Room, West Fountain 2	Initial	26-APR-23	1.000	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	03-DEC-20	1.000	ug/L
51028	51028-2-221-	IN ROOM 221	Flush180	03-DEC-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51028	51028-2-221-S01	IN ROOM 221	Flush180	03-DEC-20	1.000	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	03-DEC-20	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	03-DEC-20	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	03-DEC-20	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	03-DEC-20	1.000	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	09-OCT-20	11.800	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	09-OCT-20	12.800	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	09-OCT-20	6.290	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	09-OCT-20	6.730	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	09-OCT-20	20.200	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	09-OCT-20	17.400	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	09-OCT-20	7.570	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	09-OCT-20	15.700	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-221-S01	IN ROOM 221	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-221-S01	IN ROOM 221	Initial	03-DEC-20	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Initial	03-DEC-20	1.000	ug/L
51028	51028-2-221-S01	IN ROOM 221	Initial	09-OCT-20	22.900	ug/L
51028	51028-2-221-S02	IN ROOM 221	Initial	09-OCT-20	11.800	ug/L
51028	51028-2-221-S01	IN ROOM 221	Initial	26-APR-23	1.000	ug/L
51028	51028-2-221-S02	IN ROOM 221	Initial	26-APR-23	1.000	ug/L
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F03	Main- 2nd Floor Hallway Across Boys Toilet, North	Flush180	26-APR-23	1.210	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Flush180	26-APR-23	1.000	ug/L
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Initial	07-JUN-16	1.000	ppb
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Initial	04-OCT-19	1.000	ug/L
51028	51028-2-HAL-F01	Main- 2nd Floor Hallway Across Girls Toilet, South	Initial	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Initial	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Initial	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F01	Main- 3rd Floor Hallway Across Boys Toilet, North	Initial	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	26-APR-23	2.080	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Boys Toilet, South				
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	26-APR-23	1.640	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	26-APR-23	1.420	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Initial	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Initial	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F02	Main- 3rd Floor Hallway Across Boys Toilet, South	Initial	26-APR-23	3.800	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	26-APR-23	1.780	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	26-APR-23	2.050	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Initial	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Initial	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F03	Main- 3rd Floor Hallway Across Girls Toilet, North	Initial	26-APR-23	2.880	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Flush180	26-APR-23	1.000	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Initial	07-JUN-16	1.000	ppb
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Initial	04-OCT-19	1.000	ug/L
51028	51028-3-HAL-F04	Main- 3rd Floor Hallway Across Girls Toilet, South	Initial	26-APR-23	1.000	ug/L
51028	51028-1-HAL-	Main- Across From Rooms 103 &	Flush180	07-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	104, North Fountain				
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	26-APR-23	1.010	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Initial	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Initial	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F02	Main- Across From Rooms 103 & 104, North Fountain	Initial	26-APR-23	1.060	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	18-AUG-20	2.880	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Initial	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Initial	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Initial	18-AUG-20	2.110	ug/L
51028	51028-1-HAL-F01	Main- Across From Rooms 103 & 104, South Fountain	Initial	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	04-OCT-19	1.060	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	04-OCT-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	18-AUG-20	2.630	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	26-APR-23	2.370	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	26-APR-23	1.130	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	26-APR-23	1.320	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Initial	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Initial	04-OCT-19	1.160	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Initial	18-AUG-20	2.490	ug/L
51028	51028-1-HAL-F03	Main- Across From Rooms 109 & 110, North Fountain	Initial	26-APR-23	1.510	ug/L
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Initial	07-JUN-16	1.000	ppb
51028	51028-1-HAL-F04	Main- Across From Rooms 109 & 110, South Fountain	Initial	04-OCT-19	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Initial	07-JUN-16	1.000	ppb
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Initial	04-OCT-19	1.120	ug/L
51028	51028-1-110-F06	Main- Inside Pre-K Room 110, Fountain	Initial	26-APR-23	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	07-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Initial	07-JUN-16	1.000	ppb
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Initial	04-OCT-19	1.000	ug/L
51028	51028-1-110-S05	Main- Inside Pre-K Room 110, Sink	Initial	26-APR-23	1.000	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	04-OCT-19	1.060	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	26-APR-23	1.100	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	26-APR-23	3.160	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Flush180	26-APR-23	1.950	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Initial	07-JUN-16	1.000	ppb
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Initial	04-OCT-19	1.000	ug/L
51028	51028-1-111-S07	Main- Inside Pre-K Room 111, Fountain	Initial	26-APR-23	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	04-OCT-19	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	26-APR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F08	Sink				
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Flush180	26-APR-23	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Initial	07-JUN-16	1.000	ppb
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Initial	04-OCT-19	1.000	ug/L
51028	51028-1-111-F08	Main- Inside Pre-K Room 111, Sink	Initial	26-APR-23	1.000	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	04-OCT-19	1.770	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	04-OCT-19	2.650	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	04-OCT-19	1.750	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	04-OCT-19	1.690	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	26-APR-23	2.510	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	26-APR-23	1.570	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	26-APR-23	1.490	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Flush180	26-APR-23	1.690	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Initial	07-JUN-16	1.000	ppb
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Initial	04-OCT-19	2.900	ug/L
51028	51028-1-101-F10	Main- Kindergarten Room 101, Fountain	Initial	26-APR-23	4.590	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	26-MAY-23	1.000	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	26-MAY-23	1.000	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	26-MAY-23	1.000	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	07-JUN-16	5.820	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	07-JUN-16	1.000	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	07-JUN-16	6.480	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	28-JUL-16	6.300	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	28-JUL-16	12.000	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	28-JUL-16	3.900	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	28-JUL-16	3.400	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	04-OCT-19	1.790	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	04-OCT-19	2.130	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	04-OCT-19	1.590	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	04-OCT-19	1.170	ug/L

**Water Quality Assessment
Portage Park Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S09	Sink				
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	16-JAN-20	1.060	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	16-JAN-20	2.060	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	16-JAN-20	2.310	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	16-JAN-20	1.880	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	26-APR-23	4.580	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	26-APR-23	5.140	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	26-APR-23	5.360	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Flush180	26-APR-23	6.130	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Initial	26-MAY-23	1.290	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Initial	07-JUN-16	24.800	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Initial	28-JUL-16	7.100	ppb
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Initial	04-OCT-19	7.320	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Initial	16-JAN-20	2.660	ug/L
51028	51028-1-101-S09	Main- Kindergarten Room 101, Sink	Initial	26-APR-23	5.260	ug/L