



Sep 10, 2024

PRIETO

2231 N CENTRAL AVE, Chicago IL 60639.

Dear **PRIETO** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

PRIETO

2231 N CENTRAL AVE, Chicago IL 60639.

Estimadas familias de **PRIETO**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54698	54698-3-HAL-F01	Main- Across From Library Room 300, Left Fountain	Flush180	28-SEP-16	0.219	ppb
54698	54698-3-HAL-F01	Main- Across From Library Room 300, Left Fountain	Flush180	28-SEP-16	0.224	ppb
54698	54698-3-HAL-F01	Main- Across From Library Room 300, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F01	Main- Across From Library Room 300, Left Fountain	Flush180	28-SEP-16	0.202	ppb
54698	54698-3-HAL-F01	Main- Across From Library Room 300, Left Fountain	Initial	28-SEP-16	0.215	ppb
54698	54698-2-HAL-F02	Main- Across From Room 201, Center Fountain	Flush180	28-SEP-16	0.311	ppb
54698	54698-2-HAL-F02	Main- Across From Room 201, Center Fountain	Flush180	28-SEP-16	0.273	ppb
54698	54698-2-HAL-F02	Main- Across From Room 201, Center Fountain	Flush180	28-SEP-16	0.331	ppb
54698	54698-2-HAL-F02	Main- Across From Room 201, Center Fountain	Flush180	28-SEP-16	0.265	ppb
54698	54698-2-HAL-F02	Main- Across From Room 201, Center Fountain	Initial	28-SEP-16	0.233	ppb
54698	54698-2-HAL-F03	Main- Across From Room 201, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F03	Main- Across From Room 201, Right Fountain	Flush180	28-SEP-16	0.201	ppb
54698	54698-2-HAL-F03	Main- Across From Room 201, Right Fountain	Flush180	28-SEP-16	0.123	ppb
54698	54698-2-HAL-F03	Main- Across From Room 201, Right Fountain	Flush180	28-SEP-16	0.215	ppb
54698	54698-2-HAL-F03	Main- Across From Room 201, Right Fountain	Initial	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F05	Main- Across From Room 228, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F05	Main- Across From Room 228, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F05	Main- Across From Room 228, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F05	Main- Across From Room 228, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F05	Main- Across From Room 228, Center Fountain	Initial	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F04	Main- Across From Room 228, Left Fountain	Flush180	28-SEP-16	0.130	ppb
54698	54698-2-HAL-F04	Main- Across From Room 228, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F04	Main- Across From Room 228, Left Fountain	Flush180	28-SEP-16	0.376	ppb
54698	54698-2-HAL-F04	Main- Across From Room 228, Left Fountain	Flush180	28-SEP-16	0.127	ppb
54698	54698-2-HAL-F04	Main- Across From Room 228, Left Fountain	Initial	28-SEP-16	0.175	ppb
54698	54698-2-HAL-F06	Main- Across From Room 228, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F06	Main- Across From Room 228, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F06	Main- Across From Room 228, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F06	Main- Across From Room 228, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-2-HAL-F06	Main- Across From Room 228, Right Fountain	Initial	28-SEP-16	0.169	ppb
54698	54698-3-HAL-F02	Main- Across From Room 300, Center Fountain	Flush180	28-SEP-16	0.172	ppb
54698	54698-3-HAL-F02	Main- Across From Room 300, Center Fountain	Flush180	28-SEP-16	0.130	ppb
54698	54698-3-HAL-F02	Main- Across From Room 300, Center Fountain	Flush180	28-SEP-16	0.634	ppb
54698	54698-3-HAL-F02	Main- Across From Room 300, Center Fountain	Flush180	28-SEP-16	0.240	ppb
54698	54698-3-HAL-F02	Main- Across From Room 300, Center Fountain	Initial	28-SEP-16	0.222	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54698	54698-3-HAL-F06	Main- Across From Room 300, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F06	Main- Across From Room 300, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F06	Main- Across From Room 300, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F06	Main- Across From Room 300, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F06	Main- Across From Room 300, Left Fountain	Initial	28-SEP-16	0.129	ppb
54698	54698-3-HAL-F03	Main- Across From Room 300, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F03	Main- Across From Room 300, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F03	Main- Across From Room 300, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F03	Main- Across From Room 300, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F03	Main- Across From Room 300, Right Fountain	Initial	28-SEP-16	0.154	ppb
54698	54698-3-HAL-F05	Main- Across From Room 330, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F05	Main- Across From Room 330, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F05	Main- Across From Room 330, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F05	Main- Across From Room 330, Center Fountain	Initial	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F04	Main- Across From Room 330, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F04	Main- Across From Room 330, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F04	Main- Across From Room 330, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-3-HAL-F04	Main- Across From Room 330, Right Fountain	Initial	28-SEP-16	0.156	ppb
54698	54698-1-118-F06	Main- Inside Room 118, Fountain	Flush180	28-SEP-16	0.217	ppb
54698	54698-1-118-F06	Main- Inside Room 118, Fountain	Flush180	28-SEP-16	0.193	ppb
54698	54698-1-118-F06	Main- Inside Room 118, Fountain	Flush180	28-SEP-16	0.287	ppb
54698	54698-1-118-F06	Main- Inside Room 118, Fountain	Flush180	28-SEP-16	0.205	ppb
54698	54698-1-118-F06	Main- Inside Room 118, Fountain	Initial	28-SEP-16	0.136	ppb
54698	54698-1-118-S07	Main- Inside Room 118, Sink	Flush180	28-SEP-16	3.450	ppb
54698	54698-1-118-S07	Main- Inside Room 118, Sink	Flush180	28-SEP-16	1.090	ppb
54698	54698-1-118-S07	Main- Inside Room 118, Sink	Flush180	28-SEP-16	0.487	ppb
54698	54698-1-118-S07	Main- Inside Room 118, Sink	Flush180	28-SEP-16	1.480	ppb
54698	54698-1-118-S07	Main- Inside Room 118, Sink	Initial	28-SEP-16	0.452	ppb
54698	54698-1-119-F08	Main- Inside Room 119, Fountain	Flush180	28-SEP-16	0.168	ppb
54698	54698-1-119-F08	Main- Inside Room 119, Fountain	Flush180	28-SEP-16	0.258	ppb
54698	54698-1-119-F08	Main- Inside Room 119, Fountain	Flush180	28-SEP-16	0.189	ppb
54698	54698-1-119-F08	Main- Inside Room 119, Fountain	Flush180	28-SEP-16	0.214	ppb
54698	54698-1-119-F08	Main- Inside Room 119, Fountain	Initial	28-SEP-16	1.000	ppb
54698	54698-1-119-S09	Main- Inside Room 119, Sink	Flush180	28-SEP-16	0.772	ppb
54698	54698-1-119-S09	Main- Inside Room 119, Sink	Flush180	28-SEP-16	0.574	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54698	54698-1-119-S09	Main- Inside Room 119, Sink	Flush180	28-SEP-16	0.333	ppb
54698	54698-1-119-S09	Main- Inside Room 119, Sink	Flush180	28-SEP-16	1.440	ppb
54698	54698-1-119-S09	Main- Inside Room 119, Sink	Initial	28-SEP-16	0.814	ppb
54698	54698-1-120-F10	Main- Inside Room 120, Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-120-F10	Main- Inside Room 120, Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-120-F10	Main- Inside Room 120, Fountain	Flush180	28-SEP-16	0.122	ppb
54698	54698-1-120-F10	Main- Inside Room 120, Fountain	Flush180	28-SEP-16	0.129	ppb
54698	54698-1-120-F10	Main- Inside Room 120, Fountain	Initial	28-SEP-16	0.132	ppb
54698	54698-1-120-S11	Main- Inside Room 120, Sink	Flush180	28-SEP-16	1.890	ppb
54698	54698-1-120-S11	Main- Inside Room 120, Sink	Flush180	28-SEP-16	1.110	ppb
54698	54698-1-120-S11	Main- Inside Room 120, Sink	Flush180	28-SEP-16	1.750	ppb
54698	54698-1-120-S11	Main- Inside Room 120, Sink	Flush180	28-SEP-16	1.390	ppb
54698	54698-1-120-S11	Main- Inside Room 120, Sink	Initial	28-SEP-16	2.760	ppb
54698	54698-1-121-F12	Main- Inside Room 121, Fountain	Flush180	28-SEP-16	0.138	ppb
54698	54698-1-121-F12	Main- Inside Room 121, Fountain	Flush180	28-SEP-16	0.143	ppb
54698	54698-1-121-F12	Main- Inside Room 121, Fountain	Flush180	28-SEP-16	0.149	ppb
54698	54698-1-121-F12	Main- Inside Room 121, Fountain	Flush180	28-SEP-16	0.137	ppb
54698	54698-1-121-F12	Main- Inside Room 121, Fountain	Initial	28-SEP-16	0.193	ppb
54698	54698-1-121-S13	Main- Inside Room 121, Sink	Flush180	28-SEP-16	0.221	ppb
54698	54698-1-121-S13	Main- Inside Room 121, Sink	Flush180	28-SEP-16	0.248	ppb
54698	54698-1-121-S13	Main- Inside Room 121, Sink	Flush180	28-SEP-16	0.330	ppb
54698	54698-1-121-S13	Main- Inside Room 121, Sink	Flush180	28-SEP-16	0.272	ppb
54698	54698-1-121-S13	Main- Inside Room 121, Sink	Initial	28-SEP-16	0.526	ppb
54698	54698-1-123-F16	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-122-F14	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-122-F14	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	0.143	ppb
54698	54698-1-122-F14	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	0.173	ppb
54698	54698-1-122-F14	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-123-F16	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-123-F16	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-123-F16	Main- Inside Room 122, FountMain- Inside Room 122,	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-122-F14	Main- Inside Room 122, FountMain- Inside Room 122,	Initial	28-SEP-16	1.000	ppb
54698	54698-1-123-F16	Main- Inside Room 122, FountMain- Inside Room 122,	Initial	28-SEP-16	0.120	ppb
54698	54698-1-122-S15	Main- Inside Room 122, Sink	Flush180	28-SEP-16	0.639	ppb
54698	54698-1-122-S15	Main- Inside Room 122, Sink	Flush180	28-SEP-16	0.473	ppb
54698	54698-1-122-S15	Main- Inside Room 122, Sink	Flush180	28-SEP-16	0.488	ppb
54698	54698-1-122-S15	Main- Inside Room 122, Sink	Flush180	28-SEP-16	0.380	ppb
54698	54698-1-122-S15	Main- Inside Room 122, Sink	Initial	28-SEP-16	2.240	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S15					
54698	54698-1-KIT-KS01	Main- Kitchen South Wall, Left Sink	Flush180	28-SEP-16	0.207	ppb
54698	54698-1-KIT-KS01	Main- Kitchen South Wall, Left Sink	Flush180	28-SEP-16	0.242	ppb
54698	54698-1-KIT-KS01	Main- Kitchen South Wall, Left Sink	Flush180	28-SEP-16	0.189	ppb
54698	54698-1-KIT-KS01	Main- Kitchen South Wall, Left Sink	Flush180	28-SEP-16	0.212	ppb
54698	54698-1-KIT-KS01	Main- Kitchen South Wall, Left Sink	Initial	28-SEP-16	0.390	ppb
54698	54698-1-HAL-F18	Main- Next to Room 123, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F18	Main- Next to Room 123, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F18	Main- Next to Room 123, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F18	Main- Next to Room 123, Center Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F18	Main- Next to Room 123, Center Fountain	Initial	28-SEP-16	0.138	ppb
54698	54698-1-HAL-F19	Main- Next to Room 123, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F19	Main- Next to Room 123, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F19	Main- Next to Room 123, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F19	Main- Next to Room 123, Left Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F19	Main- Next to Room 123, Left Fountain	Initial	28-SEP-16	0.135	ppb
54698	54698-1-HAL-F17	Main- Next to Room 123, Right Fountain	Flush180	28-SEP-16	0.142	ppb
54698	54698-1-HAL-F17	Main- Next to Room 123, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F17	Main- Next to Room 123, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F17	Main- Next to Room 123, Right Fountain	Flush180	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F17	Main- Next to Room 123, Right Fountain	Initial	28-SEP-16	1.000	ppb
54698	54698-1-HAL-F04	Main- Outside of Cafeteria, Center Fountain	Flush180	28-SEP-16	0.258	ppb
54698	54698-1-HAL-F04	Main- Outside of Cafeteria, Center Fountain	Flush180	28-SEP-16	0.252	ppb
54698	54698-1-HAL-F04	Main- Outside of Cafeteria, Center Fountain	Flush180	28-SEP-16	0.344	ppb
54698	54698-1-HAL-F04	Main- Outside of Cafeteria, Center Fountain	Flush180	28-SEP-16	0.188	ppb
54698	54698-1-HAL-F04	Main- Outside of Cafeteria, Center Fountain	Initial	28-SEP-16	0.159	ppb
54698	54698-1-HAL-F05	Main- Outside of Cafeteria, Left Fountain	Flush180	28-SEP-16	0.294	ppb
54698	54698-1-HAL-F05	Main- Outside of Cafeteria, Left Fountain	Flush180	28-SEP-16	0.189	ppb
54698	54698-1-HAL-F05	Main- Outside of Cafeteria, Left Fountain	Flush180	28-SEP-16	0.144	ppb
54698	54698-1-HAL-F05	Main- Outside of Cafeteria, Left Fountain	Flush180	28-SEP-16	0.354	ppb
54698	54698-1-HAL-F05	Main- Outside of Cafeteria, Left Fountain	Initial	28-SEP-16	0.224	ppb
54698	54698-1-HAL-F03	Main- Outside of Cafeteria, Right Fountain	Flush180	28-SEP-16	0.205	ppb
54698	54698-1-HAL-F03	Main- Outside of Cafeteria, Right Fountain	Flush180	28-SEP-16	0.225	ppb
54698	54698-1-HAL-F03	Main- Outside of Cafeteria, Right Fountain	Flush180	28-SEP-16	0.216	ppb
54698	54698-1-HAL-F03	Main- Outside of Cafeteria, Right Fountain	Flush180	28-SEP-16	0.229	ppb
54698	54698-1-HAL-F03	Main- Outside of Cafeteria, Right Fountain	Initial	28-SEP-16	0.255	ppb
54698	54698-1-E-HAL-F04	hallway	Flush180	04-AUG-20	1.000	ug/L
54698	54698-3-W-	hallway	Flush180	04-AUG-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F05					
54698	54698-1-E-HAL-F04	hallway	Initial	04-AUG-20	1.000	ug/L
54698	54698-3-W-HAL-F05	hallway	Initial	04-AUG-20	1.000	ug/L
58964	58964-1-S-HAL-F04	1st floor	Flush180	04-AUG-20	1.000	ug/L
58964	58964-1-S-HAL-F03	1st floor	Flush180	04-AUG-20	1.000	ug/L
58964	58964-1-S-HAL-F04	1st floor	Initial	04-AUG-20	1.000	ug/L
58964	58964-1-S-HAL-F03	1st floor	Initial	04-AUG-20	1.000	ug/L
58964	58964-1-HAL-F01	Modular- Next to Room 403, Left Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F01	Modular- Next to Room 403, Left Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F01	Modular- Next to Room 403, Left Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F01	Modular- Next to Room 403, Left Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F01	Modular- Next to Room 403, Left Fountain	Initial	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F02	Modular- Next to Room 403, Right Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F02	Modular- Next to Room 403, Right Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F02	Modular- Next to Room 403, Right Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F02	Modular- Next to Room 403, Right Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F02	Modular- Next to Room 403, Right Fountain	Initial	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F03	Modular- Next to Room 407, Left Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F03	Modular- Next to Room 407, Left Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F03	Modular- Next to Room 407, Left Fountain	Flush180	28-SEP-16	0.206	ppb
58964	58964-1-HAL-F03	Modular- Next to Room 407, Left Fountain	Initial	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F04	Modular- Next to Room 407, Right Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F04	Modular- Next to Room 407, Right Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F04	Modular- Next to Room 407, Right Fountain	Flush180	28-SEP-16	1.000	ppb
58964	58964-1-HAL-F04	Modular- Next to Room 407, Right Fountain	Flush180	28-SEP-16	0.138	ppb
58964	58964-1-HAL-F04	Modular- Next to Room 407, Right Fountain	Initial	28-SEP-16	0.154	ppb