



Sep 10, 2024

RABY HS

3545 W FULTON BLVD, Chicago IL 60624.

Dear **RABY HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

RABY HS

3545 W FULTON BLVD, Chicago IL 60624.

Estimadas familias de **RABY HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51574	51574-4-HAL-F02	BY 420 & JANITOR'S CLOSET	Flush180	02-MAR-21	1.000	ug/L
51574	51574-4-HAL-F02	BY 420 & JANITOR'S CLOSET	Initial	02-MAR-21	2.330	ug/L
51574	51574-1-HAL-F01	BY ENGINEERS ROOM OR 102	Flush180	02-MAR-21	5.220	ug/L
51574	51574-1-HAL-F01	BY ENGINEERS ROOM OR 102	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-F01	BY ENGINEERS ROOM OR 102	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-F01	BY ENGINEERS ROOM OR 102	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-F01	BY ENGINEERS ROOM OR 102	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-F01	BY ENGINEERS ROOM OR 102	Initial	02-MAR-21	1.360	ug/L
51574	51574-1-HAL-F01	BY ENGINEERS ROOM OR 102	Initial	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-RBF01	Main- Across From Room 216, Retrofitted Bottle Filler	Flush180	11-MAY-23	1.110	ug/L
51574	51574-2-HAL-RBF01	Main- Across From Room 216, Retrofitted Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-RBF01	Main- Across From Room 216, Retrofitted Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-RBF01	Main- Across From Room 216, Retrofitted Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-RBF01	Main- Across From Room 216, Retrofitted Bottle Filler	Initial	11-MAY-23	1.670	ug/L
51574	51574-2-HAL-WC02	Main- Across From Room 216, Water Cooler	Flush180	28-OCT-16	0.605	ppb
51574	51574-2-HAL-WC02	Main- Across From Room 216, Water Cooler	Flush180	28-OCT-16	0.682	ppb
51574	51574-2-HAL-WC02	Main- Across From Room 216, Water Cooler	Flush180	28-OCT-16	0.479	ppb
51574	51574-2-HAL-WC02	Main- Across From Room 216, Water Cooler	Flush180	28-OCT-16	0.701	ppb
51574	51574-2-HAL-WC02	Main- Across From Room 216, Water Cooler	Initial	28-OCT-16	0.471	ppb
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Flush180	28-OCT-16	0.228	ppb
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Flush180	28-OCT-16	0.412	ppb
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Flush180	28-OCT-16	0.126	ppb
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Initial	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC03	Main- Across From Room 222, Water Cooler	Initial	28-OCT-16	0.140	ppb
51574	51574-3-HAL-WC01	Main- Across From Room 310, Water Cooler	Flush180	28-OCT-16	0.192	ppb
51574	51574-3-HAL-WC01	Main- Across From Room 310, Water Cooler	Flush180	28-OCT-16	0.456	ppb
51574	51574-3-HAL-WC01	Main- Across From Room 310, Water Cooler	Flush180	28-OCT-16	0.244	ppb
51574	51574-3-HAL-WC01	Main- Across From Room 310, Water Cooler	Flush180	28-OCT-16	0.403	ppb
51574	51574-3-HAL-WC01	Main- Across From Room 310, Water Cooler	Initial	28-OCT-16	0.153	ppb
51574	51574-3-HAL-BF01	Main- Across From Room 322, Bottle Filler	Flush180	11-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51574	51574-3-HAL-BF01	Main- Across From Room 322, Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-BF01	Main- Across From Room 322, Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-BF01	Main- Across From Room 322, Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-BF01	Main- Across From Room 322, Bottle Filler	Initial	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-RBF01	Main- Across From Room 322, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-RBF01	Main- Across From Room 322, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-RBF01	Main- Across From Room 322, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-RBF01	Main- Across From Room 322, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Flush180	28-OCT-16	0.649	ppb
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Flush180	28-OCT-16	0.323	ppb
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Flush180	28-OCT-16	0.301	ppb
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Flush180	28-OCT-16	0.378	ppb
51574	51574-3-HAL-RBF01	Main- Across From Room 322, Water Cooler	Initial	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Initial	11-MAY-23	1.000	ug/L
51574	51574-3-HAL-WC02	Main- Across From Room 322, Water Cooler	Initial	28-OCT-16	0.245	ppb
51574	51574-4-HAL-RBF01	Main- Across From Room 408, Retrofitted Bottle Filler	Flush180	11-MAY-23	1.680	ug/L
51574	51574-4-HAL-RBF01	Main- Across From Room 408, Retrofitted Bottle Filler	Flush180	11-MAY-23	1.630	ug/L
51574	51574-4-HAL-RBF01	Main- Across From Room 408, Retrofitted Bottle Filler	Flush180	11-MAY-23	1.660	ug/L
51574	51574-4-HAL-RBF01	Main- Across From Room 408, Retrofitted Bottle Filler	Flush180	11-MAY-23	1.570	ug/L
51574	51574-4-HAL-RBF01	Main- Across From Room 408, Retrofitted Bottle Filler	Initial	11-MAY-23	2.190	ug/L
51574	51574-4-HAL-WC01	Main- Across From Room 408, Water Cooler	Flush180	28-OCT-16	0.284	ppb
51574	51574-4-HAL-WC01	Main- Across From Room 408, Water Cooler	Flush180	28-OCT-16	0.391	ppb
51574	51574-4-HAL-WC01	Main- Across From Room 408, Water Cooler	Flush180	28-OCT-16	0.523	ppb
51574	51574-4-HAL-WC01	Main- Across From Room 408, Water Cooler	Flush180	28-OCT-16	0.592	ppb
51574	51574-4-HAL-WC01	Main- Across From Room 408, Water Cooler	Initial	28-OCT-16	0.229	ppb
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Flush180	28-OCT-16	0.858	ppb
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Flush180	28-OCT-16	0.678	ppb
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Flush180	28-OCT-16	0.758	ppb
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Flush180	28-OCT-16	0.661	ppb

Water Quality Assessment AI Raby High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Initial	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC06	Main- Across From Room 420, Water Cooler	Initial	28-OCT-16	0.447	ppb
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Flush180	28-OCT-16	0.295	ppb
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Flush180	28-OCT-16	0.396	ppb
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Flush180	28-OCT-16	0.547	ppb
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Flush180	28-OCT-16	0.646	ppb
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Initial	28-OCT-16	0.210	ppb
51574	51574-1-HAL-WC16	Main- Across Room 110, Water Cooler	Initial	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Flush180	28-OCT-16	0.254	ppb
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Flush180	28-OCT-16	0.156	ppb
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Flush180	28-OCT-16	0.360	ppb
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Flush180	28-OCT-16	0.377	ppb
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Flush180	11-MAY-23	3.350	ug/L
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Flush180	11-MAY-23	3.470	ug/L
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Flush180	11-MAY-23	3.670	ug/L
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Flush180	11-MAY-23	3.970	ug/L
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Initial	28-OCT-16	0.150	ppb
51574	51574-1-HAL-WC15	Main- Across Room 114, Water Cooler	Initial	11-MAY-23	2.000	ug/L
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Flush180	28-OCT-16	0.368	ppb
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Flush180	28-OCT-16	0.301	ppb
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Flush180	28-OCT-16	0.231	ppb
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Initial	28-OCT-16	1.000	ppb
51574	51574-1-HAL-WC14	Main- Across Room 120, Water Cooler	Initial	11-MAY-23	1.000	ug/L
51574	51574-1-HAL-WC17	Main- Across Womens Locker Room, Water Cooler	Flush180	28-OCT-16	0.297	ppb
51574	51574-1-HAL-WC17	Main- Across Womens Locker Room, Water Cooler	Flush180	28-OCT-16	0.154	ppb
51574	51574-1-HAL-WC17	Main- Across Womens Locker Room, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-HAL-WC17	Main- Across Womens Locker Room, Water Cooler	Flush180	28-OCT-16	0.372	ppb
51574	51574-1-HAL-WC17	Main- Across Womens Locker Room, Water Cooler	Initial	28-OCT-16	1.000	ppb
51574	51574-4-420-	Main- Inside Culinary Room 420,	Flush180	11-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S03	East Wall, Left Si				
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	20-DEC-16	3.200	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	15-MAR-17	1.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	15-MAR-17	1.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	20-DEC-16	2.300	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	7.600	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	5.100	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	4.400	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	16.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	5.100	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	20-DEC-16	3.600	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	20-DEC-16	4.600	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	7.600	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	4.400	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	7.600	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	5.100	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	16.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	16.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	07-DEC-16	4.400	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	28-OCT-16	7.990	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	28-OCT-16	46.100	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	28-OCT-16	11.200	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	28-OCT-16	11.300	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	15-MAR-17	1.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Flush180	15-MAR-17	1.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Initial	11-MAY-23	1.000	ug/L
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Initial	07-DEC-16	13.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Initial	07-DEC-16	13.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Initial	20-DEC-16	20.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Initial	07-DEC-16	13.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Initial	28-OCT-16	204.000	ppb
51574	51574-4-420-S03	Main- Inside Culinary Room 420, East Wall, Left Si	Initial	15-MAR-17	3.290	ppb
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Flush180	11-MAY-23	1.000	ug/L

Water Quality Assessment AI Raby High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02	NE Corner Wall, Si				
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Flush180	28-OCT-16	1.030	ppb
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Flush180	28-OCT-16	1.430	ppb
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Flush180	28-OCT-16	0.952	ppb
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Flush180	28-OCT-16	3.800	ppb
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Initial	11-MAY-23	1.000	ug/L
51574	51574-4-420-S02	Main- Inside Culinary Room 420, NE Corner Wall, Si	Initial	28-OCT-16	1.640	ppb
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Flush180	28-OCT-16	1.380	ppb
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Flush180	28-OCT-16	2.770	ppb
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Flush180	28-OCT-16	1.580	ppb
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Flush180	28-OCT-16	2.480	ppb
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Initial	11-MAY-23	1.000	ug/L
51574	51574-4-420-S05	Main- Inside Culinary Room 420, SW Wall, Sink	Initial	28-OCT-16	2.580	ppb
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Flush180	28-OCT-16	2.300	ppb
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Flush180	28-OCT-16	1.190	ppb
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Flush180	28-OCT-16	0.942	ppb
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Flush180	28-OCT-16	4.030	ppb
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Initial	28-OCT-16	4.360	ppb
51574	51574-1-118-S18	Main- Inside Room 118, South Wall Sink	Initial	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS07	Main- Kitchen Isand Sink	Flush180	28-OCT-16	5.020	ppb
51574	51574-1-KIT-KS07	Main- Kitchen Isand Sink	Flush180	28-OCT-16	1.670	ppb
51574	51574-1-KIT-KS07	Main- Kitchen Isand Sink	Flush180	28-OCT-16	0.738	ppb
51574	51574-1-KIT-KS07	Main- Kitchen Isand Sink	Flush180	28-OCT-16	1.500	ppb
51574	51574-1-KIT-KS07	Main- Kitchen Isand Sink	Initial	28-OCT-16	1.570	ppb
51574	51574-1-KIT-KS05	Main- Kitchen N. Triple Basin E. Wall Center Fauc	Flush180	28-OCT-16	0.372	ppb
51574	51574-1-KIT-KS05	Main- Kitchen N. Triple Basin E. Wall Center Fauc	Flush180	28-OCT-16	0.201	ppb
51574	51574-1-KIT-KS05	Main- Kitchen N. Triple Basin E. Wall Center Fauc	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS05	Main- Kitchen N. Triple Basin E. Wall Center Fauc	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS05	Main- Kitchen N. Triple Basin E. Wall Center Fauc	Initial	28-OCT-16	0.460	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51574	51574-1-KIT-KS04	Main- Kitchen N. Triple Basin E. Wall Left Faucet	Flush180	28-OCT-16	1.060	ppb
51574	51574-1-KIT-KS04	Main- Kitchen N. Triple Basin E. Wall Left Faucet	Flush180	28-OCT-16	2.270	ppb
51574	51574-1-KIT-KS04	Main- Kitchen N. Triple Basin E. Wall Left Faucet	Flush180	28-OCT-16	2.130	ppb
51574	51574-1-KIT-KS04	Main- Kitchen N. Triple Basin E. Wall Left Faucet	Flush180	28-OCT-16	1.310	ppb
51574	51574-1-KIT-KS04	Main- Kitchen N. Triple Basin E. Wall Left Faucet	Initial	28-OCT-16	2.440	ppb
51574	51574-1-KIT-KS06	Main- Kitchen N. Triple Basin E. Wall Right Faucet	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS06	Main- Kitchen N. Triple Basin E. Wall Right Faucet	Flush180	28-OCT-16	0.199	ppb
51574	51574-1-KIT-KS06	Main- Kitchen N. Triple Basin E. Wall Right Faucet	Flush180	28-OCT-16	0.200	ppb
51574	51574-1-KIT-KS06	Main- Kitchen N. Triple Basin E. Wall Right Faucet	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS06	Main- Kitchen N. Triple Basin E. Wall Right Faucet	Initial	28-OCT-16	1.700	ppb
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Flush180	28-OCT-16	0.209	ppb
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Flush180	28-OCT-16	0.146	ppb
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Flush180	11-MAY-23	1.630	ug/L
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Flush180	11-MAY-23	1.490	ug/L
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Flush180	11-MAY-23	1.010	ug/L
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Flush180	11-MAY-23	1.950	ug/L
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Initial	28-OCT-16	0.635	ppb
51574	51574-1-KIT-KS09	Main- Kitchen S. Triple Basin E. Wall Center Faucet	Initial	11-MAY-23	3.220	ug/L
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Flush180	28-OCT-16	0.650	ppb
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Flush180	28-OCT-16	0.180	ppb
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Initial	11-MAY-23	3.020	ug/L
51574	51574-1-KIT-KS08	Main- Kitchen S. Triple Basin E. Wall Left Faucet	Initial	28-OCT-16	0.504	ppb
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	13-JUN-23	8.410	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	13-JUN-23	7.390	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	13-JUN-23	4.660	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	13-JUN-23	3.960	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	28-JUL-23	1.610	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	28-JUL-23	1.000	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	28-JUL-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	28-JUL-23	1.000	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	28-OCT-16	0.342	ppb
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	28-OCT-16	0.384	ppb
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	28-OCT-16	0.758	ppb
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	28-OCT-16	0.336	ppb
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	11-MAY-23	3.290	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	11-MAY-23	2.250	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	11-MAY-23	1.460	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Flush180	11-MAY-23	1.180	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Initial	13-JUN-23	8.780	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Initial	28-JUL-23	1.750	ug/L
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Initial	28-OCT-16	3.360	ppb
51574	51574-1-KIT-KS10	Main- Kitchen S. Triple Basin E. Wall Right Faucet	Initial	11-MAY-23	8.280	ug/L
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Flush180	28-OCT-16	0.713	ppb
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Flush180	28-OCT-16	0.321	ppb
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Initial	28-OCT-16	0.592	ppb
51574	51574-1-KIT-KS12	Main- Kitchen Triple Basin N. Wall Divider Center	Initial	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Flush180	28-OCT-16	0.158	ppb
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Flush180	28-OCT-16	0.575	ppb
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Flush180	28-OCT-16	0.675	ppb
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Flush180	28-OCT-16	0.499	ppb
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Initial	28-OCT-16	0.490	ppb
51574	51574-1-KIT-KS11	Main- Kitchen Triple Basin N. Wall Divider Left Fa	Initial	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Flush180	28-OCT-16	0.128	ppb
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-	Main- Kitchen Triple Basin N. Wall	Flush180	11-MAY-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS13	Divider Right F				
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Flush180	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Initial	28-OCT-16	0.353	ppb
51574	51574-1-KIT-KS13	Main- Kitchen Triple Basin N. Wall Divider Right F	Initial	11-MAY-23	1.000	ug/L
51574	51574-1-KIT-KS02	Main- Kitchen Triple Basin S. Wall Divider Center	Flush180	28-OCT-16	0.490	ppb
51574	51574-1-KIT-KS02	Main- Kitchen Triple Basin S. Wall Divider Center	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS02	Main- Kitchen Triple Basin S. Wall Divider Center	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS02	Main- Kitchen Triple Basin S. Wall Divider Center	Flush180	28-OCT-16	1.000	ppb
51574	51574-1-KIT-KS02	Main- Kitchen Triple Basin S. Wall Divider Center	Initial	28-OCT-16	0.433	ppb
51574	51574-1-KIT-KS01	Main- Kitchen Triple Basin S. Wall Divider Left Fa	Flush180	28-OCT-16	0.634	ppb
51574	51574-1-KIT-KS01	Main- Kitchen Triple Basin S. Wall Divider Left Fa	Flush180	28-OCT-16	1.210	ppb
51574	51574-1-KIT-KS01	Main- Kitchen Triple Basin S. Wall Divider Left Fa	Flush180	28-OCT-16	0.807	ppb
51574	51574-1-KIT-KS01	Main- Kitchen Triple Basin S. Wall Divider Left Fa	Flush180	28-OCT-16	0.338	ppb
51574	51574-1-KIT-KS01	Main- Kitchen Triple Basin S. Wall Divider Left Fa	Initial	28-OCT-16	0.546	ppb
51574	51574-1-KIT-KS03	Main- Kitchen Triple Basin S. Wall Divider Right F	Flush180	28-OCT-16	0.679	ppb
51574	51574-1-KIT-KS03	Main- Kitchen Triple Basin S. Wall Divider Right F	Flush180	28-OCT-16	1.020	ppb
51574	51574-1-KIT-KS03	Main- Kitchen Triple Basin S. Wall Divider Right F	Flush180	28-OCT-16	0.176	ppb
51574	51574-1-KIT-KS03	Main- Kitchen Triple Basin S. Wall Divider Right F	Flush180	28-OCT-16	0.163	ppb
51574	51574-1-KIT-KS03	Main- Kitchen Triple Basin S. Wall Divider Right F	Initial	28-OCT-16	1.040	ppb
51574	51574-2-HAL-BF01	Main- Next to Room 209, Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-BF01	Main- Next to Room 209, Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-BF01	Main- Next to Room 209, Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-BF01	Main- Next to Room 209, Bottle Filler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-BF01	Main- Next to Room 209, Bottle Filler	Initial	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Flush180	28-OCT-16	7.010	ppb
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Flush180	28-OCT-16	6.110	ppb
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Flush180	28-OCT-16	7.070	ppb
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Flush180	28-OCT-16	7.260	ppb
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Initial	28-OCT-16	6.820	ppb
51574	51574-2-HAL-WC01	Main- Next to Room 209, Water Cooler	Initial	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-BF01	Next to 414	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-	Next to 414	Flush180	11-MAY-23	1.000	ug/L

Water Quality Assessment AI Raby High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
51574	51574-4-HAL-BF01	Next to 414	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-BF01	Next to 414	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-BF01	Next to 414	Initial	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC02	Next to 414, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC02	Next to 414, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC02	Next to 414, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC02	Next to 414, Water Cooler	Flush180	11-MAY-23	1.000	ug/L
51574	51574-4-HAL-WC02	Next to 414, Water Cooler	Initial	11-MAY-23	1.000	ug/L