



Sep 10, 2024

RAVENSWOOD

4332 N PAULINA ST, Chicago IL 60613.

Dear **RAVENSWOOD** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

RAVENSWOOD

4332 N PAULINA ST, Chicago IL 60613.

Estimadas familias de **RAVENSWOOD**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51070	51070-1-PLG-F01	3-Set Playground Fountains, Left	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F01	3-Set Playground Fountains, Left	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F01	3-Set Playground Fountains, Left	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F01	3-Set Playground Fountains, Left	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F01	3-Set Playground Fountains, Left	Initial	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F02	3-Set Playground Fountains, Middle	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F02	3-Set Playground Fountains, Middle	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F02	3-Set Playground Fountains, Middle	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F02	3-Set Playground Fountains, Middle	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F02	3-Set Playground Fountains, Middle	Initial	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F03	3-Set Playground Fountains, Right	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F03	3-Set Playground Fountains, Right	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F03	3-Set Playground Fountains, Right	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F03	3-Set Playground Fountains, Right	Flush	06-JUN-2024	1.000	ug/L
51070	51070-1-PLG-F03	3-Set Playground Fountains, Right	Initial	06-JUN-2024	1.000	ug/L
51070	51070-2-N-HAL-BF01	Across From Room 309	Flush180	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-BF01	Across From Room 309	Flush180	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-BF01	Across From Room 309	Flush180	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-BF01	Across From Room 309	Flush180	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-BF01	Across From Room 309	Initial	05-FEB-20	1.000	ug/L
51070	51070-B-N-TL-S01	Basement, Teacher's Lounge Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-TL-S01	Basement, Teacher's Lounge Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-TL-S01	Basement, Teacher's Lounge Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-TL-S01	Basement, Teacher's Lounge Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-TL-S01	Basement, Teacher's Lounge Sink	Initial	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-F01	Hallway	Flush180	31-JUL-20	3.150	ug/L
51070	51070-2-N-HAL-F01	Hallway	Initial	31-JUL-20	2.330	ug/L
51070	51070-1-W-HAL-BF02	Main Building, 1st Floor Boy's Bathroom Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-BF02	Main Building, 1st Floor Boy's Bathroom Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-BF02	Main Building, 1st Floor Boy's Bathroom Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-BF02	Main Building, 1st Floor Boy's Bathroom Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-BF02	Main Building, 1st Floor Boy's Bathroom Bottle Filler	Initial	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Flush180	13-SEP-16	1.200	ppb
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Flush180	13-SEP-16	1.150	ppb
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Flush180	13-SEP-16	1.100	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Flush180	13-SEP-16	1.180	ppb
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Initial	13-SEP-16	2.230	ppb
51070	51070-1-W-HAL-F04	Main Building- 1st Floor Across From Room 206 Left	Initial	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Flush180	13-SEP-16	0.724	ppb
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Flush180	13-SEP-16	0.721	ppb
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Flush180	13-SEP-16	0.715	ppb
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Flush180	13-SEP-16	0.703	ppb
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Initial	13-SEP-16	0.744	ppb
51070	51070-1-W-HAL-F03	Main Building- 1st Floor Across From Room 206 Righ	Initial	05-FEB-20	1.000	ug/L
51070	51070-1-HAL-F02	Main Building- 1st Floor Boy's Bathroom Left, Fou	Flush180	13-SEP-16	0.307	ppb
51070	51070-1-HAL-F02	Main Building- 1st Floor Boy's Bathroom Left, Fou	Flush180	13-SEP-16	0.311	ppb
51070	51070-1-HAL-F02	Main Building- 1st Floor Boy's Bathroom Left, Fou	Flush180	13-SEP-16	0.381	ppb
51070	51070-1-HAL-F02	Main Building- 1st Floor Boy's Bathroom Left, Fou	Flush180	13-SEP-16	0.309	ppb
51070	51070-1-HAL-F02	Main Building- 1st Floor Boy's Bathroom Left, Fou	Initial	13-SEP-16	0.728	ppb
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Flush180	13-SEP-16	0.766	ppb
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Flush180	13-SEP-16	0.384	ppb
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Flush180	13-SEP-16	0.547	ppb
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Flush180	13-SEP-16	0.752	ppb
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Initial	13-SEP-16	0.925	ppb
51070	51070-1-W-HAL-F01	Main Building- 1st Floor Boy's Bathroom Right, Fou	Initial	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Flush180	13-SEP-16	0.838	ppb
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Flush180	13-SEP-16	1.910	ppb
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Flush180	13-SEP-16	1.390	ppb
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Flush180	13-SEP-16	1.520	ppb
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Flush180	05-FEB-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Flush180	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Flush180	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Flush180	05-FEB-20	1.000	ug/L
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Initial	13-SEP-16	0.489	ppb
51070	51070-2-N-HAL-F05	Main Building- 2nd Floor Across From Room 309, Fou	Initial	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Flush180	13-SEP-16	0.494	ppb
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Flush180	13-SEP-16	0.531	ppb
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Flush180	13-SEP-16	0.473	ppb
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Flush180	13-SEP-16	0.533	ppb
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Initial	13-SEP-16	0.639	ppb
51070	51070-B-E-HAL-F04	Main Building- BaMain Building-Basement Outside R	Initial	05-FEB-20	1.000	ug/L
51070	51070-B-006-S06	Main Building- Basement Inside Room 006, Sink	Flush180	13-SEP-16	3.510	ppb
51070	51070-B-006-S06	Main Building- Basement Inside Room 006, Sink	Flush180	13-SEP-16	4.570	ppb
51070	51070-B-006-S06	Main Building- Basement Inside Room 006, Sink	Flush180	13-SEP-16	3.580	ppb
51070	51070-B-006-S06	Main Building- Basement Inside Room 006, Sink	Flush180	13-SEP-16	3.690	ppb
51070	51070-B-006-S06	Main Building- Basement Inside Room 006, Sink	Initial	13-SEP-16	2.780	ppb
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Flush180	13-SEP-16	1.160	ppb
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Flush180	13-SEP-16	1.160	ppb
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Flush180	13-SEP-16	1.240	ppb
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Flush180	13-SEP-16	1.180	ppb
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Initial	13-SEP-16	0.645	ppb
51070	51070-B-E-KIT-KS01	Main Building- Basement Kitchen North, Sink	Initial	05-FEB-20	1.000	ug/L
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	13-SEP-16	1.120	ppb
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	13-SEP-16	1.170	ppb
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	13-SEP-16	1.150	ppb
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	13-SEP-16	1.170	ppb
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Flush180	05-FEB-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS02	South, Sink				
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Initial	13-SEP-16	1.580	ppb
51070	51070-B-E-KIT-KS02	Main Building- Basement Kitchen South, Sink	Initial	05-FEB-20	1.210	ug/L
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Flush180	13-SEP-16	1.030	ppb
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Flush180	13-SEP-16	1.020	ppb
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Flush180	13-SEP-16	0.995	ppb
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Flush180	13-SEP-16	1.090	ppb
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Initial	13-SEP-16	0.732	ppb
51070	51070-B-N-HAL-F03	Main Building- Basement Outside Kitchen, Fountain	Initial	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	13-SEP-16	0.590	ppb
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	13-SEP-16	0.540	ppb
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	13-SEP-16	0.544	ppb
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	13-SEP-16	0.552	ppb
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	31-JUL-20	1.110	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	05-FEB-20	23.800	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	03-MAR-20	1.000	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	03-MAR-20	1.000	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Flush180	03-MAR-20	1.000	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Initial	13-SEP-16	0.343	ppb
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Initial	31-JUL-20	1.670	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Initial	05-FEB-20	1.810	ug/L
51070	51070-B-E-HAL-F05	Main Building- Basement Outside Room 004 Right, Fo	Initial	03-MAR-20	1.880	ug/L
51070	51070-B-N-HAL-BF01	Outside Kitchen, Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-HAL-BF01	Outside Kitchen, Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-HAL-BF01	Outside Kitchen, Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-HAL-BF01	Outside Kitchen, Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-B-N-HAL-BF01	Outside Kitchen, Bottle Filler	Initial	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-BF01	Outside Room 206, Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-BF01	Outside Room 206, Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-BF01	Outside Room 206, Bottle Filler	Flush180	05-FEB-20	1.000	ug/L

Water Quality Assessment
Ravenswood Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51070	HAL-BF01					
51070	51070-1-W-HAL-BF01	Outside Room 206, Bottle Filler	Flush180	05-FEB-20	1.000	ug/L
51070	51070-1-W-HAL-BF01	Outside Room 206, Bottle Filler	Initial	05-FEB-20	1.000	ug/L