



**Sep 10, 2024**

**REAVIS**

**834 E 50TH ST, Chicago IL 60615.**

Dear **REAVIS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**REAVIS**

**834 E 50TH ST, Chicago IL 60615.**

Estimadas familias de **REAVIS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51411	51411-1-HAL-F04	1st Floor Outside Washrooms, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F04	1st Floor Outside Washrooms, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F04	1st Floor Outside Washrooms, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F04	1st Floor Outside Washrooms, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F04	1st Floor Outside Washrooms, East Fountain 1	Initial	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F05	1st Floor Outside Washrooms, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F05	1st Floor Outside Washrooms, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F05	1st Floor Outside Washrooms, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F05	1st Floor Outside Washrooms, West Fountain 2	Initial	08-JUN-16	1.000	ppb
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Flush180	28-AUG-20	2.110	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Flush180	28-AUG-20	2.950	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Flush180	28-AUG-20	6.430	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Flush180	28-AUG-20	6.890	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Initial	02-OCT-20	1.000	ug/L
51411	51411-2-W-HAL-BF02	2nd Fl. Next to Boys Bathroom, Bottle Filler	Initial	28-AUG-20	2.100	ug/L
51411	51411-2-W-HAL-WC03	2nd Fl. Next to Boys Bathroom, Left Fountain	Flush180	28-AUG-20	1.090	ug/L
51411	51411-2-W-HAL-WC03	2nd Fl. Next to Boys Bathroom, Left Fountain	Flush180	28-AUG-20	1.350	ug/L
51411	51411-2-W-HAL-WC03	2nd Fl. Next to Boys Bathroom, Left Fountain	Flush180	28-AUG-20	1.040	ug/L
51411	51411-2-W-HAL-WC03	2nd Fl. Next to Boys Bathroom, Left Fountain	Flush180	28-AUG-20	1.160	ug/L
51411	51411-2-W-HAL-WC03	2nd Fl. Next to Boys Bathroom, Left Fountain	Initial	28-AUG-20	1.290	ug/L
51411	51411-2-W-HAL-WC04	2nd Fl. Next to Boys Bathroom, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-2-W-HAL-WC04	2nd Fl. Next to Boys Bathroom, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-2-W-HAL-WC04	2nd Fl. Next to Boys Bathroom, Right Fountain	Flush180	28-AUG-20	1.200	ug/L
51411	51411-2-W-HAL-WC04	2nd Fl. Next to Boys Bathroom, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-2-W-HAL-WC04	2nd Fl. Next to Boys Bathroom, Right Fountain	Initial	28-AUG-20	1.000	ug/L
51411	51411-2-HAL-F07	2nd Floor Outside Boys Bathroom, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F07	2nd Floor Outside Boys Bathroom, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F07	2nd Floor Outside Boys Bathroom, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F07	2nd Floor Outside Boys Bathroom, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F07	2nd Floor Outside Boys Bathroom, East Fountain 1	Initial	08-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51411	51411-2-HAL-F08	2nd Floor Outside Boys Bathroom, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F08	2nd Floor Outside Boys Bathroom, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F08	2nd Floor Outside Boys Bathroom, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F08	2nd Floor Outside Boys Bathroom, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F08	2nd Floor Outside Boys Bathroom, West Fountain 2	Initial	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	28-AUG-20	1.860	ug/L
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Initial	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Initial	28-AUG-20	6.430	ug/L
51411	51411-2-HAL-F05	2nd Floor Outside Girls Bathroom, East Fountain 1	Initial	02-OCT-20	1.000	ug/L
51411	51411-2-HAL-F06	2nd Floor Outside Girls Bathroom, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F06	2nd Floor Outside Girls Bathroom, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F06	2nd Floor Outside Girls Bathroom, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F06	2nd Floor Outside Girls Bathroom, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F06	2nd Floor Outside Girls Bathroom, West Fountain 2	Initial	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F06	Across From Lunchroom, Fountain	Flush180	08-JUN-16	5.660	ppb
51411	51411-1-HAL-F06	Across From Lunchroom, Fountain	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F06	Across From Lunchroom, Fountain	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F06	Across From Lunchroom, Fountain	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F06	Across From Lunchroom, Fountain	Initial	08-JUN-16	7.080	ppb
51411	51411-1-HAL-F11	Across From Main Office, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F11	Across From Main Office, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F11	Across From Main Office, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F11	Across From Main Office, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F11	Across From Main Office, East Fountain 1	Initial	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F12	Across From Main Office, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F12	Across From Main Office, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F12	Across From Main Office, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F12	Across From Main Office, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F12	Across From Main Office, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F12	Across From Main Office, West Fountain 2	Initial	08-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Flush180	07-SEP-23	1.000	ug/L
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Flush180	07-SEP-23	1.000	ug/L
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Flush180	07-SEP-23	1.000	ug/L
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Flush180	07-SEP-23	1.000	ug/L
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Flush180	08-JUN-16	5.850	ppb
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Flush180	08-JUN-16	8.850	ppb
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Initial	07-SEP-23	1.000	ug/L
51411	51411-2-HAL-F03	Across from Room 211, North Fountain 1	Initial	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F04	Across from Room 211, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F04	Across from Room 211, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F04	Across from Room 211, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F04	Across from Room 211, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F04	Across from Room 211, South Fountain 2	Initial	08-JUN-16	1.000	ppb
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Flush180	28-AUG-20	5.110	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Flush180	28-AUG-20	5.100	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Flush180	28-AUG-20	5.760	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Flush180	28-AUG-20	4.640	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Initial	28-AUG-20	4.330	ug/L
51411	51411-1-S-109-BF01	Bottle Filler in Room 109	Initial	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Flush180	28-AUG-20	1.320	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Flush180	28-AUG-20	4.810	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Flush180	28-AUG-20	5.050	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Flush180	28-AUG-20	4.590	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Initial	28-AUG-20	1.000	ug/L
51411	51411-1-S-109-WC01	In Room 108, Drinking Fountain	Initial	02-OCT-20	1.000	ug/L
51411	51411-1-S-109-S01	In Room 108, Sink	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-S-109-S01	In Room 108, Sink	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-S-	In Room 108, Sink	Flush180	28-AUG-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	109-S01					
51411	51411-1-S-109-S01	In Room 108, Sink	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-S-109-S01	In Room 108, Sink	Initial	28-AUG-20	1.000	ug/L
51411	51411-1-102-F07	Inside Room 102, Fountain	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-102-F07	Inside Room 102, Fountain	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-102-F07	Inside Room 102, Fountain	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-151411-1-102-F07	Inside Room 102, Fountain	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-102-F07	Inside Room 102, Fountain	Initial	08-JUN-16	1.000	ppb
51411	51411-1-102-S08	Inside Room 102, Sink	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-102-S08	Inside Room 102, Sink	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-102-S08	Inside Room 102, Sink	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-102-S08	Inside Room 102, Sink	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-102-S08	Inside Room 102, Sink	Initial	08-JUN-16	1.000	ppb
51411	51411-1-KIT-KS01	Kitchen, Sink	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-KIT-KS01	Kitchen, Sink	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-KIT-KS01	Kitchen, Sink	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-KIT-KS01	Kitchen, Sink	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-KIT-KS01	Kitchen, Sink	Initial	08-JUN-16	1.000	ppb
51411	51411-1-S-HAL-WC01	Next to Room 108, Left Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-S-HAL-WC01	Next to Room 108, Left Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-S-HAL-WC01	Next to Room 108, Left Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-S-HAL-WC01	Next to Room 108, Left Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-S-HAL-WC01	Next to Room 108, Left Fountain	Initial	28-AUG-20	1.350	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Flush180	28-AUG-20	9.610	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Flush180	28-AUG-20	11.400	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Flush180	28-AUG-20	11.900	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Flush180	28-AUG-20	13.900	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Initial	28-AUG-20	4.510	ug/L
51411	51411-1-S-HAL-BF01	Next to Room 108, Right Fountain	Initial	02-OCT-20	1.000	ug/L
51411	51411-2-N-HAL-BF01	Next to Room 201, Bottle Filler	Flush180	28-AUG-20	1.620	ug/L
51411	51411-2-N-HAL-BF01	Next to Room 201, Bottle Filler	Flush180	28-AUG-20	2.600	ug/L
51411	51411-2-N-HAL-BF01	Next to Room 201, Bottle Filler	Flush180	28-AUG-20	3.520	ug/L
51411	51411-2-N-HAL-BF01	Next to Room 201, Bottle Filler	Flush180	28-AUG-20	4.090	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51411	51411-2-N-HAL-BF01	Next to Room 201, Bottle Filler	Initial	28-AUG-20	1.000	ug/L
51411	51411-2-N-HAL-WC01	Next to Room 201, Left Fountain	Flush180	28-AUG-20	4.250	ug/L
51411	51411-2-N-HAL-WC01	Next to Room 201, Left Fountain	Flush180	28-AUG-20	2.810	ug/L
51411	51411-2-N-HAL-WC01	Next to Room 201, Left Fountain	Flush180	28-AUG-20	2.960	ug/L
51411	51411-2-N-HAL-WC01	Next to Room 201, Left Fountain	Flush180	28-AUG-20	1.910	ug/L
51411	51411-2-N-HAL-WC01	Next to Room 201, Left Fountain	Initial	28-AUG-20	3.490	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Initial	02-OCT-20	1.000	ug/L
51411	51411-2-N-HAL-WC02	Next to Room 201, Right Fountain	Initial	28-AUG-20	1.000	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Flush180	28-AUG-20	9.010	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Flush180	28-AUG-20	7.310	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Flush180	28-AUG-20	6.270	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Flush180	28-AUG-20	5.440	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Flush180	02-OCT-20	1.000	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Initial	28-AUG-20	10.400	ug/L
51411	51411-1-S-HAL-WC02	Next to room 108, right fountain	Initial	02-OCT-20	1.000	ug/L
51411	51411-1-HAL-F09	Outside Room 109, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F09	Outside Room 109, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F09	Outside Room 109, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F09	Outside Room 109, East Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F09	Outside Room 109, East Fountain 1	Initial	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F10	Outside Room 109, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F10	Outside Room 109, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F10	Outside Room 109, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F10	Outside Room 109, West Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F10	Outside Room 109, West Fountain 2	Initial	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F01	Outside Room 218, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-	Outside Room 218, North Fountain	Flush180	08-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	1				
51411	51411-2-HAL-F01	Outside Room 218, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F01	Outside Room 218, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F01	Outside Room 218, North Fountain 1	Initial	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F02	Outside Room 218, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F02	Outside Room 218, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F02	Outside Room 218, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F02	Outside Room 218, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-2-HAL-F02	Outside Room 218, South Fountain 2	Initial	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	07-SEP-23	2.000	ug/L
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	07-SEP-23	1.070	ug/L
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	07-SEP-23	1.040	ug/L
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	07-SEP-23	1.110	ug/L
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	12-AUG-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	15-NOV-16	3.080	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	15-NOV-16	2.530	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	15-NOV-16	2.220	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	12-AUG-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	12-AUG-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	12-AUG-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	15-NOV-16	1.990	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Initial	07-SEP-23	2.810	ug/L
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Initial	08-JUN-16	16.400	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Initial	15-NOV-16	5.500	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Initial	12-AUG-16	1.000	ppb
51411	51411-1-HAL-F02	Outside Room 8, North Fountain 1	Initial	28-AUG-20	16.000	ug/L
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Flush180	07-SEP-23	1.300	ug/L
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Flush180	07-SEP-23	1.320	ug/L
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Flush180	07-SEP-23	3.900	ug/L
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Flush180	07-SEP-23	11.100	ug/L
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Flush180	08-JUN-16	1.000	ppb
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Flush180	08-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Flush180	08-JUN-16	5.490	ppb
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Initial	07-SEP-23	4.330	ug/L
51411	51411-1-HAL-F03	Outside Room 8, South Fountain 2	Initial	08-JUN-16	1.000	ppb
51411	51411-1-N-HAL-BF02	Outside of Gym, Bottle Filler	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-BF02	Outside of Gym, Bottle Filler	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-BF02	Outside of Gym, Bottle Filler	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-BF02	Outside of Gym, Bottle Filler	Flush180	28-AUG-20	1.120	ug/L
51411	51411-1-N-HAL-BF02	Outside of Gym, Bottle Filler	Initial	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC03	Outside of Gym, Left Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC03	Outside of Gym, Left Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC03	Outside of Gym, Left Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC03	Outside of Gym, Left Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC03	Outside of Gym, Left Fountain	Initial	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC04	Outside of Gym, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC04	Outside of Gym, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC04	Outside of Gym, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC04	Outside of Gym, Right Fountain	Flush180	28-AUG-20	1.000	ug/L
51411	51411-1-N-HAL-WC04	Outside of Gym, Right Fountain	Initial	28-AUG-20	1.000	ug/L
51411	51411-1-W-TL-S01	Sink in Teachers Lounge	Flush180	28-AUG-20	2.230	ug/L
51411	51411-1-W-TL-S01	Sink in Teachers Lounge	Flush180	28-AUG-20	2.310	ug/L
51411	51411-1-W-TL-S01	Sink in Teachers Lounge	Flush180	28-AUG-20	2.150	ug/L
51411	51411-1-W-TL-S01	Sink in Teachers Lounge	Flush180	28-AUG-20	2.200	ug/L
51411	51411-1-W-TL-S01	Sink in Teachers Lounge	Initial	28-AUG-20	2.450	ug/L