



Sep 10, 2024

REILLY

3650 W SCHOOL ST, Chicago IL 60618.

Dear **REILLY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

REILLY

3650 W SCHOOL ST, Chicago IL 60618.

Estimadas familias de **REILLY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	08-JUN-16	3.400	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	16-NOV-16	0.733	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	16-NOV-16	0.665	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	16-NOV-16	0.703	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	16-NOV-16	0.723	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	27-MAY-16	0.092	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	27-MAY-16	1.970	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	27-MAY-16	28.300	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	27-MAY-16	6.300	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	08-JUN-16	4.090	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	08-JUN-16	4.830	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Flush180	08-JUN-16	3.580	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Initial	08-JUN-16	6.720	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Initial	16-NOV-16	0.740	ppb
50301	50301-1-HAL-F01	Modular 2 Entry, North Fountain	Initial	27-MAY-16	63.700	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Flush180	03-MAY-18	0.370	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Flush180	03-MAY-18	2.070	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Flush180	07-JUN-16	4.200	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Flush180	07-JUN-16	3.710	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Flush180	07-JUN-16	3.040	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Flush180	07-JUN-16	4.000	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Flush180	03-MAY-18	0.232	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Flush180	03-MAY-18	0.269	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Initial	07-JUN-16	7.190	ppb
50301	50301-1-HAL-F02	Modular 2 Entry, South Fountain	Initial	03-MAY-18	3.760	ppb
51030	51030-1-E-111-S01	1st Floor, East End, Room 111	Flush180	01-SEP-19	1.080	ug/L
51030	51030-1-E-111-S01	1st Floor, East End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-E-111-S01	1st Floor, East End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-E-111-S01	1st Floor, East End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-E-111-S01	1st Floor, East End, Room 111	Initial	01-SEP-19	3.830	ug/L
51030	51030-1-N-111-S02	1st Floor, North End, Room 111	Flush180	01-SEP-19	1.030	ug/L
51030	51030-1-N-111-S02	1st Floor, North End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-N-111-S02	1st Floor, North End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-N-111-S02	1st Floor, North End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-N-111-S02	1st Floor, North End, Room 111	Initial	01-SEP-19	4.460	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51030	51030-1-W-111-DF01	1st Floor, West End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-W-111-DF01	1st Floor, West End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-W-111-DF01	1st Floor, West End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-W-111-DF01	1st Floor, West End, Room 111	Flush180	01-SEP-19	1.000	ug/L
51030	51030-1-W-111-DF01	1st Floor, West End, Room 111	Flush180	06-AUG-20	1.000	ug/L
51030	51030-1-W-111-DF01	1st Floor, West End, Room 111	Initial	01-SEP-19	1.120	ug/L
51030	51030-1-W-111-DF01	1st Floor, West End, Room 111	Initial	06-AUG-20	4.520	ug/L
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	16-NOV-16	0.859	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	16-NOV-16	0.717	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	27-MAY-16	915.00	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	27-MAY-16	64.900	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	27-MAY-16	541.00	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	27-MAY-16	1930.00	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	08-JUN-16	30.500	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	08-JUN-16	46.000	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	08-JUN-16	22.000	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	08-JUN-16	340.00	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	16-NOV-16	0.828	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Flush180	16-NOV-16	0.588	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Initial	27-MAY-16	1390.00	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Initial	08-JUN-16	34.100	ppb
51030	51030-1-W-HAL-F03	Main, Outside Rm 103, North Fountain	Initial	16-NOV-16	0.909	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	27-MAY-16	818.00	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	27-MAY-16	1270.00	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	27-MAY-16	962.00	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	27-MAY-16	1030.00	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	08-JUN-16	3.920	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	08-JUN-16	9.690	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	08-JUN-16	16.400	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	08-JUN-16	6.050	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	16-NOV-16	0.342	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	16-NOV-16	0.345	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	16-NOV-16	0.355	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	16-NOV-16	0.341	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	26-MAR-19	1.180	ug/L
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	26-MAR-19	1.460	ug/L
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	26-MAR-19	1.620	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Flush180	26-MAR-19	1.710	ug/L
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Initial	27-MAY-16	9200.000	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Initial	08-JUN-16	8.540	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Initial	16-NOV-16	0.492	ppb
51030	51030-1-W-HAL-F04	Main, Outside Rm 103, South Fountain	Initial	26-MAR-19	1.000	ug/L
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	27-MAY-16	25.700	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	27-MAY-16	33.800	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	27-MAY-16	46.200	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	27-MAY-16	55.800	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	08-JUN-16	11.500	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	08-JUN-16	6.740	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	08-JUN-16	26.200	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	16-NOV-16	0.217	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	16-NOV-16	0.389	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	08-JUN-16	46.600	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	16-NOV-16	0.466	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	16-NOV-16	1.000	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	26-MAR-19	1.300	ug/L
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Flush180	26-MAR-19	1.310	ug/L
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Initial	27-MAY-16	76.600	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Initial	08-JUN-16	548.000	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Initial	16-NOV-16	0.231	ppb
51030	51030-1-E-HAL-F01	Main, Outside Rm 104, North Fountain	Initial	26-MAR-19	1.000	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	16-NOV-16	0.449	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	16-NOV-16	0.431	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	16-NOV-16	0.457	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	16-NOV-16	0.451	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	08-JUN-16	3.070	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	08-JUN-16	2.600	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	08-JUN-16	5.020	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	08-JUN-16	5.740	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	27-MAY-16	73.900	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	27-MAY-16	86.700	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	27-MAY-16	29.300	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	27-MAY-16	66.900	ppb
51030	51030-1-E-	Main, Outside Rm 104, South	Flush180	26-MAR-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Fountain				
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	06-AUG-20	7.380	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	13-OCT-20	2.650	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	13-OCT-20	2.000	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	13-OCT-20	1.490	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Flush180	13-OCT-20	1.000	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Initial	16-NOV-16	0.557	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Initial	08-JUN-16	17.100	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Initial	27-MAY-16	72.000	ppb
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Initial	26-MAR-19	1.000	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Initial	06-AUG-20	4.350	ug/L
51030	51030-1-E-HAL-F02	Main, Outside Rm 104, South Fountain	Initial	13-OCT-20	3.500	ug/L
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	27-MAY-16	598.000	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	27-MAY-16	795.000	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	27-MAY-16	925.000	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	27-MAY-16	560.000	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	08-JUN-16	0.235	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	08-JUN-16	1.290	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	08-JUN-16	0.406	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	08-JUN-16	0.343	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	16-NOV-16	0.240	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	16-NOV-16	0.192	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	16-NOV-16	0.160	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	16-NOV-16	0.195	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Initial	27-MAY-16	4220.000	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Initial	08-JUN-16	0.971	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Initial	16-NOV-16	0.783	ppb
51030	51030-2-E-HAL-F02	Main, Outside Rm 204, Center Fountain	Initial	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	16-NOV-16	1.000	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	16-NOV-16	0.166	ppb
51030	51030-2-E-	Main, Outside Rm 204, Fountain	Flush180	16-NOV-16	0.129	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01					
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	16-NOV-16	1.000	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	08-JUN-16	1.340	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	08-JUN-16	2.400	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	27-MAY-16	7.390	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	27-MAY-16	3.710	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	27-MAY-16	9.980	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	27-MAY-16	11.600	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	08-JUN-16	1.480	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	08-JUN-16	1.790	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Initial	16-NOV-16	0.231	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Initial	08-JUN-16	8.530	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Initial	27-MAY-16	26.300	ppb
51030	51030-2-E-HAL-F01	Main, Outside Rm 204, Fountain	Initial	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	16-NOV-16	0.789	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	16-NOV-16	0.809	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	08-JUN-16	1.190	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	08-JUN-16	0.777	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	08-JUN-16	1.040	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	16-NOV-16	0.481	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	16-NOV-16	0.677	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	27-MAY-16	39.100	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	27-MAY-16	26.500	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	27-MAY-16	25.100	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	27-MAY-16	21.900	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	08-JUN-16	0.957	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Initial	08-JUN-16	2.950	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Initial	27-MAY-16	37.000	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Initial	16-NOV-16	0.382	ppb
51030	51030-3-W-HAL-F03	Main, Outside Rm 303, Fountain	Initial	26-MAR-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	27-MAY-16	21.100	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	27-MAY-16	16.600	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	08-JUN-16	0.539	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	08-JUN-16	0.770	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	08-JUN-16	0.994	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	08-JUN-16	1.140	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	16-NOV-16	0.932	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	16-NOV-16	1.490	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	16-NOV-16	1.220	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	16-NOV-16	5.720	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	27-MAY-16	30.000	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	27-MAY-16	20.600	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Initial	27-MAY-16	32.400	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Initial	08-JUN-16	1.160	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Initial	16-NOV-16	0.607	ppb
51030	51030-3-E-HAL-F01	Main, Outside Rm 304, Fountain	Initial	26-MAR-19	1.220	ug/L
51030	51030-2-W-HAL-F05	Next to room 203	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F05	Next to room 203	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F05	Next to room 203	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F05	Next to room 203	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F05	Next to room 203	Initial	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F06	Next to room 203	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F06	Next to room 203	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F06	Next to room 203	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F06	Next to room 203	Initial	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F04	Next to room 203, left fountain.	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F04	Next to room 203, left fountain.	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F04	Next to room 203, left fountain.	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-W-HAL-F04	Next to room 203, left fountain.	Initial	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F03	Outside 204, third fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F03	Outside 204, third fountain	Flush180	26-MAR-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51030	51030-2-E-HAL-F03	Outside 204, third fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F03	Outside 204, third fountain	Flush180	26-MAR-19	1.000	ug/L
51030	51030-2-E-HAL-F03	Outside 204, third fountain	Initial	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F04	Outside of room 303	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F04	Outside of room 303	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F04	Outside of room 303	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F04	Outside of room 303	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-W-HAL-F04	Outside of room 303	Initial	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Flush180	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Initial	26-MAR-19	1.000	ug/L
51030	51030-3-E-HAL-F02	Outside of room 304	Initial	26-MAR-19	1.000	ug/L
51030	51030-1-HAL-BF01	outside room 104	Flush180	22-JAN-21	1.000	ug/L
51030	51030-1-HAL-BF01	outside room 104	Flush180	22-JAN-21	1.000	ug/L
51030	51030-1-HAL-BF01	outside room 104	Flush180	22-JAN-21	1.000	ug/L
51030	51030-1-HAL-BF01	outside room 104	Flush180	22-JAN-21	1.000	ug/L
51030	51030-1-HAL-BF01	outside room 104	Initial	22-JAN-21	1.000	ug/L
53001	53001-2-W-228-S01	228	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-228-S01	228	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-228-S01	228	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-228-S01	228	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-228-S01	228	Initial	26-MAR-19	1.140	ug/L
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	27-MAY-16	0.145	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	16-NOV-16	1.000	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	16-NOV-16	0.138	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	16-NOV-16	0.125	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	16-NOV-16	1.000	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	27-MAY-16	0.717	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	08-JUN-16	10.600	ppb
53001	53001-1-S-	Annex Kindergarden Rm 114, Sink	Flush180	08-JUN-16	6.160	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	114-S01					
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	08-JUN-16	0.960	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	08-JUN-16	9.720	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Initial	27-MAY-16	1.000	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Initial	16-NOV-16	0.423	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Initial	08-JUN-16	22.600	ppb
53001	53001-1-S-114-S01	Annex Kindergarden Rm 114, Sink	Initial	26-MAR-19	1.000	ug/L
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	27-MAY-16	1.020	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	27-MAY-16	0.502	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	27-MAY-16	0.209	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	27-MAY-16	0.228	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	08-JUN-16	5.480	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	08-JUN-16	11.500	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	08-JUN-16	12.400	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	08-JUN-16	13.500	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	16-NOV-16	2.430	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	16-NOV-16	1.400	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	16-NOV-16	3.510	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	16-NOV-16	1.720	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Initial	27-MAY-16	0.907	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Initial	08-JUN-16	354.000	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Initial	16-NOV-16	1.400	ppb
53001	53001-1-S-112-S01	Annex Kindergraden Rm 112, Sink	Initial	26-MAR-19	1.100	ug/L
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	08-JUN-16	1.570	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	27-MAY-16	0.130	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	08-JUN-16	0.918	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	08-JUN-16	1.530	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	08-JUN-16	6.650	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	16-NOV-16	0.220	ppb
53001	53001-1-S-	Annex kindergarden Rm113, Sink	Flush180	16-NOV-16	0.234	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	113-S01					
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	16-NOV-16	0.190	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	16-NOV-16	0.360	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	27-MAY-16	0.123	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	27-MAY-16	0.120	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	27-MAY-16	0.132	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	26-MAR-19	1.320	ug/L
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Initial	08-JUN-16	148.00 0	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Initial	16-NOV-16	0.639	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Initial	27-MAY-16	0.481	ppb
53001	53001-1-S-113-S01	Annex kindergarden Rm113, Sink	Initial	26-MAR-19	1.000	ug/L
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	08-JUN-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	08-JUN-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	08-JUN-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	08-JUN-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Flush180	08-JUN-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Initial	27-MAY-16	1.000	ppb
53001	53001-1-KIT-KS06	Annex, In Kitchen, Fountain	Initial	08-JUN-16	1.000	ppb
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	04-MAY-18	1.140	ppb
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	04-MAY-18	1.380	ppb
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	04-MAY-18	0.560	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	08-JUN-16	6.500	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	08-JUN-16	8.430	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	08-JUN-16	11.000	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	08-JUN-16	13.900	ppb
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	27-MAY-16	1.000	ppb
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	27-MAY-16	1.130	ppb
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	27-MAY-16	1.530	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	27-MAY-16	2.090	ppb
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	04-MAY-18	0.746	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.350	ug/L
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.120	ug/L
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.110	ug/L
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Initial	04-MAY-18	0.460	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Initial	27-MAY-16	1.000	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Initial	08-JUN-16	2.320	ppb
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Initial	27-MAY-16	2.590	ppb
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Initial	26-MAR-19	1.000	ug/L
53001	53001-1-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Initial	26-MAR-19	1.000	ug/L
53001	53001-2-W-HAL-F01	Annex, Outside Bathrooms, Fountain	Initial	26-MAR-19	1.000	ug/L
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	08-JUN-16	2.210	ppb
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	08-JUN-16	1.990	ppb
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	08-JUN-16	1.590	ppb
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	08-JUN-16	1.420	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	27-MAY-16	1.000	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	27-MAY-16	1.000	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	27-MAY-16	1.000	ppb
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	27-MAY-16	1.000	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	27-MAY-16	1.000	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	08-JUN-16	4.310	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	08-JUN-16	6.640	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	08-JUN-16	6.040	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	08-JUN-16	3.850	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Initial	08-JUN-16	1.230	ppb
53001	53001-1-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Initial	27-MAY-16	1.000	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Initial	27-MAY-16	1.000	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Initial	08-JUN-16	3.220	ppb
53001	53001-2-W-HAL-F02	Annex, Outside Bathrooms, Fountain 2	Initial	26-MAR-19	1.000	ug/L
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	08-JUN-16	0.600	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	08-JUN-16	0.416	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	27-MAY-16	0.234	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	27-MAY-16	0.227	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	27-MAY-16	0.814	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	27-MAY-16	0.272	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	08-JUN-16	0.259	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	08-JUN-16	0.447	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Initial	27-MAY-16	1.350	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Initial	08-JUN-16	1.440	ppb
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Initial	26-MAR-19	1.250	ug/L
53001	53001-2-W-224-S01	Annex, Rm 224, Sink	Initial	26-MAR-19	1.000	ug/L
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	27-MAY-16	2.490	ppb
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	27-MAY-16	0.228	ppb
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	27-MAY-16	0.213	ppb
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	27-MAY-16	0.218	ppb
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	08-JUN-16	0.247	ppb
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	08-JUN-16	0.159	ppb
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	08-JUN-16	0.158	ppb
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	08-JUN-16	0.116	ppb
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Initial	27-MAY-16	0.230	ppb
53001	53001-2-E-	Annex, Rm 225, Sink	Initial	08-JUN-16	0.748	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	225-S01					
53001	53001-2-E-225-S01	Annex, Rm 225, Sink	Initial	26-MAR-19	1.360	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	08-JUN-16	0.547	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	27-MAY-16	0.770	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	27-MAY-16	0.722	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	27-MAY-16	0.631	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	27-MAY-16	1.880	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	08-JUN-16	0.579	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	08-JUN-16	0.607	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	08-JUN-16	1.230	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	26-MAR-19	2.650	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	26-MAR-19	1.960	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	26-MAR-19	2.080	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	26-MAR-19	2.230	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	16-APR-20	1.000	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	16-APR-20	1.390	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	16-APR-20	1.380	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Flush180	16-APR-20	1.130	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Initial	08-JUN-16	3.020	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Initial	27-MAY-16	0.723	ppb
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Initial	26-MAR-19	9.570	ug/L
53001	53001-2-E-226-S01	Annex, Rm 226, Sink	Initial	16-APR-20	2.600	ug/L
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	08-JUN-16	0.173	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	08-JUN-16	0.230	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	08-JUN-16	0.191	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	08-JUN-16	0.189	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	27-MAY-16	0.207	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	27-MAY-16	0.204	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	27-MAY-16	0.196	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	27-MAY-16	2.060	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Initial	08-JUN-16	1.640	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Initial	27-MAY-16	0.244	ppb
53001	53001-2-W-229-S01	Annex, Rm 229, Sink	Initial	26-MAR-19	1.620	ug/L
53001	53001-1-W-	Annex, Teachers Lounge, Sink	Flush180	08-JUN-16	0.361	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	TL-S01					
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	08-JUN-16	0.514	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	08-JUN-16	1.400	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	08-JUN-16	16.500	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	16-NOV-16	0.532	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	16-NOV-16	0.323	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	16-NOV-16	0.183	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	16-NOV-16	0.173	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Flush180	26-MAR-19	1.000	ug/L
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Initial	08-JUN-16	11.800	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Initial	16-NOV-16	1.140	ppb
53001	53001-1-W-TL-S01	Annex, Teachers Lounge, Sink	Initial	26-MAR-19	1.000	ug/L
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	27-MAY-16	13.700	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	27-MAY-16	26.700	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	16-NOV-16	0.739	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	16-NOV-16	0.588	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	27-MAY-16	6.600	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	08-JUN-16	3.750	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	08-JUN-16	2.690	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	08-JUN-16	3.090	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	08-JUN-16	13.400	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	16-NOV-16	0.238	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	16-NOV-16	1.000	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Flush180	27-MAY-16	34.300	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Initial	27-MAY-16	1.760	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Initial	08-JUN-16	7.440	ppb
53865	53865-1-HAL-F01	Modular 1 Entry, North Fountain	Initial	16-NOV-16	0.191	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Flush180	08-JUN-16	2.140	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Flush180	03-MAY-18	10.900	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Flush180	03-MAY-18	11.000	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Flush180	03-MAY-18	11.300	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Flush180	03-MAY-18	11.100	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Flush180	08-JUN-16	2.090	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Flush180	08-JUN-16	3.200	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Flush180	08-JUN-16	2.340	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Initial	03-MAY-18	3.620	ppb
53865	53865-1-HAL-F02	Modular 1 Entry, South Fountain	Initial	08-JUN-16	3.920	ppb
53865	53865-1-HAL-BF01	North Module, Bottle Filler	Flush	15-MAR-2024	1.020	ug/L
53865	53865-1-HAL-BF01	North Module, Bottle Filler	Flush	15-MAR-2024	1.120	ug/L
53865	53865-1-HAL-BF01	North Module, Bottle Filler	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-BF01	North Module, Bottle Filler	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-BF01	North Module, Bottle Filler	Initial	15-MAR-2024	1.340	ug/L
53865	53865-1-HAL-F06	North Module, Left Fountain	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-F06	North Module, Left Fountain	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-F06	North Module, Left Fountain	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-F06	North Module, Left Fountain	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-F06	North Module, Left Fountain	Initial	15-MAR-2024	1.030	ug/L
53865	53865-1-HAL-F05	North Module, Right Fountain	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-F05	North Module, Right Fountain	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-F05	North Module, Right Fountain	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-F05	North Module, Right Fountain	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-F05	North Module, Right Fountain	Initial	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-BF02	South Module, Bottle Filler	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-BF02	South Module, Bottle Filler	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-BF02	South Module, Bottle Filler	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-BF02	South Module, Bottle Filler	Flush	15-MAR-2024	1.000	ug/L
53865	53865-1-HAL-BF02	South Module, Bottle Filler	Initial	15-MAR-2024	1.090	ug/L
53865	53865-1-HAL-F04	South Module, Left Fountain	Flush	15-MAR-2024	1.480	ug/L
53865	53865-1-HAL-F04	South Module, Left Fountain	Flush	15-MAR-2024	1.440	ug/L
53865	53865-1-HAL-F04	South Module, Left Fountain	Flush	15-MAR-2024	1.520	ug/L
53865	53865-1-HAL-F04	South Module, Left Fountain	Flush	15-MAR-2024	1.500	ug/L
53865	53865-1-HAL-F04	South Module, Left Fountain	Initial	15-MAR-2024	1.500	ug/L
53865	53865-1-HAL-F03	South Module, Right Fountain	Flush	15-MAR-2024	1.330	ug/L
53865	53865-1-HAL-F03	South Module, Right Fountain	Flush	15-MAR-2024	1.380	ug/L
53865	53865-1-HAL-F03	South Module, Right Fountain	Flush	15-MAR-2024	1.330	ug/L
53865	53865-1-HAL-F03	South Module, Right Fountain	Flush	15-MAR-2024	1.500	ug/L
53865	53865-1-HAL-F03	South Module, Right Fountain	Initial	15-MAR-2024	1.520	ug/L