



Sep 10, 2024

REINBERG

3425 N MAJOR AVE, Chicago IL 60634.

Dear **REINBERG** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

REINBERG

3425 N MAJOR AVE, Chicago IL 60634.

Estimadas familias de **REINBERG**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51031	51031-2-HAL-F02	Main- Fountain 1 Across From 204	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F02	Main- Fountain 1 Across From 204	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F02	Main- Fountain 1 Across From 204	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F02	Main- Fountain 1 Across From 204	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F02	Main- Fountain 1 Across From 204	Initial	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F01	Main- Fountain 1 Across From Room 304	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F01	Main- Fountain 1 Across From Room 304	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F01	Main- Fountain 1 Across From Room 304	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F01	Main- Fountain 1 Across From Room 304	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F01	Main- Fountain 1 Across From Room 304	Initial	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	04-FEB-21	19.600	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	04-FEB-21	11.600	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	04-FEB-21	2.470	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	04-FEB-21	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	26-FEB-21	8.160	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	26-FEB-21	2.830	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	26-FEB-21	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	26-FEB-21	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	06-JAN-21	13.300	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	06-JAN-21	3.820	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	06-JAN-21	2.580	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	06-JAN-21	1.300	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	09-OCT-20	2.370	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	09-OCT-20	3.200	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	23-SEP-20	1.430	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	09-OCT-20	1.590	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	09-OCT-20	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	30-DEC-20	6.300	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	30-DEC-20	1.310	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	30-DEC-20	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	30-DEC-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	25-JUL-23	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	25-JUL-23	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	25-JUL-23	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Flush180	25-JUL-23	1.000	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Initial	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Initial	04-FEB-21	16.800	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Initial	26-FEB-21	5.570	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Initial	06-JAN-21	9.010	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Initial	09-OCT-20	11.500	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Initial	23-SEP-20	9.250	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Initial	30-DEC-20	3.720	ug/L
51031	51031-1-HAL-F02	Main- Fountain 1 Outside Main Office	Initial	25-JUL-23	1.000	ug/L
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	23-SEP-20	2.510	ug/L
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	09-OCT-20	1.000	ug/L
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	09-OCT-20	1.000	ug/L
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	09-OCT-20	1.370	ug/L
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Flush180	09-OCT-20	1.070	ug/L
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Initial	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Initial	23-SEP-20	6.260	ug/L
51031	51031-3-HAL-F03	Main- Fountain 1 Outside Room 310	Initial	09-OCT-20	1.200	ug/L
51031	51031-2-HAL-F03	Main- Fountain 2 Across From 204	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F03	Main- Fountain 2 Across From 204	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F03	Main- Fountain 2 Across From 204	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F03	Main- Fountain 2 Across From 204	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F03	Main- Fountain 2 Across From 204	Initial	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F02	Main- Fountain 2 Across From 304	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F02	Main- Fountain 2 Across From 304	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F02	Main- Fountain 2 Across From 304	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F02	Main- Fountain 2 Across From 304	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F02	Main- Fountain 2 Across From 304	Initial	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F03	Main- Fountain 2 Outside Main Office	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F03	Main- Fountain 2 Outside Main Office	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F03	Main- Fountain 2 Outside Main Office	Flush180	28-MAY-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51031	51031-1-HAL-F03	Main- Fountain 2 Outside Main Office	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F03	Main- Fountain 2 Outside Main Office	Initial	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F04	Main- Fountain 2 Outside Room 310	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F04	Main- Fountain 2 Outside Room 310	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F04	Main- Fountain 2 Outside Room 310	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F04	Main- Fountain 2 Outside Room 310	Flush180	28-MAY-16	1.000	ppb
51031	51031-3-HAL-F04	Main- Fountain 2 Outside Room 310	Initial	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F09	Main- Fountain Outside Room 110	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F09	Main- Fountain Outside Room 110	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F09	Main- Fountain Outside Room 110	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F09	Main- Fountain Outside Room 110	Initial	28-MAY-16	1.000	ppb
51031	51031-1-KIT-KS05	Main- Kitchen Sink	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-KIT-KS05	Main- Kitchen Sink	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-KIT-KS05	Main- Kitchen Sink	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-KIT-KS05	Main- Kitchen Sink	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-KIT-KS05	Main- Kitchen Sink	Flush180	06-JAN-21	1.000	ug/L
51031	51031-1-KIT-KS05	Main- Kitchen Sink	Initial	28-MAY-16	1.000	ppb
51031	51031-1-KIT-KS05	Main- Kitchen Sink	Initial	06-JAN-21	1.000	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	25-JUL-23	1.220	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	25-JUL-23	1.000	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	25-JUL-23	1.000	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	25-JUL-23	1.000	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	30-DEC-20	7.800	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	30-DEC-20	9.450	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	04-FEB-21	15.600	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	04-FEB-21	10.900	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	04-FEB-21	8.460	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	04-FEB-21	7.370	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	26-FEB-21	4.650	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	26-FEB-21	8.920	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	26-FEB-21	11.100	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	26-FEB-21	14.000	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	06-JAN-21	5.710	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Fountain				
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	06-JAN-21	6.380	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	06-JAN-21	3.950	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	06-JAN-21	3.620	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	23-SEP-20	41.600	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	23-SEP-20	29.600	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	23-SEP-20	19.200	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	09-OCT-20	42.800	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	09-OCT-20	25.100	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	09-OCT-20	28.000	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	09-OCT-20	37.500	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	23-SEP-20	62.100	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	30-DEC-20	10.400	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Flush180	30-DEC-20	20.300	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Initial	25-JUL-23	1.350	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Initial	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Initial	04-FEB-21	27.800	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Initial	26-FEB-21	7.410	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Initial	06-JAN-21	12.600	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Initial	09-OCT-20	114.000	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Initial	23-SEP-20	10.800	ug/L
51031	51031-2-HAL-F04	Main- Outside Room 210, Left Fountain	Initial	30-DEC-20	9.380	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	25-JUL-23	2.080	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	25-JUL-23	1.300	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	25-JUL-23	1.260	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	25-JUL-23	1.290	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	30-DEC-20	10.500	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	30-DEC-20	6.050	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	30-DEC-20	2.930	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	30-DEC-20	1.000	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	04-FEB-21	9.000	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	04-FEB-21	11.000	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	04-FEB-21	6.030	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	04-FEB-21	4.660	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Fountain				
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	26-FEB-21	17.200	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	26-FEB-21	11.600	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	26-FEB-21	8.730	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	26-FEB-21	5.650	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	06-JAN-21	5.440	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	06-JAN-21	3.130	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	06-JAN-21	1.810	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	06-JAN-21	1.300	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	23-SEP-20	7.900	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	23-SEP-20	6.480	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	23-SEP-20	7.410	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	23-SEP-20	9.090	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	09-OCT-20	9.070	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	09-OCT-20	8.960	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	09-OCT-20	8.360	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Flush180	09-OCT-20	8.140	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Initial	25-JUL-23	2.920	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Initial	28-MAY-16	1.000	ppb
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Initial	30-DEC-20	10.200	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Initial	04-FEB-21	9.730	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Initial	26-FEB-21	60.200	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Initial	06-JAN-21	4.720	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Initial	23-SEP-20	7.780	ug/L
51031	51031-2-HAL-F05	Main- Outside Room 210, Right Fountain	Initial	09-OCT-20	11.500	ug/L
51031	51031-1-107-S06	Main- Sink 1 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S06	Main- Sink 1 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S06	Main- Sink 1 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S06	Main- Sink 1 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S06	Main- Sink 1 Inside Room 107	Initial	28-MAY-16	1.000	ppb
51031	51031-1-107-S07	Main- Sink 2 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S07	Main- Sink 2 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S07	Main- Sink 2 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S07	Main- Sink 2 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S07	Main- Sink 2 Inside Room 107	Initial	28-MAY-16	1.000	ppb
51031	51031-1-107-S08	Main- Sink 3 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S08	Main- Sink 3 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S08	Main- Sink 3 Inside Room 107	Flush180	28-MAY-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51031	51031-1-107-S08	Main- Sink 3 Inside Room 107	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-107-S08	Main- Sink 3 Inside Room 107	Initial	28-MAY-16	1.000	ppb
51031	51031-2--TL-S01	Main- Sink Inside Teachers Lounge	Flush180	28-MAY-16	1.000	ppb
51031	51031-2--TL-S01	Main- Sink Inside Teachers Lounge	Flush180	28-MAY-16	1.000	ppb
51031	51031-2--TL-S01	Main- Sink Inside Teachers Lounge	Flush180	28-MAY-16	1.000	ppb
51031	51031-2--TL-S01	Main- Sink Inside Teachers Lounge	Flush180	28-MAY-16	1.000	ppb
51031	51031-2--TL-S01	Main- Sink Inside Teachers Lounge	Initial	28-MAY-16	1.000	ppb
51031	51031-1-HAL-S10	Main- Sink Outside Room 110	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-S10	Main- Sink Outside Room 110	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-S10	Main- Sink Outside Room 110	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-S10	Main- Sink Outside Room 110	Flush180	28-MAY-16	1.000	ppb
51031	51031-1-HAL-S10	Main- Sink Outside Room 110	Initial	28-MAY-16	1.000	ppb
51031	51031-1-HAL-F01	Main-Fountain 2 Outside Main Office, Right	Flush180	25-JUL-23	1.000	ug/L
51031	51031-1-HAL-F01	Main-Fountain 2 Outside Main Office, Right	Flush180	25-JUL-23	1.000	ug/L
51031	51031-1-HAL-F01	Main-Fountain 2 Outside Main Office, Right	Flush180	25-JUL-23	1.000	ug/L
51031	51031-1-HAL-F01	Main-Fountain 2 Outside Main Office, Right	Flush180	25-JUL-23	1.000	ug/L
51031	51031-1-HAL-F01	Main-Fountain 2 Outside Main Office, Right	Initial	25-JUL-23	1.220	ug/L
55031	55031-1-HAL-F01	Annex- North Corridor North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F01	Annex- North Corridor North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F01	Annex- North Corridor North, Fountain 1	Flush180	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F01	Annex- North Corridor North, Fountain 1	Flush180	06-JAN-21	1.000	ug/L
55031	55031-1-HAL-F01	Annex- North Corridor North, Fountain 1	Flush180	23-SEP-20	1.000	ug/L
55031	55031-1-HAL-F01	Annex- North Corridor North, Fountain 1	Initial	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F01	Annex- North Corridor North, Fountain 1	Initial	06-JAN-21	1.180	ug/L
55031	55031-1-HAL-F01	Annex- North Corridor North, Fountain 1	Initial	23-SEP-20	1.000	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	23-SEP-20	1.000	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	09-OCT-20	1.000	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	09-OCT-20	8.430	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	09-OCT-20	4.690	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	09-OCT-20	6.660	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	25-JUL-23	1.000	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	25-JUL-23	1.000	ug/L

**Water Quality Assessment
Peter A Reinberg Elementary School**

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	25-JUL-23	1.000	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Flush180	25-JUL-23	1.000	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Initial	28-MAY-16	1.000	ppb
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Initial	23-SEP-20	15.400	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Initial	09-OCT-20	1.000	ug/L
55031	55031-1-HAL-F02	Annex- North Corridor South, Fountain 2	Initial	25-JUL-23	1.000	ug/L
55031	55031-1-HAL-RBF03	Annex-North Corridor South, Fountain 1 Right	Flush180	25-JUL-23	1.000	ug/L
55031	55031-1-HAL-RBF03	Annex-North Corridor South, Fountain 1 Right	Flush180	25-JUL-23	1.000	ug/L
55031	55031-1-HAL-RBF03	Annex-North Corridor South, Fountain 1 Right	Flush180	25-JUL-23	1.000	ug/L
55031	55031-1-HAL-RBF03	Annex-North Corridor South, Fountain 1 Right	Flush180	25-JUL-23	1.000	ug/L
55031	55031-1-HAL-RBF03	Annex-North Corridor South, Fountain 1 Right	Initial	25-JUL-23	1.000	ug/L