



Sep 10, 2024

ROOSEVELT HS

3436 W WILSON AVE, Chicago IL 60625.

Dear **ROOSEVELT HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

ROOSEVELT HS

3436 W WILSON AVE, Chicago IL 60625.

Estimadas familias de **ROOSEVELT HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51536	51536-2-HAL-RBF01	Main - Outside Room 229	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-RBF01	Main - Outside Room 229	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-RBF01	Main - Outside Room 229	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-RBF01	Main - Outside Room 229	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-RBF01	Main - Outside Room 229	Initial	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F01	Main - Outside Room 246, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F01	Main - Outside Room 246, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F01	Main - Outside Room 246, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F01	Main - Outside Room 246, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F01	Main - Outside Room 246, Left Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F07	Main - Outside Room 308	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F07	Main - Outside Room 308	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F07	Main - Outside Room 308	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F07	Main - Outside Room 308	Initial	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-RBF01	Main - Outside Room 317, Bottle Filler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-RBF01	Main - Outside Room 317, Bottle Filler	Flush	07-DEC-2023	2.150	ug/L
51536	51536-3-HAL-RBF01	Main - Outside Room 317, Bottle Filler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-RBF01	Main - Outside Room 317, Bottle Filler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-RBF01	Main - Outside Room 317, Bottle Filler	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-KIT-KS02	Main- 1st Floor Kitchen Meat Sink Center	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS02	Main- 1st Floor Kitchen Meat Sink Center	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS02	Main- 1st Floor Kitchen Meat Sink Center	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS02	Main- 1st Floor Kitchen Meat Sink Center	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS02	Main- 1st Floor Kitchen Meat Sink Center	Initial	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS01	Main- 1st Floor Kitchen Sink North Side	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS01	Main- 1st Floor Kitchen Sink North Side	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS01	Main- 1st Floor Kitchen Sink North Side	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS01	Main- 1st Floor Kitchen Sink North Side	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS01	Main- 1st Floor Kitchen Sink North Side	Initial	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS03	Main- 1st Floor Kitchen Stove Top Meat Sink South	Flush180	28-OCT-16	9.400	ppb
51536	51536-1-KIT-KS03	Main- 1st Floor Kitchen Stove Top Meat Sink South	Flush180	28-OCT-16	21.000	ppb
51536	51536-1-KIT-KS03	Main- 1st Floor Kitchen Stove Top Meat Sink South	Flush180	28-OCT-16	9.900	ppb
51536	51536-1-KIT-KS03	Main- 1st Floor Kitchen Stove Top Meat Sink South	Flush180	28-OCT-16	58.000	ppb
51536	51536-1-KIT-KS03	Main- 1st Floor Kitchen Stove Top Meat Sink South	Initial	28-OCT-16	72.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51536	51536-1-KIT-KS05	Main- 1st Floor Kitchen, 3- Basin, Center Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS05	Main- 1st Floor Kitchen, 3- Basin, Center Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS05	Main- 1st Floor Kitchen, 3- Basin, Center Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS05	Main- 1st Floor Kitchen, 3- Basin, Center Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS05	Main- 1st Floor Kitchen, 3- Basin, Center Faucet	Initial	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS04	Main- 1st Floor Kitchen, 3- Basin, Left Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS04	Main- 1st Floor Kitchen, 3- Basin, Left Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS04	Main- 1st Floor Kitchen, 3- Basin, Left Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS04	Main- 1st Floor Kitchen, 3- Basin, Left Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS04	Main- 1st Floor Kitchen, 3- Basin, Left Faucet	Initial	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS06	Main- 1st Floor Kitchen, 3- Basin, Right Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS06	Main- 1st Floor Kitchen, 3- Basin, Right Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS06	Main- 1st Floor Kitchen, 3- Basin, Right Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS06	Main- 1st Floor Kitchen, 3- Basin, Right Faucet	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-KIT-KS06	Main- 1st Floor Kitchen, 3- Basin, Right Faucet	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F18	Main- By Room 108, Left FMain-By Room 108, Left F	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F18	Main- By Room 108, Left FMain-By Room 108, Left F	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F18	Main- By Room 108, Left FMain-By Room 108, Left F	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F18	Main- By Room 108, Left FMain-By Room 108, Left F	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F18	Main- By Room 108, Left FMain-By Room 108, Left F	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Flush	07-DEC-2023	1.140	ug/L
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F19	Main- By Room 108, Right Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Flush180	28-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F16	Main- By Room 117, Left Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F17	Main- By Room 117, Right Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F14	Main- By Room 129, Left Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Flush	07-DEC-2023	1.240	ug/L
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F15	Main- By Room 129, Right Fountain	Initial	07-DEC-2023	1.300	ug/L
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-	Main- By Room 148, Left Fountain	Flush180	28-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F12					
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F12	Main- By Room 148, Left Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-F13	Main- By Room 148, Right Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F07	Main- By Room 210, Left Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F08	Main- By Room 210, Right Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-	Main- By Room 217, Left Fountain	Flush	07-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05					
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F05	Main- By Room 217, Left Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F06	Main- By Room 217, Right Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F03	Main- By Room 229, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F03	Main- By Room 229, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F03	Main- By Room 229, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F03	Main- By Room 229, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F03	Main- By Room 229, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-2-HAL-F02	Main- By Room 246, Right Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	28-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	16-DEC-20	1.490	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	10-FEB-21	13.100	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	10-FEB-21	2.740	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	10-FEB-21	1.120	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	10-FEB-21	1.000	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	05-MAR-21	20.200	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	05-MAR-21	6.400	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	05-MAR-21	5.430	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	05-MAR-21	7.460	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	21-JUL-23	2.180	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	21-JUL-23	1.450	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	21-JUL-23	1.000	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Flush180	21-JUL-23	1.000	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Initial	16-DEC-20	8.710	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Initial	10-FEB-21	5.940	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Initial	05-MAR-21	39.400	ug/L
51536	51536-3-HAL-F07	Main- By Room 310, Left Fountain	Initial	21-JUL-23	1.000	ug/L
51536	51536-3-HAL-F08	Main- By Room 310, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F08	Main- By Room 310, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F08	Main- By Room 310, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F08	Main- By Room 310, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F08	Main- By Room 310, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F05	Main- By Room 317, Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F05	Main- By Room 317, Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F05	Main- By Room 317, Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F05	Main- By Room 317, Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F05	Main- By Room 317, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F05	Main- By Room 317, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F05	Main- By Room 317, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F05	Main- By Room 317, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F05	Main- By Room 317, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F06	Main- By Room 317, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F06	Main- By Room 317, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F06	Main- By Room 317, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F06	Main- By Room 317, Right Fountain	Flush180	28-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51536	51536-3-HAL-F06	Main- By Room 317, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F03	Main- By Room 329, Left Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F04	Main- By Room 329, Right Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F01	Main- By Room 348, Left Fountain	Initial	07-DEC-2023	1.070	ug/L
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Flush180	28-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Fountain				
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-3-HAL-F02	Main- By Room 348, Right Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Initial	28-OCT-16	1.000	ppb
51536	51536-1-POOL-WC22	Main- Inside Pool Area, Water Cooler	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Initial	28-OCT-16	1.000	ppb
51536	51536-1-166-WC21	Main- Inside Room 166 Health Center, Water Cooler	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Flush180	28-OCT-16	4.300	ppb
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Flush180	28-OCT-16	2.100	ppb
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Flush180	28-OCT-16	6.000	ppb
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Flush180	28-OCT-16	4.500	ppb
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Initial	28-OCT-16	4.700	ppb
51536	51536-1-167-KS09	Main- Inside Room 167, Cooking Lab Kitchen Sink, E	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Flush	07-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS08	Lab Kitchen Sink, S				
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Initial	28-OCT-16	1.000	ppb
51536	51536-1-167-KS08	Main- Inside Room 167, Cooking Lab Kitchen Sink, S	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Initial	28-OCT-16	1.000	ppb
51536	51536-1-167-KS07	Main- Inside Room 167, Cooking Lab Kitchen Sink, W	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Flush180	16-DEC-20	1.000	ug/L
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Initial	28-OCT-16	1.000	ppb
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Initial	16-DEC-20	1.000	ug/L
51536	51536-1-168-F10	Main- Inside Room 168, Early Childhood, Fountain	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-168-S11	Main- Inside Room 168, Early Childhood, Sink	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-168-S11	Main- Inside Room 168, Early Childhood, Sink	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-168-S11	Main- Inside Room 168, Early Childhood, Sink	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-168-S11	Main- Inside Room 168, Early Childhood, Sink	Initial	28-OCT-16	1.000	ppb
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Flush	07-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Initial	28-OCT-16	1.000	ppb
51536	51536-1-MOF-WC23	Main- Main Office, Water Cooler	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Flush	07-DEC-2023	1.000	ug/L
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Initial	28-OCT-16	1.000	ppb
51536	51536-1-HAL-WC20	Main- Outside Engineers Office, Water Cooler	Initial	07-DEC-2023	1.000	ug/L
51536	51536-1-TL-WC24	Main- Teachers Lounge, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-TL-WC24	Main- Teachers Lounge, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-TL-WC24	Main- Teachers Lounge, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-TL-WC24	Main- Teachers Lounge, Water Cooler	Flush180	28-OCT-16	1.000	ppb
51536	51536-1-TL-WC24	Main- Teachers Lounge, Water Cooler	Initial	28-OCT-16	1.000	ppb