



Sep 10, 2024

ROWE

1420 W AUGUSTA BLVD, Chicago IL 60642.

Dear **ROWE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

ROWE

1420 W AUGUSTA BLVD, Chicago IL 60642.

Estimadas familias de **ROWE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51138	51138-1-HAL-F04	Across From Room 104 (North), Fountain 1	Flush180	21-JUN-16	0.434	ppb
51138	51138-1-HAL-F04	Across From Room 104 (North), Fountain 1	Flush180	21-JUN-16	0.468	ppb
51138	51138-1-HAL-F04	Across From Room 104 (North), Fountain 1	Flush180	21-JUN-16	0.434	ppb
51138	51138-1-HAL-F04	Across From Room 104 (North), Fountain 1	Flush180	21-JUN-16	0.430	ppb
51138	51138-1-HAL-F04	Across From Room 104 (North), Fountain 1	Initial	21-JUN-16	0.712	ppb
51138	51138-1-HAL-F05	Across From Room 104 (South), Fountain 2	Flush180	21-JUN-16	0.445	ppb
51138	51138-1-HAL-F05	Across From Room 104 (South), Fountain 2	Flush180	21-JUN-16	0.439	ppb
51138	51138-1-HAL-F05	Across From Room 104 (South), Fountain 2	Flush180	21-JUN-16	0.429	ppb
51138	51138-1-HAL-F05	Across From Room 104 (South), Fountain 2	Flush180	21-JUN-16	0.421	ppb
51138	51138-1-HAL-F05	Across From Room 104 (South), Fountain 2	Initial	21-JUN-16	0.418	ppb
51138	51138-1-HAL-BF01	Across From Room 104 (South), Fountain 2, Bottle Filler	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-BF01	Across From Room 104 (South), Fountain 2, Bottle Filler	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-BF01	Across From Room 104 (South), Fountain 2, Bottle Filler	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-BF01	Across From Room 104 (South), Fountain 2, Bottle Filler	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-BF01	Across From Room 104 (South), Fountain 2, Bottle Filler	Initial	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F04	Across From Room 204, Fountain Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F04	Across From Room 204, Fountain Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F04	Across From Room 204, Fountain Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F04	Across From Room 204, Fountain Right	Initial	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Flush180	31-JAN-23	1.090	ug/L
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Flush180	31-JAN-23	1.160	ug/L
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Flush180	31-JAN-23	1.230	ug/L
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Flush180	31-JAN-23	1.180	ug/L
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Flush180	21-JUN-16	0.742	ppb
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Flush180	21-JUN-16	0.808	ppb
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Flush180	21-JUN-16	0.898	ppb
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Flush180	21-JUN-16	0.808	ppb
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Initial	31-JAN-23	1.160	ug/L
51138	51138-2-HAL-F03	Across From Room 204, Left Fountain	Initial	21-JUN-16	2.500	ppb
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Flush180	21-JUN-16	0.384	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Flush180	21-JUN-16	0.389	ppb
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Flush180	21-JUN-16	0.399	ppb
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Flush180	21-JUN-16	0.430	ppb
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Initial	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F01	Across From Room 206 (North), Fountain 1	Initial	21-JUN-16	0.563	ppb
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Flush180	21-JUN-16	0.380	ppb
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Flush180	21-JUN-16	0.372	ppb
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Flush180	21-JUN-16	0.378	ppb
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Flush180	21-JUN-16	0.371	ppb
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Initial	31-JAN-23	1.000	ug/L
51138	51138-2-HAL-F02	Across From Room 206 (South), Fountain 2	Initial	21-JUN-16	0.365	ppb
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	31-JAN-23	1.160	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	31-JAN-23	1.030	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	31-JAN-23	1.120	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	21-JUN-16	0.908	ppb
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	21-JUN-16	0.944	ppb
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	21-JUN-16	1.230	ppb
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	21-JUN-16	0.997	ppb
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	01-OCT-20	17.200	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	06-NOV-20	1.000	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	06-NOV-20	1.000	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	06-NOV-20	1.000	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Flush180	06-NOV-20	1.000	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Initial	31-JAN-23	3.450	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Initial	21-JUN-16	2.500	ppb
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Initial	01-OCT-20	73.300	ug/L
51138	51138-3-HAL-F03	Across From Room 304, Fountain.	Initial	06-NOV-20	1.000	ug/L
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Flush180	21-JUN-16	0.427	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Flush180	21-JUN-16	0.459	ppb
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Flush180	21-JUN-16	0.457	ppb
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Flush180	21-JUN-16	0.405	ppb
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Initial	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F01	Across From Room 306, (North), Fountain 1	Initial	21-JUN-16	0.764	ppb
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Flush180	21-JUN-16	0.371	ppb
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Flush180	21-JUN-16	0.359	ppb
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Flush180	21-JUN-16	0.318	ppb
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Flush180	21-JUN-16	0.294	ppb
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Initial	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F02	Across From Room 306, (South), Fountain 2	Initial	21-JUN-16	0.401	ppb
51138	51138-B-HAL-F02	Across From Stairwell (North), Fountain 1	Flush180	21-JUN-16	0.833	ppb
51138	51138-B-HAL-F02	Across From Stairwell (North), Fountain 1	Flush180	21-JUN-16	0.798	ppb
51138	51138-B-HAL-F02	Across From Stairwell (North), Fountain 1	Flush180	21-JUN-16	0.860	ppb
51138	51138-B-HAL-F02	Across From Stairwell (North), Fountain 1	Flush180	21-JUN-16	0.740	ppb
51138	51138-B-HAL-F02	Across From Stairwell (North), Fountain 1	Initial	21-JUN-16	1.060	ppb
51138	51138-B-HAL-F03	Across From Stairwell (South) Fountain 2	Flush180	21-JUN-16	1.040	ppb
51138	51138-B-HAL-F03	Across From Stairwell (South) Fountain 2	Flush180	21-JUN-16	0.705	ppb
51138	51138-B-HAL-F03	Across From Stairwell (South) Fountain 2	Flush180	21-JUN-16	0.762	ppb
51138	51138-B-HAL-F03	Across From Stairwell (South) Fountain 2	Flush180	21-JUN-16	0.812	ppb
51138	51138-B-HAL-F03	Across From Stairwell (South) Fountain 2	Initial	21-JUN-16	2.040	ppb
51138	51138-206-BF01	Direct Piping Water Dispenser Inside Room 206	Flush180	31-JAN-23	1.000	ug/L
51138	51138-206-BF01	Direct Piping Water Dispenser Inside Room 206	Flush180	31-JAN-23	1.000	ug/L
51138	51138-206-BF01	Direct Piping Water Dispenser Inside Room 206	Flush180	31-JAN-23	1.000	ug/L
51138	51138-206-BF01	Direct Piping Water Dispenser Inside Room 206	Flush180	31-JAN-23	1.000	ug/L
51138	51138-206-BF01	Direct Piping Water Dispenser Inside Room 206	Initial	31-JAN-23	1.000	ug/L
51138	51138-B-HAL-F01	HALLWAY BY ELEVATOR	Flush180	01-OCT-20	4.510	ug/L
51138	51138-B-HAL-F01	HALLWAY BY ELEVATOR	Flush180	06-NOV-20	1.000	ug/L
51138	51138-B-HAL-F01	HALLWAY BY ELEVATOR	Flush180	06-NOV-20	1.000	ug/L
51138	51138-B-HAL-F01	HALLWAY BY ELEVATOR	Flush180	06-NOV-20	1.000	ug/L
51138	51138-B-HAL-F01	HALLWAY BY ELEVATOR	Initial	01-OCT-20	69.800	ug/L
51138	51138-B-HAL-F01	HALLWAY BY ELEVATOR	Initial	06-NOV-20	1.000	ug/L
51138	51138-3-HAL-	Hallway by Elevator, Fountain 2,	Flush180	31-JAN-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Right				
51138	51138-3-HAL-F04	Hallway by Elevator, Fountain 2, Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F04	Hallway by Elevator, Fountain 2, Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F04	Hallway by Elevator, Fountain 2, Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F04	Hallway by Elevator, Fountain 2, Right	Initial	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F05	Hallway by Elevator, Fountain 3, Left	Flush180	31-JAN-23	1.260	ug/L
51138	51138-3-HAL-F05	Hallway by Elevator, Fountain 3, Left	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F05	Hallway by Elevator, Fountain 3, Left	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F05	Hallway by Elevator, Fountain 3, Left	Initial	31-JAN-23	2.430	ug/L
51138	51138-3-HAL-F06	Hallway by Elevator, Fountain 3, Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F06	Hallway by Elevator, Fountain 3, Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F06	Hallway by Elevator, Fountain 3, Right	Flush180	31-JAN-23	1.000	ug/L
51138	51138-3-HAL-F06	Hallway by Elevator, Fountain 3, Right	Initial	31-JAN-23	1.430	ug/L
51138	51138-1-107-S01	Inside Room 107, Sink	Flush180	31-JAN-23	13.200	ug/L
51138	51138-1-107-S01	Inside Room 107, Sink	Flush180	31-JAN-23	163.000	ug/L
51138	51138-1-107-S01	Inside Room 107, Sink	Flush180	31-JAN-23	26.700	ug/L
51138	51138-1-107-S01	Inside Room 107, Sink	Flush180	31-JAN-23	14.000	ug/L
51138	51138-1-107-S01	Inside Room 107, Sink	Flush180	21-JUN-16	33.900	ppb
51138	51138-1-107-S01	Inside Room 107, Sink	Flush180	21-JUN-16	6.710	ppb
51138	51138-1-107-S01	Inside Room 107, Sink	Flush180	21-JUN-16	1.270	ppb
51138	51138-1-107-S01	Inside Room 107, Sink	Flush180	21-JUN-16	5.550	ppb
51138	51138-1-107-S01	Inside Room 107, Sink	Initial	31-JAN-23	140.000	ug/L
51138	51138-1-107-S01	Inside Room 107, Sink	Initial	21-JUN-16	47.300	ppb
51138	51138-B-KIT-KS02	Kitchen Island Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS02	Kitchen Island Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS02	Kitchen Island Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS02	Kitchen Island Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS02	Kitchen Island Sink	Initial	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS01	Kitchen Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS01	Kitchen Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS01	Kitchen Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS01	Kitchen Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-KIT-KS01	Kitchen Sink	Flush180	21-JUN-16	0.749	ppb
51138	51138-B-KIT-KS01	Kitchen Sink	Flush180	21-JUN-16	0.662	ppb
51138	51138-B-KIT-KS01	Kitchen Sink	Flush180	21-JUN-16	0.630	ppb
51138	51138-B-KIT-KS01	Kitchen Sink	Flush180	21-JUN-16	0.862	ppb
51138	51138-B-KIT-	Kitchen Sink	Initial	31-JAN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS01					
51138	51138-B-KIT-KS01	Kitchen Sink	Initial	21-JUN-16	0.488	ppb
51138	51138-B-HAL-S04	Outside Art Room, Sink	Flush180	31-JAN-23	1.240	ug/L
51138	51138-B-HAL-S04	Outside Art Room, Sink	Flush180	31-JAN-23	1.310	ug/L
51138	51138-B-HAL-S04	Outside Art Room, Sink	Flush180	31-JAN-23	1.220	ug/L
51138	51138-B-HAL-S04	Outside Art Room, Sink	Flush180	31-JAN-23	1.000	ug/L
51138	51138-B-HAL-S04	Outside Art Room, Sink	Flush180	21-JUN-16	0.514	ppb
51138	51138-B-HAL-S04	Outside Art Room, Sink	Flush180	21-JUN-16	0.502	ppb
51138	51138-B-HAL-S04	Outside Art Room, Sink	Flush180	21-JUN-16	0.495	ppb
51138	51138-B-HAL-S04	Outside Art Room, Sink	Flush180	21-JUN-16	0.487	ppb
51138	51138-B-HAL-S04	Outside Art Room, Sink	Initial	31-JAN-23	1.630	ug/L
51138	51138-B-HAL-S04	Outside Art Room, Sink	Initial	21-JUN-16	0.764	ppb
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Flush180	21-JUN-16	0.393	ppb
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Flush180	21-JUN-16	0.391	ppb
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Flush180	21-JUN-16	0.400	ppb
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Flush180	21-JUN-16	0.402	ppb
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Initial	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F02	Outside Room 107 (North), Fountain 1	Initial	21-JUN-16	1.450	ppb
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Flush180	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Flush180	21-JUN-16	0.424	ppb
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Flush180	21-JUN-16	0.400	ppb
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Flush180	21-JUN-16	0.410	ppb
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Flush180	21-JUN-16	0.413	ppb
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Initial	31-JAN-23	1.000	ug/L
51138	51138-1-HAL-F03	Outside Room 107 (South), Fountain 2	Initial	21-JUN-16	0.537	ppb