



Sep 10, 2024

**RUGGLES**

**7831 S PRAIRIE AVE, Chicago IL 60619.**

Dear **RUGGLES** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**RUGGLES**

**7831 S PRAIRIE AVE, Chicago IL 60619.**

Estimadas familias de **RUGGLES**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51384	51384-1-HAL-BF01	By Main Office, Bottle Filler	Flush	25-JAN-2024	3.140	ug/L
51384	51384-1-HAL-BF01	By Main Office, Bottle Filler	Flush	25-JAN-2024	1.730	ug/L
51384	51384-1-HAL-BF01	By Main Office, Bottle Filler	Flush	25-JAN-2024	2.390	ug/L
51384	51384-1-HAL-BF01	By Main Office, Bottle Filler	Flush	25-JAN-2024	2.330	ug/L
51384	51384-1-HAL-BF01	By Main Office, Bottle Filler	Initial	25-JAN-2024	1.230	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Flush	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Flush	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Flush	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Flush	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Flush	25-JAN-2024	5.640	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Flush	25-JAN-2024	5.610	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Flush	25-JAN-2024	5.450	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Flush	25-JAN-2024	6.340	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Initial	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F07	By Main Office, Left Fountain	Initial	25-JAN-2024	6.100	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Flush	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Flush	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Flush	25-JAN-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Flush	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Flush	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Initial	14-FEB-2024	1.000	ug/L
51384	51384-1-HAL-F08	By Main Office, Right Fountain	Initial	25-JAN-2024	1.050	ug/L
51384	51384-1-HAL-RBF01	By Room 105, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-RBF01	By Room 105, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-RBF01	By Room 105, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-RBF01	By Room 105, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F03	By Room 105, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F03	By Room 105, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F03	By Room 105, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F03	By Room 105, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F03	By Room 105, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-RBF01	By Room 105, left	Initial	14-DEC-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51384	51384-1-HAL-F04	By Room 105, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F04	By Room 105, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F04	By Room 105, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F04	By Room 105, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F04	By Room 105, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F04	By Room 105, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F04	By Room 105, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F04	By Room 105, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F04	By Room 105, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F04	By Room 105, right	Initial	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F01	By Room 111, left	Flush	08-MAY-2024	4.410	ug/L
51384	51384-1-HAL-F01	By Room 111, left	Flush	08-MAY-2024	3.550	ug/L
51384	51384-1-HAL-F01	By Room 111, left	Flush	08-MAY-2024	3.780	ug/L
51384	51384-1-HAL-F01	By Room 111, left	Flush	08-MAY-2024	2.190	ug/L
51384	51384-1-HAL-F01	By Room 111, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F01	By Room 111, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F01	By Room 111, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F01	By Room 111, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F01	By Room 111, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F01	By Room 111, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F01	By Room 111, left	Flush180	26-AUG-20	1.690	ug/L
51384	51384-1-HAL-F01	By Room 111, left	Initial	26-AUG-20	1.000	ug/L
51384	51384-1-HAL-F01	By Room 111, left	Initial	08-MAY-2024	1.650	ug/L
51384	51384-1-HAL-F02	By Room 111, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F02	By Room 111, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F02	By Room 111, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F02	By Room 111, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F02	By Room 111, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F02	By Room 111, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F02	By Room 111, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F02	By Room 111, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-HAL-F02	By Room 111, right	Initial	14-DEC-22	1.830	ug/L
51384	51384-1-HAL-F05	By Room 151 (lunchroom), left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F05	By Room 151 (lunchroom), left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F05	By Room 151 (lunchroom), left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F05	By Room 151 (lunchroom), left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-HAL-F05	By Room 151 (lunchroom), left	Initial	14-DEC-22	1.290	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51384	51384-2-HAL-F03	By Room 203, left	Flush180	14-DEC-22	2.910	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Flush180	14-DEC-22	1.980	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Flush180	14-DEC-22	1.030	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F03	By Room 203, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F03	By Room 203, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F03	By Room 203, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F03	By Room 203, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F03	By Room 203, left	Flush180	27-OCT-20	1.090	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Flush180	27-OCT-20	1.060	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Flush180	27-OCT-20	1.100	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Flush180	27-OCT-20	1.110	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Initial	14-DEC-22	3.650	ug/L
51384	51384-2-HAL-F03	By Room 203, left	Initial	27-OCT-20	1.450	ug/L
51384	51384-2-HAL-F04	By Room 203, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F04	By Room 203, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F04	By Room 203, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F04	By Room 203, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F04	By Room 203, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F04	By Room 203, right	Flush180	26-AUG-20	1.570	ug/L
51384	51384-2-HAL-F04	By Room 203, right	Initial	26-AUG-20	8.730	ug/L
51384	51384-2-HAL-BF01	By Room 207, Bottle Filler	Flush	25-JAN-2024	3.020	ug/L
51384	51384-2-HAL-BF01	By Room 207, Bottle Filler	Flush	25-JAN-2024	2.290	ug/L
51384	51384-2-HAL-BF01	By Room 207, Bottle Filler	Flush	25-JAN-2024	2.550	ug/L
51384	51384-2-HAL-BF01	By Room 207, Bottle Filler	Flush	25-JAN-2024	2.310	ug/L
51384	51384-2-HAL-BF01	By Room 207, Bottle Filler	Initial	25-JAN-2024	3.240	ug/L
51384	51384-2-HAL-F07	By Room 207, Left Fountain	Flush	25-JAN-2024	2.180	ug/L
51384	51384-2-HAL-F07	By Room 207, Left Fountain	Flush	25-JAN-2024	1.840	ug/L
51384	51384-2-HAL-F07	By Room 207, Left Fountain	Flush	25-JAN-2024	1.430	ug/L
51384	51384-2-HAL-F07	By Room 207, Left Fountain	Flush	25-JAN-2024	2.220	ug/L
51384	51384-2-HAL-F07	By Room 207, Left Fountain	Initial	25-JAN-2024	1.910	ug/L
51384	51384-2-HAL-F08	By Room 207, Right Fountain	Flush	25-JAN-2024	6.080	ug/L
51384	51384-2-HAL-F08	By Room 207, Right Fountain	Flush	25-JAN-2024	4.770	ug/L
51384	51384-2-HAL-F08	By Room 207, Right Fountain	Flush	25-JAN-2024	3.900	ug/L
51384	51384-2-HAL-F08	By Room 207, Right Fountain	Flush	25-JAN-2024	2.870	ug/L
51384	51384-2-HAL-F08	By Room 207, Right Fountain	Initial	25-JAN-2024	6.850	ug/L
51384	51384-2-HAL-	By Room 207, left	Flush180	14-DEC-22	1.590	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF01					
51384	51384-2-HAL-RBF01	By Room 207, left	Flush180	14-DEC-22	1.380	ug/L
51384	51384-2-HAL-RBF01	By Room 207, left	Flush180	14-DEC-22	1.190	ug/L
51384	51384-2-HAL-RBF01	By Room 207, left	Flush180	14-DEC-22	1.120	ug/L
51384	51384-2-HAL-F01	By Room 207, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F01	By Room 207, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F01	By Room 207, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F01	By Room 207, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F01	By Room 207, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-RBF01	By Room 207, left	Initial	14-DEC-22	1.210	ug/L
51384	51384-2-HAL-F02	By Room 207, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F02	By Room 207, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F02	By Room 207, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F02	By Room 207, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F02	By Room 207, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F05	By Room 215, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F05	By Room 215, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F05	By Room 215, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F05	By Room 215, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F05	By Room 215, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F06	By Room 215, right	Flush180	14-DEC-22	1.200	ug/L
51384	51384-2-HAL-F06	By Room 215, right	Flush180	14-DEC-22	1.080	ug/L
51384	51384-2-HAL-F06	By Room 215, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-2-HAL-F06	By Room 215, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-2-HAL-F06	By Room 215, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F06	By Room 215, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F06	By Room 215, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F06	By Room 215, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F06	By Room 215, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F06	By Room 215, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-2-HAL-F06	By Room 215, right	Initial	14-DEC-22	1.000	ug/L
51384	51384-1-104-S01	Classroom 104	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-104-S01	Classroom 104	Flush180	14-DEC-22	1.070	ug/L
51384	51384-1-104-S01	Classroom 104	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-104-S01	Classroom 104	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-104-S01	Classroom 104	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-104-S01	Classroom 104	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-104-S01	Classroom 104	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-104-S01	Classroom 104	Flush180	16-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
51384	51384-1-104-S01	Classroom 104	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-104-S01	Classroom 104	Initial	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS01	Kitchen, far left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS01	Kitchen, far left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS01	Kitchen, far left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS01	Kitchen, far left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS01	Kitchen, far left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS01	Kitchen, far left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS01	Kitchen, far left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS01	Kitchen, far left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS01	Kitchen, far left	Initial	14-DEC-22	1.050	ug/L
51384	51384-1-KIT-KS01	Kitchen, far left	Initial	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	14-DEC-22	2.550	ug/L
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	14-DEC-22	1.780	ug/L
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	14-DEC-22	1.260	ug/L
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	14-DEC-22	1.210	ug/L
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS04	Kitchen, far right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS04	Kitchen, far right	Initial	14-DEC-22	2.480	ug/L
51384	51384-1-KIT-KS02	Kitchen, left	Flush	08-MAY-2024	1.000	ug/L
51384	51384-1-KIT-KS02	Kitchen, left	Flush	08-MAY-2024	1.000	ug/L
51384	51384-1-KIT-KS02	Kitchen, left	Flush	08-MAY-2024	1.000	ug/L
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS02	Kitchen, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS02	Kitchen, left	Initial	14-DEC-22	8.000	ug/L
51384	51384-1-KIT-KS02	Kitchen, left	Initial	08-MAY-2024	1.000	ug/L





Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	14-DEC-22	1.260	ug/L
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	14-DEC-22	1.120	ug/L
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS03	Kitchen, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-KIT-KS03	Kitchen, right	Initial	14-DEC-22	1.800	ug/L
51384	51384-1-LUN-BF01	Left Bottle Filler in Lunchroom	Flush180	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-BF01	Left Bottle Filler in Lunchroom	Flush180	29-AUG-23	1.010	ug/L
51384	51384-1-LUN-BF01	Left Bottle Filler in Lunchroom	Flush180	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-BF01	Left Bottle Filler in Lunchroom	Flush180	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-BF01	Left Bottle Filler in Lunchroom	Initial	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-F01	Left Fountain in Lunchroom	Flush180	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-F01	Left Fountain in Lunchroom	Flush180	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-F01	Left Fountain in Lunchroom	Flush180	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-F01	Left Fountain in Lunchroom	Flush180	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-F01	Left Fountain in Lunchroom	Initial	29-AUG-23	1.000	ug/L
51384	51384-1-LUN-F02	Middle Fountain in Lunchroom	Flush180	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F02	Middle Fountain in Lunchroom	Flush180	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F02	Middle Fountain in Lunchroom	Flush180	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F02	Middle Fountain in Lunchroom	Flush180	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F02	Middle Fountain in Lunchroom	Initial	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F03	Right Fountain in Lunchroom	Flush180	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F03	Right Fountain in Lunchroom	Flush180	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F03	Right Fountain in Lunchroom	Flush180	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F03	Right Fountain in Lunchroom	Flush180	16-AUG-23	1.000	ug/L
51384	51384-1-LUN-F03	Right Fountain in Lunchroom	Initial	16-AUG-23	1.000	ug/L
51384	51384-1-101-S01	Room 101, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-101-S01	Room 101, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-101-S01	Room 101, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-101-S01	Room 101, left	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-101-S01	Room 101, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S01	Room 101, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S01	Room 101, left	Flush180	16-JUN-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51384	51384-1-101-S01	Room 101, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S01	Room 101, left	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S01	Room 101, left	Initial	14-DEC-22	1.000	ug/L
51384	51384-1-101-S02	Room 101, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-101-S02	Room 101, right	Flush180	14-DEC-22	2.090	ug/L
51384	51384-1-101-S02	Room 101, right	Flush180	14-DEC-22	1.600	ug/L
51384	51384-1-101-S02	Room 101, right	Flush180	14-DEC-22	1.490	ug/L
51384	51384-1-101-S02	Room 101, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S02	Room 101, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S02	Room 101, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S02	Room 101, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S02	Room 101, right	Flush180	16-JUN-16	1.000	ppb
51384	51384-1-101-S02	Room 101, right	Initial	14-DEC-22	1.000	ug/L
51384	51384-1-111-S01	Room 111, left	Flush	08-MAY-2024	1.000	ug/L
51384	51384-1-111-S01	Room 111, left	Flush	08-MAY-2024	1.000	ug/L
51384	51384-1-111-S01	Room 111, left	Flush	08-MAY-2024	1.000	ug/L
51384	51384-1-111-S01	Room 111, left	Flush	08-MAY-2024	1.000	ug/L
51384	51384-1-111-S01	Room 111, left	Flush180	14-DEC-22	3.830	ug/L
51384	51384-1-111-S01	Room 111, left	Flush180	14-DEC-22	1.990	ug/L
51384	51384-1-111-S01	Room 111, left	Flush180	14-DEC-22	2.120	ug/L
51384	51384-1-111-S01	Room 111, left	Flush180	14-DEC-22	2.010	ug/L
51384	51384-1-111-S01	Room 111, left	Initial	14-DEC-22	6.210	ug/L
51384	51384-1-111-S01	Room 111, left	Initial	08-MAY-2024	1.000	ug/L
51384	51384-1-111-S02	Room 111, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-111-S02	Room 111, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-111-S02	Room 111, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-111-S02	Room 111, right	Flush180	14-DEC-22	1.000	ug/L
51384	51384-1-111-S02	Room 111, right	Initial	14-DEC-22	1.980	ug/L