



Sep 10, 2024

SAUCEDO

2850 W 24TH BLVD, Chicago IL 60623.

Dear **SAUCEDO** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

SAUCEDO

2850 W 24TH BLVD, Chicago IL 60623.

Estimadas familias de **SAUCEDO**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51275	51275-2-KIT-KS-05	1 Basin Sink by North Wall	Flush180	13-SEP-16	0.400	ppb
51275	51275-2-KIT-KS-05	1 Basin Sink by North Wall	Flush180	13-SEP-16	0.390	ppb
51275	51275-2-KIT-KS-05	1 Basin Sink by North Wall	Flush180	13-SEP-16	0.700	ppb
51275	51275-2-KIT-KS-05	1 Basin Sink by North Wall	Flush180	13-SEP-16	0.540	ppb
51275	51275-2-KIT-KS-05	1 Basin Sink by North Wall	Initial	13-SEP-16	0.510	ppb
51275	51275-2-230A-KS-01	1 Basin Sink in 230A	Flush180	13-SEP-16	0.590	ppb
51275	51275-2-230A-KS-01	1 Basin Sink in 230A	Flush180	13-SEP-16	0.570	ppb
51275	51275-2-230A-KS-01	1 Basin Sink in 230A	Flush180	13-SEP-16	0.750	ppb
51275	51275-2-230A-KS-01	1 Basin Sink in 230A	Flush180	13-SEP-16	0.490	ppb
51275	51275-2-230A-KS-01	1 Basin Sink in 230A	Initial	13-SEP-16	0.620	ppb
51275	51275-1-116-S01	116 East End	Flush180	13-SEP-16	0.350	ppb
51275	51275-1-116-S01	116 East End	Flush180	13-SEP-16	0.520	ppb
51275	51275-1-116-S01	116 East End	Flush180	13-SEP-16	0.740	ppb
51275	51275-1-116-S01	116 East End	Flush180	13-SEP-16	0.480	ppb
51275	51275-1-116-S01	116 East End	Initial	13-SEP-16	0.160	ppb
51275	51275-1-116-S01	116 Left Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S01	116 Left Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S01	116 Left Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S01	116 Left Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S01	116 Left Sink	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S02	116 Right Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S02	116 Right Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S02	116 Right Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S02	116 Right Sink	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-116-S02	116 West End	Flush180	13-SEP-16	1.100	ppb
51275	51275-1-116-S02	116 West End	Flush180	13-SEP-16	0.920	ppb
51275	51275-1-116-S02	116 West End	Flush180	13-SEP-16	0.830	ppb
51275	51275-1-116-S02	116 West End	Flush180	13-SEP-16	1.200	ppb
51275	51275-1-116-S02	116 West End	Initial	13-SEP-16	0.320	ppb
51275	51275-1-124-KS01	124 Office	Flush180	16-MAY-23	2.870	ug/L
51275	51275-1-124-KS01	124 Office	Flush180	16-MAY-23	4.110	ug/L
51275	51275-1-124-KS01	124 Office	Flush180	16-MAY-23	2.880	ug/L
51275	51275-1-124-KS01	124 Office	Flush180	16-MAY-23	2.220	ug/L
51275	51275-1-124-KS01	124 Office	Flush180	13-SEP-16	2.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51275	51275-1-124-KS01	124 Office	Flush180	13-SEP-16	0.660	ppb
51275	51275-1-124-KS01	124 Office	Flush180	13-SEP-16	0.670	ppb
51275	51275-1-124-KS01	124 Office	Flush180	13-SEP-16	5.000	ppb
51275	51275-1-124-KS01	124 Office	Initial	16-MAY-23	1.570	ug/L
51275	51275-1-124-KS01	124 Office	Initial	13-SEP-16	0.500	ppb
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Initial	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-S01	1st Floor, East End, Room 144	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-E-143-S01	1st Floor, East End, Room 143	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-143-S01	1st Floor, East End, Room 143	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-143-S01	1st Floor, East End, Room 143	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-143-S01	1st Floor, East End, Room 143	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-143-F01	1st Floor, East End, Room 143	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-143-F01	1st Floor, East End, Room 143	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-143-F01	1st Floor, East End, Room 143	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-143-F01	1st Floor, East End, Room 143	Initial	06-SEP-19	1.000	ug/L
51275	51275-1-E-143-F01	1st Floor, East End, Room 143	Initial	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Flush180	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Initial	06-SEP-19	1.000	ug/L
51275	51275-1-E-144-F01	1st Floor, East End, Room 144	Initial	11-JAN-2024	1.000	ug/L
51275	51275-2-KIT-KS-07	3 Basin 3 Tap Sink Middle	Flush180	13-SEP-16	0.220	ppb
51275	51275-2-KIT-KS-07	3 Basin 3 Tap Sink Middle	Flush180	13-SEP-16	0.110	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51275	51275-2-KIT-KS-07	3 Basin 3 Tap Sink Middle	Flush180	13-SEP-16	0.170	ppb
51275	51275-2-KIT-KS-07	3 Basin 3 Tap Sink Middle	Flush180	13-SEP-16	0.140	ppb
51275	51275-2-KIT-KS-07	3 Basin 3 Tap Sink Middle	Initial	13-SEP-16	0.340	ppb
51275	51275-2-KIT-KS-08	3 Basin 3 Tap West End	Flush180	13-SEP-16	1.300	ppb
51275	51275-2-KIT-KS-08	3 Basin 3 Tap West End	Flush180	13-SEP-16	0.200	ppb
51275	51275-2-KIT-KS-08	3 Basin 3 Tap West End	Flush180	13-SEP-16	0.270	ppb
51275	51275-2-KIT-KS-08	3 Basin 3 Tap West End	Flush180	13-SEP-16	0.260	ppb
51275	51275-2-KIT-KS-08	3 Basin 3 Tap West End	Initial	13-SEP-16	0.180	ppb
51275	51275-2-KIT-KS-06	3 Basin 33 Basin 3 Tap sink East End	Flush180	13-SEP-16	0.200	ppb
51275	51275-2-KIT-KS-06	3 Basin 33 Basin 3 Tap sink East End	Flush180	13-SEP-16	0.250	ppb
51275	51275-2-KIT-KS-06	3 Basin 33 Basin 3 Tap sink East End	Flush180	13-SEP-16	0.180	ppb
51275	51275-2-KIT-KS-06	3 Basin 33 Basin 3 Tap sink East End	Flush180	13-SEP-16	0.170	ppb
51275	51275-2-KIT-KS-06	3 Basin 33 Basin 3 Tap sink East End	Initial	13-SEP-16	0.230	ppb
51275	51275-3-HALL-F01	3rd FL NE Corner	Flush180	14-SEP-16	0.080	ppb
51275	51275-3-HALL-F01	3rd FL NE Corner	Flush180	14-SEP-16	0.067	ppb
51275	51275-3-HALL-F01	3rd FL NE Corner	Flush180	14-SEP-16	0.080	ppb
51275	51275-3-HALL-F01	3rd FL NE Corner	Flush180	14-SEP-16	0.092	ppb
51275	51275-3-HALL-F01	3rd FL NE Corner	Initial	14-SEP-16	0.390	ppb
51275	51275-3-HALL-F04	3rd FL NW Corner	Flush180	14-SEP-16	0.200	ppb
51275	51275-3-HALL-F04	3rd FL NW Corner	Flush180	14-SEP-16	0.220	ppb
51275	51275-3-HALL-F04	3rd FL NW Corner	Flush180	14-SEP-16	0.220	ppb
51275	51275-3-HALL-F04	3rd FL NW Corner	Flush180	14-SEP-16	0.160	ppb
51275	51275-3-HALL-F04	3rd FL NW Corner	Flush180	19-AUG-20	1.000	ug/L
51275	51275-3-HALL-F04	3rd FL NW Corner	Initial	14-SEP-16	0.350	ppb
51275	51275-3-HALL-F04	3rd FL NW Corner	Initial	19-AUG-20	1.640	ug/L
51275	51275-3-HALL-F03	3rd FL SW Corner	Flush180	14-SEP-16	0.150	ppb
51275	51275-3-HALL-F03	3rd FL SW Corner	Flush180	14-SEP-16	0.230	ppb
51275	51275-3-HALL-F03	3rd FL SW Corner	Flush180	14-SEP-16	0.210	ppb
51275	51275-3-HALL-F03	3rd FL SW Corner	Flush180	14-SEP-16	0.110	ppb
51275	51275-3-HALL-F03	3rd FL SW Corner	Initial	14-SEP-16	0.460	ppb
51275	51275-3-HALL-F02	3rd FLSE Corner	Flush180	14-SEP-16	0.210	ppb
51275	51275-3-HALL-F02	3rd FLSE Corner	Flush180	14-SEP-16	0.210	ppb
51275	51275-3-HALL-F02	3rd FLSE Corner	Flush180	14-SEP-16	0.240	ppb
51275	51275-3-HALL-F02	3rd FLSE Corner	Flush180	14-SEP-16	0.310	ppb
51275	51275-3-HALL-F02	3rd FLSE Corner	Initial	14-SEP-16	0.460	ppb
51275	51275-1-HAL-F09	Center SW Hall	Flush180	13-SEP-16	3.900	ppb
51275	51275-1-HAL-F09	Center SW Hall	Flush180	13-SEP-16	0.640	ppb
51275	51275-1-HAL-F09	Center SW Hall	Flush180	13-SEP-16	2.400	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09					
51275	51275-1-HAL-F09	Center SW Hall	Flush180	13-SEP-16	0.950	ppb
51275	51275-1-HAL-F10	Center SW Hall	Flush180	13-SEP-16	0.450	ppb
51275	51275-1-HAL-F10	Center SW Hall	Flush180	13-SEP-16	0.590	ppb
51275	51275-1-HAL-F10	Center SW Hall	Flush180	13-SEP-16	0.530	ppb
51275	51275-1-HAL-F10	Center SW Hall	Flush180	13-SEP-16	0.520	ppb
51275	51275-1-HAL-F09	Center SW Hall	Initial	13-SEP-16	4.100	ppb
51275	51275-1-HAL-F10	Center SW Hall	Initial	13-SEP-16	2.600	ppb
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Flush180	23-NOV-21	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Flush180	23-NOV-21	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Flush180	23-NOV-21	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Flush180	23-NOV-21	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Initial	23-NOV-21	1.000	ug/L
51275	51275-1-116-F01	Inside Room 116/118, Fountain	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-126-S01	Inside Room 126 Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-S01	Inside Room 126 Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-S01	Inside Room 126 Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-S01	Inside Room 126 Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-S01	Inside Room 126 Sink	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush180	23-NOV-21	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush180	23-NOV-21	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush180	23-NOV-21	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Flush180	23-NOV-21	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Initial	23-NOV-21	1.000	ug/L
51275	51275-1-126-F01	Inside Room 126, Fountain	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-143-F01	Inside Room 143 Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-143-F01	Inside Room 143 Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-143-F01	Inside Room 143 Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-143-F01	Inside Room 143 Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-143-	Inside Room 143 Fountain	Initial	11-JAN-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51275	51275-1-143-S01	Inside Room 143 Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-143-S01	Inside Room 143 Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-143-S01	Inside Room 143 Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-143-S01	Inside Room 143 Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-143-S01	Inside Room 143 Sink	Initial	11-JAN-2024	1.000	ug/L
51275	51275-2-KIT-KS-01	Kitchen 3 Basin 2 Tap Sink	Flush180	13-SEP-16	0.640	ppb
51275	51275-2-KIT-KS-01	Kitchen 3 Basin 2 Tap Sink	Flush180	13-SEP-16	1.200	ppb
51275	51275-2-KIT-KS-01	Kitchen 3 Basin 2 Tap Sink	Flush180	13-SEP-16	0.970	ppb
51275	51275-2-KIT-KS-01	Kitchen 3 Basin 2 Tap Sink	Flush180	13-SEP-16	0.480	ppb
51275	51275-2-KIT-KS-02	Kitchen 3 Basin 2 Tap Sink	Flush180	13-SEP-16	0.120	ppb
51275	51275-2-KIT-KS-02	Kitchen 3 Basin 2 Tap Sink	Flush180	13-SEP-16	0.098	ppb
51275	51275-2-KIT-KS-02	Kitchen 3 Basin 2 Tap Sink	Flush180	13-SEP-16	0.130	ppb
51275	51275-2-KIT-KS-02	Kitchen 3 Basin 2 Tap Sink	Flush180	13-SEP-16	0.087	ppb
51275	51275-2-KIT-KS-01	Kitchen 3 Basin 2 Tap Sink	Initial	13-SEP-16	1.200	ppb
51275	51275-2-KIT-KS-02	Kitchen 3 Basin 2 Tap Sink	Initial	13-SEP-16	0.230	ppb
51275	51275-1-GYM-F01	Main Gym	Flush180	14-SEP-16	5.900	ppb
51275	51275-1-GYM-F01	Main Gym	Flush180	14-SEP-16	5.800	ppb
51275	51275-1-GYM-F01	Main Gym	Flush180	14-SEP-16	7.200	ppb
51275	51275-1-GYM-F01	Main Gym	Flush180	14-SEP-16	5.800	ppb
51275	51275-1-GYM-F01	Main Gym	Initial	14-SEP-16	7.000	ppb
51275	51275-2-HALL-F03	NE Corner outside Bathroom	Flush180	14-SEP-16	0.068	ppb
51275	51275-2-HALL-F03	NE Corner outside Bathroom	Flush180	14-SEP-16	0.110	ppb
51275	51275-2-HALL-F03	NE Corner outside Bathroom	Flush180	14-SEP-16	0.140	ppb
51275	51275-2-HALL-F03	NE Corner outside Bathroom	Flush180	14-SEP-16	0.079	ppb
51275	51275-2-HALL-F03	NE Corner outside Bathroom	Initial	14-SEP-16	0.300	ppb
51275	51275-1-HAL-F04	NE Corner outside girls bathroom	Flush180	13-SEP-16	0.790	ppb
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	13-SEP-16	1.100	ppb
51275	51275-1-HAL-F04	NE Corner outside girls bathroom	Flush180	13-SEP-16	1.600	ppb
51275	51275-1-HAL-F04	NE Corner outside girls bathroom	Flush180	13-SEP-16	3.100	ppb
51275	51275-1-HAL-F04	NE Corner outside girls bathroom	Flush180	13-SEP-16	2.300	ppb
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	13-SEP-16	1.700	ppb
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	13-SEP-16	1.600	ppb
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	13-SEP-16	0.390	ppb
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	19-AUG-20	45.700	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	21-OCT-20	2.040	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	21-OCT-20	1.730	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	21-OCT-20	1.840	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Flush180	21-OCT-20	1.860	ug/L
51275	51275-1-HAL-F04	NE Corner outside girls bathroom	Initial	13-SEP-16	1.100	ppb
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Initial	13-SEP-16	1.600	ppb
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Initial	19-AUG-20	23.700	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom	Initial	21-OCT-20	2.890	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F03	NE Corner outside girls bathroom, Left Fountain	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F04	NE Corner outside girls bathroom, Right Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F04	NE Corner outside girls bathroom, Right Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F04	NE Corner outside girls bathroom, Right Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F04	NE Corner outside girls bathroom, Right Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F04	NE Corner outside girls bathroom, Right Fountain	Initial	11-JAN-2024	1.000	ug/L
51275	51275-2-HALL-F06	NW Corner Outside Bathroom	Flush180	14-SEP-16	0.230	ppb
51275	51275-2-HALL-F06	NW Corner Outside Bathroom	Flush180	14-SEP-16	0.240	ppb
51275	51275-2-HALL-F06	NW Corner Outside Bathroom	Flush180	14-SEP-16	0.260	ppb
51275	51275-2-HALL-F06	NW Corner Outside Bathroom	Flush180	14-SEP-16	0.270	ppb
51275	51275-2-HALL-F06	NW Corner Outside Bathroom	Initial	14-SEP-16	0.490	ppb
51275	51275-2-HALL-F02	Outside Bathrooms 2nd FL Hall	Flush180	14-SEP-16	2.000	ppb
51275	51275-2-HALL-F02	Outside Bathrooms 2nd FL Hall	Flush180	14-SEP-16	2.200	ppb
51275	51275-2-HALL-F02	Outside Bathrooms 2nd FL Hall	Flush180	14-SEP-16	1.900	ppb
51275	51275-2-HALL-F02	Outside Bathrooms 2nd FL Hall	Flush180	14-SEP-16	2.200	ppb
51275	51275-2-HALL-F01	Outside Bathrooms 2nd FL Hall	Flush180	14-SEP-16	2.100	ppb
51275	51275-2-HALL-F01	Outside Bathrooms 2nd FL Hall	Flush180	14-SEP-16	3.000	ppb
51275	51275-2-HALL-F01	Outside Bathrooms 2nd FL Hall	Flush180	14-SEP-16	2.400	ppb
51275	51275-2-HALL-F01	Outside Bathrooms 2nd FL Hall	Flush180	14-SEP-16	2.600	ppb
51275	51275-2-HALL-F02	Outside Bathrooms 2nd FL Hall	Initial	14-SEP-16	4.000	ppb
51275	51275-2-HALL-F01	Outside Bathrooms 2nd FL Hall	Initial	14-SEP-16	3.600	ppb
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Flush	11-JAN-2024	1.230	ug/L
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Flush	11-JAN-2024	1.090	ug/L
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Flush	11-JAN-2024	1.180	ug/L
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Flush	11-JAN-2024	1.320	ug/L
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Flush	11-JAN-2024	1.100	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Flush	11-JAN-2024	1.020	ug/L
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Flush180	13-SEP-16	1.200	ppb
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Flush180	13-SEP-16	0.970	ppb
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Flush180	13-SEP-16	0.890	ppb
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Flush180	13-SEP-16	1.100	ppb
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Flush180	13-SEP-16	1.000	ppb
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Flush180	13-SEP-16	1.200	ppb
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Flush180	13-SEP-16	1.200	ppb
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Flush180	13-SEP-16	1.200	ppb
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Initial	13-SEP-16	1.400	ppb
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Initial	13-SEP-16	1.500	ppb
51275	51275-1-HAL-F11	Outside Boys Bathroom SW Corner	Initial	11-JAN-2024	2.410	ug/L
51275	51275-1-HAL-F12	Outside Boys Bathroom SW Corner	Initial	11-JAN-2024	2.840	ug/L
51275	51275-1-HAL-RBF02	Outside Girl Washroom NW Corner, Left Bottle Filler	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF02	Outside Girl Washroom NW Corner, Left Bottle Filler	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF02	Outside Girl Washroom NW Corner, Left Bottle Filler	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF02	Outside Girl Washroom NW Corner, Left Bottle Filler	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF02	Outside Girl Washroom NW Corner, Left Bottle Filler	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F02	Outside Girl Washroom NW Corner, Right Fountain	Flush	11-JAN-2024	1.530	ug/L
51275	51275-1-HAL-F02	Outside Girl Washroom NW Corner, Right Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F02	Outside Girl Washroom NW Corner, Right Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F02	Outside Girl Washroom NW Corner, Right Fountain	Initial	11-JAN-2024	1.670	ug/L
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Flush	11-JAN-2024	1.270	ug/L
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Flush180	13-SEP-16	0.330	ppb
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Flush180	13-SEP-16	0.520	ppb
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Flush180	13-SEP-16	0.400	ppb
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Flush180	13-SEP-16	0.320	ppb
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Flush180	13-SEP-16	0.400	ppb
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Flush180	13-SEP-16	0.270	ppb
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Flush180	13-SEP-16	0.340	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F14	Corner				
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Flush180	13-SEP-16	0.530	ppb
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Initial	13-SEP-16	0.680	ppb
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Initial	13-SEP-16	1.200	ppb
51275	51275-1-HAL-F14	Outside Girls Bathroom NW Corner	Initial	11-JAN-2024	1.510	ug/L
51275	51275-1-HAL-F13	Outside Girls Bathroom NW Corner	Initial	11-JAN-2024	1.210	ug/L
51275	51275-2-HAL-F02	Outside Room 216	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F02	Outside Room 216	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F02	Outside Room 216	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F02	Outside Room 216	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F02	Outside Room 216	Initial	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F03	Outside Room 217	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F03	Outside Room 217	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F03	Outside Room 217	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F03	Outside Room 217	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F03	Outside Room 217	Initial	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F01	Outside Room 226	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F01	Outside Room 226	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F01	Outside Room 226	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F01	Outside Room 226	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F01	Outside Room 226	Initial	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F04	Outside Room 227	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F04	Outside Room 227	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F04	Outside Room 227	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F04	Outside Room 227	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-F04	Outside Room 227	Initial	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-BF01	Outside Room 227	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-BF01	Outside Room 227	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-BF01	Outside Room 227	Flush	11-JAN-2024	1.000	ug/L
51275	51275-2-HAL-BF01	Outside Room 227	Initial	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F02	Outside Room 316	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F02	Outside Room 316	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F02	Outside Room 316	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F02	Outside Room 316	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F02	Outside Room 316	Initial	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F03	Outside Room 317	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-	Outside Room 317	Flush	11-JAN-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51275	51275-3-HAL-F03	Outside Room 317	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F03	Outside Room 317	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F03	Outside Room 317	Initial	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F04	Outside Room 327	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F04	Outside Room 327	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F04	Outside Room 327	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F04	Outside Room 327	Initial	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F01	Outside Room 338	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F01	Outside Room 338	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F01	Outside Room 338	Flush	11-JAN-2024	1.000	ug/L
51275	51275-3-HAL-F01	Outside Room 338	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F07	Outside West side of Gym	Flush180	16-MAY-23	1.330	ug/L
51275	51275-1-HAL-F07	Outside West side of Gym	Flush180	16-MAY-23	1.000	ug/L
51275	51275-1-HAL-F07	Outside West side of Gym	Flush180	16-MAY-23	1.000	ug/L
51275	51275-1-HAL-F07	Outside West side of Gym	Flush180	16-MAY-23	1.000	ug/L
51275	51275-1-HAL-F08	Outside West side of Gym	Flush180	13-SEP-16	0.900	ppb
51275	51275-1-HAL-F08	Outside West side of Gym	Flush180	13-SEP-16	1.200	ppb
51275	51275-1-HAL-F07	Outside West side of Gym	Flush180	13-SEP-16	2.200	ppb
51275	51275-1-HAL-F07	Outside West side of Gym	Flush180	13-SEP-16	3.100	ppb
51275	51275-1-HAL-F07	Outside West side of Gym	Flush180	13-SEP-16	1.900	ppb
51275	51275-1-HAL-F07	Outside West side of Gym	Flush180	13-SEP-16	2.600	ppb
51275	51275-1-HAL-F08	Outside West side of Gym	Flush180	13-SEP-16	1.400	ppb
51275	51275-1-HAL-F08	Outside West side of Gym	Flush180	13-SEP-16	0.750	ppb
51275	51275-1-HAL-F07	Outside West side of Gym	Initial	16-MAY-23	1.600	ug/L
51275	51275-1-HAL-F07	Outside West side of Gym	Initial	13-SEP-16	8.300	ppb
51275	51275-1-HAL-F08	Outside West side of Gym	Initial	13-SEP-16	2.200	ppb
51275	51275-1-POL-F01	Pool	Flush180	16-MAY-23	3.630	ug/L
51275	51275-1-POL-F01	Pool	Flush180	16-MAY-23	3.920	ug/L
51275	51275-1-POL-F01	Pool	Flush180	16-MAY-23	3.360	ug/L
51275	51275-1-POL-F01	Pool	Flush180	16-MAY-23	3.510	ug/L
51275	51275-1-POL-F01	Pool	Flush180	13-SEP-16	4.200	ppb
51275	51275-1-POL-F01	Pool	Flush180	13-SEP-16	5.100	ppb
51275	51275-1-POL-F01	Pool	Flush180	13-SEP-16	4.400	ppb
51275	51275-1-POL-F01	Pool	Flush180	13-SEP-16	4.900	ppb
51275	51275-1-POL-F01	Pool	Initial	16-MAY-23	4.210	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51275	51275-1-POL-F01	Pool	Initial	13-SEP-16	6.300	ppb
51275	51275-2-KIT-KS-03	Pot Fillers by Stove	Flush180	13-SEP-16	0.990	ppb
51275	51275-2-KIT-KS-03	Pot Fillers by Stove	Flush180	13-SEP-16	2.700	ppb
51275	51275-2-KIT-KS-04	Pot Fillers by Stove	Flush180	13-SEP-16	1.100	ppb
51275	51275-2-KIT-KS-04	Pot Fillers by Stove	Flush180	13-SEP-16	2.000	ppb
51275	51275-2-KIT-KS-04	Pot Fillers by Stove	Flush180	13-SEP-16	1.200	ppb
51275	51275-2-KIT-KS-04	Pot Fillers by Stove	Flush180	13-SEP-16	0.840	ppb
51275	51275-2-KIT-KS-03	Pot Fillers by Stove	Flush180	13-SEP-16	1.200	ppb
51275	51275-2-KIT-KS-03	Pot Fillers by Stove	Flush180	13-SEP-16	0.720	ppb
51275	51275-2-KIT-KS-03	Pot Fillers by Stove	Initial	13-SEP-16	2.300	ppb
51275	51275-2-KIT-KS-04	Pot Fillers by Stove	Initial	13-SEP-16	5.600	ppb
51275	51275-130-F01	Pre-k RM 130	Flush180	13-SEP-16	0.440	ppb
51275	51275-130-F01	Pre-k RM 130	Flush180	13-SEP-16	0.480	ppb
51275	51275-130-F01	Pre-k RM 130	Flush180	13-SEP-16	0.440	ppb
51275	51275-130-F01	Pre-k RM 130	Flush180	13-SEP-16	0.490	ppb
51275	51275-130-F01	Pre-k RM 130	Initial	13-SEP-16	0.960	ppb
51275	51275-130-S01	RM 130 North Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-130-S01	RM 130 North Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-130-S01	RM 130 North Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-130-S01	RM 130 North Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-130-S01	RM 130 North Sink	Flush180	13-SEP-16	0.700	ppb
51275	51275-130-S01	RM 130 North Sink	Flush180	13-SEP-16	0.410	ppb
51275	51275-130-S01	RM 130 North Sink	Flush180	13-SEP-16	0.390	ppb
51275	51275-130-S01	RM 130 North Sink	Flush180	13-SEP-16	0.440	ppb
51275	51275-130-S01	RM 130 North Sink	Initial	13-SEP-16	1.400	ppb
51275	51275-130-S01	RM 130 North Sink	Initial	11-JAN-2024	1.000	ug/L
51275	51275-130-S02	RM 130 South Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-130-S02	RM 130 South Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-130-S02	RM 130 South Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-130-S02	RM 130 South Sink	Flush	11-JAN-2024	1.000	ug/L
51275	51275-130-S02	RM 130 South Sink	Flush180	13-SEP-16	1.100	ppb
51275	51275-130-S02	RM 130 South Sink	Flush180	13-SEP-16	1.200	ppb
51275	51275-130-S02	RM 130 South Sink	Flush180	13-SEP-16	0.660	ppb
51275	51275-130-S02	RM 130 South Sink	Flush180	13-SEP-16	0.960	ppb
51275	51275-130-S02	RM 130 South Sink	Initial	13-SEP-16	0.770	ppb
51275	51275-130-S02	RM 130 South Sink	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-162-S01	RM 162 East Sink	Flush180	13-SEP-16	0.089	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51275	51275-1-162-S01	RM 162 East Sink	Flush180	13-SEP-16	0.130	ppb
51275	51275-1-162-S01	RM 162 East Sink	Flush180	13-SEP-16	0.180	ppb
51275	51275-1-162-S01	RM 162 East Sink	Flush180	13-SEP-16	0.120	ppb
51275	51275-1-162-S01	RM 162 East Sink	Initial	13-SEP-16	0.230	ppb
51275	51275-1-162-S02	RM 162 West Sink	Flush180	13-SEP-16	0.270	ppb
51275	51275-1-162-S02	RM 162 West Sink	Flush180	13-SEP-16	0.190	ppb
51275	51275-1-162-S02	RM 162 West Sink	Flush180	13-SEP-16	0.210	ppb
51275	51275-1-162-S02	RM 162 West Sink	Flush180	13-SEP-16	0.170	ppb
51275	51275-1-162-S02	RM 162 West Sink	Initial	13-SEP-16	0.180	ppb
51275	51275-2-HALL-F04	SE Corner Outside Bathroom	Flush180	14-SEP-16	1.200	ppb
51275	51275-2-HALL-F04	SE Corner Outside Bathroom	Flush180	14-SEP-16	1.200	ppb
51275	51275-2-HALL-F04	SE Corner Outside Bathroom	Flush180	14-SEP-16	1.100	ppb
51275	51275-2-HALL-F04	SE Corner Outside Bathroom	Flush180	14-SEP-16	0.960	ppb
51275	51275-2-HALL-F04	SE Corner Outside Bathroom	Initial	14-SEP-16	1.700	ppb
51275	51275-1-HAL-F05	SE Corner outside boys bathroom	Flush180	13-SEP-16	0.800	ppb
51275	51275-1-HAL-F05	SE Corner outside boys bathroom	Flush180	13-SEP-16	0.350	ppb
51275	51275-1-HAL-F05	SE Corner outside boys bathroom	Flush180	13-SEP-16	0.870	ppb
51275	51275-1-HAL-F05	SE Corner outside boys bathroom	Flush180	13-SEP-16	1.200	ppb
51275	51275-1-HAL-F06	SE Corner outside boys bathroom	Flush180	13-SEP-16	0.750	ppb
51275	51275-1-HAL-F06	SE Corner outside boys bathroom	Flush180	13-SEP-16	1.700	ppb
51275	51275-1-HAL-F06	SE Corner outside boys bathroom	Flush180	13-SEP-16	0.760	ppb
51275	51275-1-HAL-F06	SE Corner outside boys bathroom	Flush180	13-SEP-16	0.810	ppb
51275	51275-1-HAL-F05	SE Corner outside boys bathroom	Initial	13-SEP-16	0.860	ppb
51275	51275-1-HAL-F06	SE Corner outside boys bathroom	Initial	13-SEP-16	0.510	ppb
51275	51275-1-HAL-F05	SE Corner outside boys bathroom, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F05	SE Corner outside boys bathroom, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F05	SE Corner outside boys bathroom, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F05	SE Corner outside boys bathroom, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F05	SE Corner outside boys bathroom, Left Fountain	Initial	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF01	SE Corner outside boys bathroom, Right Bottle Filler	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF01	SE Corner outside boys bathroom, Right Bottle Filler	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF01	SE Corner outside boys bathroom, Right Bottle Filler	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF01	SE Corner outside boys bathroom, Right Bottle Filler	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-RBF01	SE Corner outside boys bathroom, Right Bottle Filler	Initial	11-JAN-2024	1.000	ug/L
51275	51275-2-HALL-F05	SW Corner Outside Bathroom	Flush180	14-SEP-16	0.700	ppb
51275	51275-2-HALL-F05	SW Corner Outside Bathroom	Flush180	14-SEP-16	0.720	ppb
51275	51275-2-HALL-F05	SW Corner Outside Bathroom	Flush180	14-SEP-16	0.700	ppb
51275	51275-2-	SW Corner Outside Bathroom	Flush180	14-SEP-16	0.930	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HALL-F05					
51275	51275-2-HALL-F05	SW Corner Outside Bathroom	Initial	14-SEP-16	0.900	ppb
51275	51275-1-HAL-F09	SW Hall Corner, Left Fountain	Flush	11-JAN-2024	1.300	ug/L
51275	51275-1-HAL-F09	SW Hall Corner, Left Fountain	Flush	11-JAN-2024	1.220	ug/L
51275	51275-1-HAL-F09	SW Hall Corner, Left Fountain	Flush	11-JAN-2024	1.130	ug/L
51275	51275-1-HAL-F09	SW Hall Corner, Left Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F09	SW Hall Corner, Left Fountain	Initial	11-JAN-2024	1.030	ug/L
51275	51275-1-HAL-F10	SW Hall Corner, Right Fountain	Flush	11-JAN-2024	1.060	ug/L
51275	51275-1-HAL-F10	SW Hall Corner, Right Fountain	Flush	11-JAN-2024	1.050	ug/L
51275	51275-1-HAL-F10	SW Hall Corner, Right Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F10	SW Hall Corner, Right Fountain	Flush	11-JAN-2024	1.000	ug/L
51275	51275-1-HAL-F10	SW Hall Corner, Right Fountain	Initial	11-JAN-2024	1.360	ug/L
51275	51275-2-HAL-BF01	Second Floor Bottle Filler	Flush180	23-DEC-20	1.000	ug/L
51275	51275-2-HAL-BF01	Second Floor Bottle Filler	Flush180	23-DEC-20	1.000	ug/L
51275	51275-2-HAL-BF01	Second Floor Bottle Filler	Flush180	23-DEC-20	1.000	ug/L
51275	51275-2-HAL-BF01	Second Floor Bottle Filler	Flush180	23-DEC-20	1.000	ug/L
51275	51275-2-HAL-BF01	Second Floor Bottle Filler	Initial	23-DEC-20	1.000	ug/L
51275	51275-1-151-S01	Sink in 151	Flush180	13-SEP-16	16.000	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	13-SEP-16	26.000	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	13-SEP-16	19.000	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	13-SEP-16	43.000	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	11-JAN-17	3.400	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	11-JAN-17	2.400	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	19-MAY-17	0.839	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	19-MAY-17	1.440	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	11-JAN-17	2.900	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	19-MAY-17	1.440	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	19-MAY-17	1.170	ppb
51275	51275-1-151-S01	Sink in 151	Flush180	11-JAN-17	8.500	ppb
51275	51275-1-151-S01	Sink in 151	Initial	13-SEP-16	15.000	ppb
51275	51275-1-151-S01	Sink in 151	Initial	11-JAN-17	26.000	ppb
51275	51275-1-151-S01	Sink in 151	Initial	19-MAY-17	2.310	ppb
51275	51275-1-HAL-F01	TEL Building Outside Girl Washroom east side	Flush180	13-SEP-16	0.240	ppb
51275	51275-1-HAL-F01	TEL Building Outside Girl Washroom east side	Flush180	13-SEP-16	1.100	ppb
51275	51275-1-HAL-F01	TEL Building Outside Girl Washroom east side	Flush180	13-SEP-16	0.570	ppb
51275	51275-1-HAL-F01	TEL Building Outside Girl Washroom east side	Flush180	13-SEP-16	0.710	ppb
51275	51275-1-HAL-F01	TEL Building Outside Girl Washroom east side	Initial	13-SEP-16	0.880	ppb
51275	51275-1-HAL-F01	TEL Building Outside Girl Washroom east side	Flush180	13-SEP-16	0.930	ppb

Water Quality Assessment
Maria Saucedo Elementary Scholastic Academy

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Washroom west side				
51275	51275-1-HAL-F02	TEL Building Outside Girl Washroom west side	Flush180	13-SEP-16	0.160	ppb
51275	51275-1-HAL-F02	TEL Building Outside Girl Washroom west side	Flush180	13-SEP-16	0.220	ppb
51275	51275-1-HAL-F02	TEL Building Outside Girl Washroom west side	Flush180	13-SEP-16	0.140	ppb
51275	51275-1-HAL-F02	TEL Building Outside Girl Washroom west side	Initial	13-SEP-16	0.860	ppb