



**Sep 10, 2024**

**SMYSER**

**4310 N MELVINA AVE, Chicago IL 60634.**

Dear **SMYSER** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**SMYSER**

**4310 N MELVINA AVE, Chicago IL 60634.**

Estimadas familias de **SMYSER**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Flush180	11-JUN-16	0.311	ppb
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Flush180	11-JUN-16	0.303	ppb
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Flush180	11-JUN-16	0.348	ppb
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Flush180	11-JUN-16	0.323	ppb
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Initial	11-JUN-16	0.477	ppb
51035	51035-1-HAL-F01	Main - Across From Cafeteria (East), Fountain 1	Initial	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-RBF02	Main - Across From Cafeteria, (West), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-RBF02	Main - Across From Cafeteria, (West), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-RBF02	Main - Across From Cafeteria, (West), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-RBF02	Main - Across From Cafeteria, (West), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F02	Main - Across From Cafeteria, (West), Fountain 2	Flush180	11-JUN-16	0.280	ppb
51035	51035-1-HAL-F02	Main - Across From Cafeteria, (West), Fountain 2	Flush180	11-JUN-16	0.424	ppb
51035	51035-1-HAL-F02	Main - Across From Cafeteria, (West), Fountain 2	Flush180	11-JUN-16	0.289	ppb
51035	51035-1-HAL-F02	Main - Across From Cafeteria, (West), Fountain 2	Flush180	11-JUN-16	0.306	ppb
51035	51035-1-HAL-F02	Main - Across From Cafeteria, (West), Fountain 2	Initial	11-JUN-16	0.380	ppb
51035	51035-1-HAL-RBF02	Main - Across From Cafeteria, (West), Fountain 2	Initial	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-RBF01	Main - Across From Room 103 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-RBF01	Main - Across From Room 103 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-RBF01	Main - Across From Room 103 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F03	Main - Across From Room 103 (North), Fountain 1	Flush180	11-JUN-16	0.583	ppb
51035	51035-1-HAL-F03	Main - Across From Room 103 (North), Fountain 1	Flush180	11-JUN-16	0.442	ppb
51035	51035-1-HAL-F03	Main - Across From Room 103 (North), Fountain 1	Flush180	11-JUN-16	0.525	ppb
51035	51035-1-HAL-F03	Main - Across From Room 103 (North), Fountain 1	Flush180	11-JUN-16	0.531	ppb
51035	51035-1-HAL-F03	Main - Across From Room 103 (North), Fountain 1	Initial	11-JUN-16	0.680	ppb
51035	51035-1-HAL-RBF01	Main - Across From Room 103 (North), Fountain 1	Initial	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F04	Main - Across From Room 103 (South), Fountain 2	Flush180	11-JUN-16	0.334	ppb
51035	51035-1-HAL-F04	Main - Across From Room 103 (South), Fountain 2	Flush180	11-JUN-16	0.329	ppb
51035	51035-1-HAL-F04	Main - Across From Room 103 (South), Fountain 2	Flush180	11-JUN-16	0.370	ppb
51035	51035-1-HAL-F04	Main - Across From Room 103 (South), Fountain 2	Flush180	11-JUN-16	0.342	ppb
51035	51035-1-HAL-F04	Main - Across From Room 103 (South), Fountain 2	Flush180	18-AUG-20	1.510	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51035	51035-1-HAL-F04	Main - Across From Room 103 (South), Fountain 2	Initial	11-JUN-16	0.438	ppb
51035	51035-1-HAL-F04	Main - Across From Room 103 (South), Fountain 2	Initial	18-AUG-20	1.520	ug/L
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Flush180	11-JUN-16	0.936	ppb
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Flush180	11-JUN-16	0.763	ppb
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Flush180	11-JUN-16	0.730	ppb
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Flush180	11-JUN-16	0.723	ppb
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Initial	11-JUN-16	1.110	ppb
51035	51035-2-HAL-F05	Main - Across From Room 203 (North), Fountain 1	Initial	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Flush	28-NOV-2023	1.090	ug/L
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Flush	28-NOV-2023	1.120	ug/L
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Flush	28-NOV-2023	1.890	ug/L
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Flush180	11-JUN-16	0.850	ppb
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Flush180	11-JUN-16	0.580	ppb
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Flush180	11-JUN-16	0.538	ppb
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Flush180	11-JUN-16	0.670	ppb
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Initial	11-JUN-16	1.110	ppb
51035	51035-2-HAL-F06	Main - Across From Room 203 (South), Fountain 2	Initial	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F04	Main - Across From Room 207 (South), Fountain 2	Flush180	11-JUN-16	0.453	ppb
51035	51035-2-HAL-F04	Main - Across From Room 207 (South), Fountain 2	Flush180	11-JUN-16	0.496	ppb
51035	51035-2-HAL-F04	Main - Across From Room 207 (South), Fountain 2	Flush180	11-JUN-16	0.459	ppb
51035	51035-2-HAL-F04	Main - Across From Room 207 (South), Fountain 2	Flush180	11-JUN-16	0.459	ppb
51035	51035-2-HAL-F04	Main - Across From Room 207 (South), Fountain 2	Initial	11-JUN-16	0.594	ppb
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Flush180	11-JUN-16	0.773	ppb
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Flush180	11-JUN-16	0.604	ppb
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Flush180	11-JUN-16	0.690	ppb
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Flush180	11-JUN-16	0.671	ppb
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Initial	11-JUN-16	0.664	ppb
51035	51035-2-HAL-F03	Main - Across From Room 207, (North), Fountain 1	Initial	28-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51035	51035-2-HAL-F01	Main - Across From Room 212 (East), Fountain 1	Flush180	11-JUN-16	0.358	ppb
51035	51035-2-HAL-F01	Main - Across From Room 212 (East), Fountain 1	Flush180	11-JUN-16	0.430	ppb
51035	51035-2-HAL-F01	Main - Across From Room 212 (East), Fountain 1	Flush180	11-JUN-16	0.509	ppb
51035	51035-2-HAL-F01	Main - Across From Room 212 (East), Fountain 1	Flush180	11-JUN-16	0.340	ppb
51035	51035-2-HAL-F01	Main - Across From Room 212 (East), Fountain 1	Initial	11-JUN-16	0.696	ppb
51035	51035-2-HAL-F02	Main - Across From Room 212 (West), Fountain 2	Flush180	11-JUN-16	0.335	ppb
51035	51035-2-HAL-F02	Main - Across From Room 212 (West), Fountain 2	Flush180	11-JUN-16	0.361	ppb
51035	51035-2-HAL-F02	Main - Across From Room 212 (West), Fountain 2	Flush180	11-JUN-16	0.327	ppb
51035	51035-2-HAL-F02	Main - Across From Room 212 (West), Fountain 2	Flush180	11-JUN-16	0.331	ppb
51035	51035-2-HAL-F02	Main - Across From Room 212 (West), Fountain 2	Initial	11-JUN-16	0.718	ppb
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Flush180	11-JUN-16	0.565	ppb
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Flush180	11-JUN-16	0.762	ppb
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Flush180	11-JUN-16	0.734	ppb
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Flush180	11-JUN-16	0.587	ppb
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Initial	11-JUN-16	0.722	ppb
51035	51035-3-HAL-F03	Main - Across From Room 300 (North), Fountain 1	Initial	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Flush180	11-JUN-16	0.485	ppb
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Flush180	11-JUN-16	0.622	ppb
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Flush180	11-JUN-16	0.574	ppb
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Flush180	11-JUN-16	0.526	ppb
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Initial	11-JUN-16	0.810	ppb
51035	51035-3-HAL-F04	Main - Across From Room 300 (South), Fountain 2	Initial	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Flush180	11-JUN-16	0.562	ppb
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Flush180	11-JUN-16	0.498	ppb
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Flush180	11-JUN-16	0.455	ppb
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Flush180	11-JUN-16	0.510	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	(South), Fountain 2				
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Initial	11-JUN-16	0.593	ppb
51035	51035-3-HAL-F02	Main - Across From Room 305 (South), Fountain 2	Initial	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-F01	Main - Across From Room 305, (North), Fountain 1	Flush180	11-JUN-16	0.811	ppb
51035	51035-3-HAL-F01	Main - Across From Room 305, (North), Fountain 1	Flush180	11-JUN-16	0.682	ppb
51035	51035-3-HAL-F01	Main - Across From Room 305, (North), Fountain 1	Flush180	11-JUN-16	0.741	ppb
51035	51035-3-HAL-F01	Main - Across From Room 305, (North), Fountain 1	Flush180	11-JUN-16	0.725	ppb
51035	51035-3-HAL-F01	Main - Across From Room 305, (North), Fountain 1	Flush180	18-AUG-20	1.430	ug/L
51035	51035-3-HAL-F01	Main - Across From Room 305, (North), Fountain 1	Initial	11-JUN-16	0.809	ppb
51035	51035-3-HAL-F01	Main - Across From Room 305, (North), Fountain 1	Initial	18-AUG-20	1.000	ug/L
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Flush180	11-JUN-16	0.290	ppb
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Flush180	11-JUN-16	0.206	ppb
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Flush180	11-JUN-16	0.153	ppb
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Flush180	11-JUN-16	0.130	ppb
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Initial	11-JUN-16	1.140	ppb
51035	51035-1-KIT-KS05	Main - Kitchen (North), Sink 1	Initial	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Flush180	11-JUN-16	0.130	ppb
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Flush180	11-JUN-16	1.000	ppb
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Flush180	11-JUN-16	0.226	ppb
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Flush180	11-JUN-16	1.380	ppb
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Initial	11-JUN-16	1.300	ppb
51035	51035-1-KIT-KS06	Main - Kitchen (South), Sink 2	Initial	28-NOV-2023	1.000	ug/L
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Flush180	17-AUG-16	1.000	ppb
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Flush180	17-AUG-16	1.000	ppb
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Flush180	17-AUG-16	1.000	ppb
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Flush180	17-AUG-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S09	Wall Sink				
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Initial	17-AUG-16	1.000	ppb
51035	51035-1-104-S09	Main- Inside Room 104, Northern Wall Sink	Initial	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Flush	28-NOV-2023	1.750	ug/L
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Flush	28-NOV-2023	1.330	ug/L
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Flush	28-NOV-2023	1.020	ug/L
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Flush180	17-AUG-16	2.900	ppb
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Flush180	17-AUG-16	1.500	ppb
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Flush180	17-AUG-16	1.300	ppb
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Flush180	17-AUG-16	2.000	ppb
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Initial	17-AUG-16	4.700	ppb
51035	51035-1-HAL-F07	Main- Outside Principle's Office, Fountain 1	Initial	28-NOV-2023	2.590	ug/L
51035	51035-1-HAL-F08	Main- Outside Principle's Office, Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F08	Main- Outside Principle's Office, Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F08	Main- Outside Principle's Office, Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-1-HAL-F08	Main- Outside Principle's Office, Fountain 2	Flush180	17-AUG-16	1.000	ppb
51035	51035-1-HAL-F08	Main- Outside Principle's Office, Fountain 2	Flush180	17-AUG-16	1.000	ppb
51035	51035-1-HAL-F08	Main- Outside Principle's Office, Fountain 2	Flush180	17-AUG-16	1.000	ppb
51035	51035-1-HAL-F08	Main- Outside Principle's Office, Fountain 2	Initial	17-AUG-16	1.000	ppb
51035	51035-1-HAL-F08	Main- Outside Principle's Office, Fountain 2	Initial	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-RBF01	Main-Across From Room 207 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-RBF01	Main-Across From Room 207 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-RBF01	Main-Across From Room 207 (South), Fountain 2	Flush	28-NOV-2023	1.000	ug/L
51035	51035-2-HAL-RBF01	Main-Across From Room 207 (South), Fountain 2	Initial	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-RBF01	Main-Across From Room 305 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-RBF01	Main-Across From Room 305 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-RBF01	Main-Across From Room 305 (North), Fountain 1	Flush	28-NOV-2023	1.000	ug/L
51035	51035-3-HAL-RBF01	Main-Across From Room 305 (North), Fountain 1	Initial	28-NOV-2023	1.040	ug/L
52570	52570-B-CAF-F01	Branch- Cafeteria North, Fountain	Flush180	11-JUN-16	0.351	ppb
52570	52570-B-CAF-F01	Branch- Cafeteria North, Fountain	Flush180	11-JUN-16	0.342	ppb
52570	52570-B-CAF-F01	Branch- Cafeteria North, Fountain	Flush180	11-JUN-16	0.338	ppb
52570	52570-B-CAF-F01	Branch- Cafeteria North, Fountain	Flush180	11-JUN-16	0.342	ppb
52570	52570-B-CAF-F01	Branch- Cafeteria North, Fountain	Initial	11-JUN-16	0.846	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52570	52570-B-CAF-RBF01	Branch- Cafeteria North, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-B-CAF-RBF01	Branch- Cafeteria North, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-B-CAF-RBF01	Branch- Cafeteria North, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-B-CAF-RBF01	Branch- Cafeteria North, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-B-CAF-RBF01	Branch- Cafeteria North, Fountain	Initial	28-NOV-2023	2.990	ug/L
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Flush180	11-JUN-16	0.413	ppb
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Flush180	11-JUN-16	1.510	ppb
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Flush180	11-JUN-16	0.697	ppb
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Flush180	11-JUN-16	0.443	ppb
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Initial	11-JUN-16	1.370	ppb
52570	52570-B-CAF-S02	Branch- Cafeteria South, Sink	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush	28-NOV-2023	6.150	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush	19-DEC-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush	19-DEC-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush	19-DEC-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush	19-DEC-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	15-DEC-22	9.910	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	15-DEC-22	4.720	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	15-DEC-22	1.030	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	15-DEC-22	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	02-SEP-22	33.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	02-SEP-22	10.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	02-SEP-22	6.970	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	19-AUG-22	34.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	19-AUG-22	32.300	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	19-AUG-22	54.500	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	19-AUG-22	76.400	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Flush180	02-SEP-22	12.900	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Initial	15-DEC-22	17.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Initial	19-AUG-22	134.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Initial	02-SEP-22	50.100	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-101-BF01	Branch- Inside Room 101, Bottle Filler	Initial	19-DEC-2023	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Flush180	19-AUG-22	1.320	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Initial	19-AUG-22	1.000	ug/L
52570	52570-1-101-F01	Branch- Inside Room 101, Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Flush180	17-AUG-16	1.300	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Flush180	17-AUG-16	1.600	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Flush180	17-AUG-16	1.000	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Flush180	11-JUN-16	18.500	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Flush180	11-JUN-16	54.500	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Flush180	11-JUN-16	129.000	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Flush180	11-JUN-16	9.560	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Flush180	17-AUG-16	1.600	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Initial	17-AUG-16	40.000	ppb
52570	52570-1-101-S04	Branch- Inside Room 101, Sink	Initial	11-JUN-16	93.500	ppb
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	14-OCT-22	3.070	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	14-OCT-22	1.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	14-OCT-22	1.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	14-OCT-22	1.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	19-AUG-22	2.790	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	19-AUG-22	2.170	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	19-AUG-22	1.770	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	20-SEP-22	2.750	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	20-SEP-22	12.400	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	20-SEP-22	14.700	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S01					
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	20-SEP-22	4.630	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	02-SEP-22	1.330	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	02-SEP-22	4.130	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	02-SEP-22	17.000	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Flush180	02-SEP-22	26.200	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Initial	14-OCT-22	3.200	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Initial	19-AUG-22	5.190	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Initial	20-SEP-22	2.550	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Initial	02-SEP-22	3.120	ug/L
52570	52570-1-101-S01	Branch- Inside Room 101, Sink	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	14-OCT-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	14-OCT-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	14-OCT-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	14-OCT-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	20-SEP-22	5.900	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	20-SEP-22	5.970	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	20-SEP-22	5.910	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Flush180	20-SEP-22	9.790	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Initial	14-OCT-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Initial	19-AUG-22	1.000	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Initial	20-SEP-22	7.460	ug/L
52570	52570-1-102-BF01	Branch- Inside Room 102, Bottle Filler	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Flush180	19-AUG-22	1.000	ug/L

## Water Quality Assessment Washington D Smyser Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Fountain				
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Initial	19-AUG-22	1.000	ug/L
52570	52570-1-102-F01	Branch- Inside Room 102, Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Flush180	11-JUN-16	5.680	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Flush180	11-JUN-16	7.540	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Flush180	11-JUN-16	3.640	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Flush180	11-JUN-16	0.238	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Flush180	17-AUG-16	1.500	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Flush180	17-AUG-16	1.300	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Flush180	17-AUG-16	1.100	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Flush180	17-AUG-16	1.800	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Initial	11-JUN-16	17.400	ppb
52570	52570-1-102-S02	Branch- Inside Room 102, Sink	Initial	17-AUG-16	4.500	ppb
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	02-SEP-22	16.100	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	02-SEP-22	9.790	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	02-SEP-22	3.490	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	02-SEP-22	41.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	20-SEP-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	20-SEP-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	20-SEP-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Flush180	20-SEP-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Initial	02-SEP-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Initial	19-AUG-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Initial	20-SEP-22	1.000	ug/L
52570	52570-1-102-S01	Branch- Inside Room 102, Sink	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush	28-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush180	11-JUN-16	7.140	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush180	11-JUN-16	23.800	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush180	11-JUN-16	12.200	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush180	11-JUN-16	8.150	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush180	17-AUG-16	1.700	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush180	17-AUG-16	1.400	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush180	17-AUG-16	1.400	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Flush180	17-AUG-16	1.400	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Initial	11-JUN-16	34.800	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Initial	17-AUG-16	1.600	ppb
52570	52570-1-103-S01	Branch- Inside Room 103, Sink	Initial	28-NOV-2023	1.000	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush	28-NOV-2023	1.570	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush180	02-SEP-22	1.420	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush180	02-SEP-22	1.960	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush180	02-SEP-22	1.170	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush180	02-SEP-22	1.420	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush180	19-AUG-22	39.800	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush180	19-AUG-22	14.400	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush180	19-AUG-22	7.420	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Flush180	19-AUG-22	7.140	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Initial	02-SEP-22	1.680	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Initial	19-AUG-22	30.400	ug/L
52570	52570-2-201-BF01	Branch- Inside Room 201, Bottle Filler	Initial	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-BF04	Branch- Inside Room 201, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-BF04	Branch- Inside Room 201, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-BF04	Branch- Inside Room 201, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-BF04	Branch- Inside Room 201, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-BF04	Branch- Inside Room 201, Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Flush180	19-AUG-22	1.790	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Flush180	19-AUG-22	1.010	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Initial	19-AUG-22	2.110	ug/L
52570	52570-2-201-F01	Branch- Inside Room 201, Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F04	Branch- Inside Room 201, Right Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F04	Branch- Inside Room 201, Right Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F04	Branch- Inside Room 201, Right Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F04	Branch- Inside Room 201, Right Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F04	Branch- Inside Room 201, Right Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush180	15-DEC-22	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush180	15-DEC-22	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush180	15-DEC-22	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush180	15-DEC-22	2.940	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush180	19-AUG-22	10.100	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush180	19-AUG-22	2.710	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Flush180	19-AUG-22	1.580	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Initial	15-DEC-22	1.300	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Initial	19-AUG-22	10.500	ug/L
52570	52570-2-201-S01	Branch- Inside Room 201, Sink	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F03	Branch- Outside RoBranch-Outside Room 102, Founta	Flush180	11-JUN-16	0.268	ppb
52570	52570-1-HAL-F03	Branch- Outside RoBranch-Outside Room 102, Founta	Flush180	11-JUN-16	0.235	ppb
52570	52570-1-HAL-F03	Branch- Outside RoBranch-Outside Room 102, Founta	Flush180	11-JUN-16	0.243	ppb
52570	52570-1-HAL-F03	Branch- Outside RoBranch-Outside Room 102, Founta	Flush180	11-JUN-16	0.221	ppb
52570	52570-1-HAL-F03	Branch- Outside RoBranch-Outside Room 102, Founta	Initial	11-JUN-16	0.570	ppb
52570	52570-2-HAL-F01	Branch- Outside Room 203, Fountain	Flush180	11-JUN-16	0.394	ppb
52570	52570-2-HAL-F01	Branch- Outside Room 203, Fountain	Flush180	11-JUN-16	0.356	ppb
52570	52570-2-HAL-F01	Branch- Outside Room 203, Fountain	Flush180	11-JUN-16	0.337	ppb
52570	52570-2-HAL-F01	Branch- Outside Room 203, Fountain	Flush180	11-JUN-16	0.208	ppb
52570	52570-2-HAL-F01	Branch- Outside Room 203, Fountain	Initial	11-JUN-16	0.350	ppb
52570	52570-1-KIT-KS06	Branch-Kitchen Dishwashing North Wall Sink 2	Flush180	17-AUG-16	12.000	ppb
52570	52570-1-KIT-KS06	Branch-Kitchen Dishwashing North Wall Sink 2	Flush180	17-AUG-16	7.700	ppb
52570	52570-1-KIT-KS06	Branch-Kitchen Dishwashing North Wall Sink 2	Flush180	17-AUG-16	13.000	ppb
52570	52570-1-KIT-	Branch-Kitchen Dishwashing North	Flush180	17-AUG-16	9.700	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS06	Wall Sink 2				
52570	52570-1-KIT-KS06	Branch-Kitchen Dishwashing North Wall Sink 2	Initial	17-AUG-16	18.000	ppb
52570	52570-1-KIT-KS07	Branch-Kitchen East Wall Sink 3	Flush180	17-AUG-16	5.800	ppb
52570	52570-1-KIT-KS07	Branch-Kitchen East Wall Sink 3	Flush180	17-AUG-16	8.600	ppb
52570	52570-1-KIT-KS07	Branch-Kitchen East Wall Sink 3	Flush180	17-AUG-16	6.400	ppb
52570	52570-1-KIT-KS07	Branch-Kitchen East Wall Sink 3	Flush180	17-AUG-16	5.400	ppb
52570	52570-1-KIT-KS07	Branch-Kitchen East Wall Sink 3	Initial	17-AUG-16	12.000	ppb
52570	52570-1-KIT-KS05	Branch-Kitchen South Wall Sink 1	Flush180	17-AUG-16	7.000	ppb
52570	52570-1-KIT-KS05	Branch-Kitchen South Wall Sink 1	Flush180	17-AUG-16	4.800	ppb
52570	52570-1-KIT-KS05	Branch-Kitchen South Wall Sink 1	Flush180	17-AUG-16	4.400	ppb
52570	52570-1-KIT-KS05	Branch-Kitchen South Wall Sink 1	Flush180	17-AUG-16	5.600	ppb
52570	52570-1-KIT-KS05	Branch-Kitchen South Wall Sink 1	Initial	17-AUG-16	8.800	ppb
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Initial	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-BF01	Branch-b/t Washrooms across from rm 101 , Bottle Filler	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Initial	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F02	Branch-b/t Washrooms across from rm 101, Center Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Flush180	19-AUG-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	from rm 101, Left Fountain				
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Initial	19-AUG-22	1.110	ug/L
52570	52570-1-HAL-F01	Branch-b/t Washrooms across from rm 101, Left Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Initial	19-AUG-22	1.000	ug/L
52570	52570-1-HAL-F04	Branch-b/t Washrooms across from rm 101, Right Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Initial	19-AUG-22	1.320	ug/L
52570	52570-2-HAL-F03	Branch-b/t Washrooms across from rm 201, Center Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Flush	28-NOV-2023	1.000	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Flush180	19-AUG-22	1.000	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Initial	19-AUG-22	1.750	ug/L
52570	52570-2-HAL-F02	Branch-b/t Washrooms across from rm 201, Left Fountain	Initial	28-NOV-2023	1.000	ug/L
52570	52570-1-103-F01	Inside Room 103	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-103-F01	Inside Room 103	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-103-F01	Inside Room 103	Flush	28-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52570	52570-1-103-F01	Inside Room 103	Flush	28-NOV-2023	1.000	ug/L
52570	52570-1-103-F01	Inside Room 103	Initial	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush180	16-JUN-16	0.140	ppb
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush180	16-JUN-16	0.187	ppb
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Flush180	18-AUG-20	1.000	ug/L
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Initial	16-JUN-16	1.000	ppb
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Initial	18-AUG-20	1.000	ug/L
55301	55301-1-HAL-F01	Annex- Across From Electrical Room (North), Founta	Initial	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-F02	Annex- Across From Electrical Room (South), Founta	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-HAL-F02	Annex- Across From Electrical Room (South), Founta	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-HAL-F02	Annex- Across From Electrical Room (South), Founta	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-HAL-F02	Annex- Across From Electrical Room (South), Founta	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-HAL-F02	Annex- Across From Electrical Room (South), Founta	Flush180	18-AUG-20	1.000	ug/L
55301	55301-1-HAL-F02	Annex- Across From Electrical Room (South), Founta	Initial	16-JUN-16	1.000	ppb
55301	55301-1-HAL-F02	Annex- Across From Electrical Room (South), Founta	Initial	18-AUG-20	1.000	ug/L
55301	55301-1-HAL-RBF01	Annex- Across From Electrical Room (South), Fountain	Flush	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-RBF01	Annex- Across From Electrical Room (South), Fountain	Flush	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-RBF01	Annex- Across From Electrical Room (South), Fountain	Flush	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-RBF01	Annex- Across From Electrical Room (South), Fountain	Flush	28-NOV-2023	1.000	ug/L
55301	55301-1-HAL-RBF01	Annex- Across From Electrical Room (South), Fountain	Initial	28-NOV-2023	1.000	ug/L
55301	55301-1-104-S03	Annex- Inside Room 104, Sink	Flush180	16-JUN-16	0.131	ppb
55301	55301-1-104-S03	Annex- Inside Room 104, Sink	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-104-S03	Annex- Inside Room 104, Sink	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-104-S03	Annex- Inside Room 104, Sink	Flush180	16-JUN-16	1.000	ppb
55301	55301-1-104-S03	Annex- Inside Room 104, Sink	Initial	16-JUN-16	0.128	ppb