



Sep 10, 2024

SMYTH

1059 W 13TH ST, Chicago IL 60608.

Dear **SMYTH** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

SMYTH

1059 W 13TH ST, Chicago IL 60608.

Estimadas familias de **SMYTH**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Flush180	06-JUN-16	0.468	ppb
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Flush180	06-JUN-16	0.356	ppb
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Flush180	06-JUN-16	0.355	ppb
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Flush180	06-JUN-16	0.819	ppb
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Initial	06-JUN-16	0.362	ppb
51250	51250-1-N-HAL-F02	Across from Room 109, Left Fountain	Initial	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Flush180	06-JUN-16	0.458	ppb
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Flush180	06-JUN-16	0.467	ppb
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Flush180	06-JUN-16	0.480	ppb
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Flush180	06-JUN-16	0.445	ppb
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Initial	06-JUN-16	0.675	ppb
51250	51250-B-E-KIT-KS01	Basement Kitchen North Sink	Initial	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	04-NOV-16	0.211	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	06-JUN-16	22.900	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	06-JUN-16	19.300	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	06-JUN-16	11.400	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	06-JUN-16	22.600	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	29-JUL-16	1.000	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	29-JUL-16	1.000	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	29-JUL-16	1.000	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	29-JUL-16	1.000	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	04-NOV-16	0.212	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	04-NOV-16	0.199	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	04-NOV-16	0.202	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	03-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Initial	06-JUN-16	7.810	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Initial	29-JUL-16	1.000	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Initial	04-NOV-16	0.550	ppb
51250	51250-B-E-KIT-KS02	Basement Kitchen South Sink	Initial	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Flush180	06-JUN-16	0.532	ppb
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Flush180	06-JUN-16	0.538	ppb
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Flush180	06-JUN-16	0.526	ppb
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Flush180	06-JUN-16	0.531	ppb
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Initial	06-JUN-16	0.383	ppb
51250	51250-B-W-CAF-F03	Basement Lunchroom North Fountain	Initial	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Flush180	06-JUN-16	0.510	ppb
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Flush180	06-JUN-16	0.222	ppb
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Flush180	06-JUN-16	0.598	ppb
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Flush180	06-JUN-16	0.701	ppb
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Initial	06-JUN-16	0.227	ppb
51250	51250-B-W-CAF-F05	Basement Lunchroom South Fountain	Initial	03-MAR-20	1.000	ug/L
51250	51250-1-109-BF01	Bottle Filler in RM 109	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-109-BF01	Bottle Filler in RM 109	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-109-BF01	Bottle Filler in RM 109	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-109-BF01	Bottle Filler in RM 109	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-109-BF01	Bottle Filler in RM 109	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-101-BF01	Bottle Filler in Rm 101	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-BF01	Bottle Filler in Rm 101	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-BF01	Bottle Filler in Rm 101	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-BF01	Bottle Filler in Rm 101	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-103-BF01	Bottle Filler in Rm 103	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-BF01	Bottle Filler in Rm 103	Flush180	18-JAN-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51250	51250-1-103-BF01	Bottle Filler in Rm 103	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-BF01	Bottle Filler in Rm 103	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-BF01	Bottle Filler in Rm 103	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-107-BF01	Bottle Filler in Rm 107	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-BF01	Bottle Filler in Rm 107	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-BF01	Bottle Filler in Rm 107	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-BF01	Bottle Filler in Rm 107	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-BF01	Bottle Filler in Rm 107	Initial	18-JAN-23	1.000	ug/L
51250	51250-B-W-CAF-F04	Cafeteria, Middle Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F04	Cafeteria, Middle Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F04	Cafeteria, Middle Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F04	Cafeteria, Middle Fountain	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-W-CAF-F04	Cafeteria, Middle Fountain	Initial	03-MAR-20	1.000	ug/L
51250	51250-1-107-F01	Drinking Fountain in RM 107	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-F01	Drinking Fountain in RM 107	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-F01	Drinking Fountain in RM 107	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-F01	Drinking Fountain in RM 107	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-F01	Drinking Fountain in RM 107	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-109-F01	Drinking Fountain in RM 109	Flush180	18-JAN-23	2.340	ug/L
51250	51250-1-109-F01	Drinking Fountain in RM 109	Flush180	18-JAN-23	1.260	ug/L
51250	51250-1-109-F01	Drinking Fountain in RM 109	Flush180	18-JAN-23	1.470	ug/L
51250	51250-1-109-F01	Drinking Fountain in RM 109	Flush180	18-JAN-23	1.390	ug/L
51250	51250-1-109-F01	Drinking Fountain in RM 109	Initial	18-JAN-23	23.100	ug/L
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Flush180	06-JUN-16	1.000	ppb
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Flush180	06-JUN-16	1.000	ppb
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Flush180	06-JUN-16	1.000	ppb
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Flush180	06-JUN-16	1.000	ppb
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Flush180	03-MAR-20	2.370	ug/L
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Flush180	03-MAR-20	2.520	ug/L
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Flush180	03-MAR-20	2.650	ug/L
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Flush180	03-MAR-20	2.850	ug/L
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Initial	06-JUN-16	0.440	ppb
51250	51250-1-N-HAL-F04	Fountain Across From Room 104	Initial	03-MAR-20	3.240	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	06-JUN-16	1.880	ppb
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	06-JUN-16	1.690	ppb
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	06-JUN-16	1.950	ppb
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	06-JUN-16	1.880	ppb
51250	51250-1-E-	Fountain Across From Room 109,	Flush180	24-APR-20	5.890	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F03	Right Fountain				
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	24-APR-20	9.980	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	24-APR-20	9.570	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	24-APR-20	8.170	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	14-MAY-20	6.840	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	14-MAY-20	4.780	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	14-MAY-20	3.540	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	14-MAY-20	2.660	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	03-MAR-20	6.980	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	03-MAR-20	5.490	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	03-MAR-20	6.800	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Flush180	03-MAR-20	5.200	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Initial	06-JUN-16	2.350	ppb
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Initial	24-APR-20	6.410	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Initial	14-MAY-20	7.510	ug/L
51250	51250-1-E-HAL-F03	Fountain Across From Room 109, Right Fountain	Initial	03-MAR-20	14.800	ug/L
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Flush180	06-JUN-16	1.080	ppb
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Flush180	06-JUN-16	2.230	ppb
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Flush180	06-JUN-16	2.470	ppb
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Flush180	06-JUN-16	2.100	ppb
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Initial	06-JUN-16	2.310	ppb
51250	51250-2-E-HAL-F03	Fountain Across From Room 204	Initial	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Flush180	06-JUN-16	4.900	ppb
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Flush180	06-JUN-16	1.690	ppb
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Flush180	06-JUN-16	2.840	ppb
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Flush180	06-JUN-16	3.450	ppb
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Flush180	03-MAR-20	2.160	ug/L
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Initial	06-JUN-16	2.010	ppb
51250	51250-2-N-HAL-F04	Fountain Across From Room 209	Initial	03-MAR-20	1.080	ug/L
51250	51250-1-N-HAL-F01	Fountain By Room 123	Flush180	06-JUN-16	0.768	ppb
51250	51250-1-N-	Fountain By Room 123	Flush180	06-JUN-16	0.749	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01					
51250	51250-1-N-HAL-F01	Fountain By Room 123	Flush180	06-JUN-16	0.738	ppb
51250	51250-1-N-HAL-F01	Fountain By Room 123	Flush180	06-JUN-16	0.759	ppb
51250	51250-1-N-HAL-F01	Fountain By Room 123	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-N-HAL-F01	Fountain By Room 123	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-N-HAL-F01	Fountain By Room 123	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-N-HAL-F01	Fountain By Room 123	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-N-HAL-F01	Fountain By Room 123	Initial	06-JUN-16	0.523	ppb
51250	51250-1-N-HAL-F01	Fountain By Room 123	Initial	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F02	Fountain By Room 213	Flush180	06-JUN-16	0.498	ppb
51250	51250-2-N-HAL-F02	Fountain By Room 213	Flush180	06-JUN-16	0.516	ppb
51250	51250-2-N-HAL-F02	Fountain By Room 213	Flush180	06-JUN-16	0.397	ppb
51250	51250-2-N-HAL-F02	Fountain By Room 213	Flush180	06-JUN-16	0.503	ppb
51250	51250-2-N-HAL-F02	Fountain By Room 213	Flush180	03-MAR-20	1.990	ug/L
51250	51250-2-N-HAL-F02	Fountain By Room 213	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F02	Fountain By Room 213	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F02	Fountain By Room 213	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F02	Fountain By Room 213	Initial	06-JUN-16	0.843	ppb
51250	51250-2-N-HAL-F02	Fountain By Room 213	Initial	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F01	Fountain By Room 223	Flush180	06-JUN-16	0.729	ppb
51250	51250-2-N-HAL-F01	Fountain By Room 223	Flush180	06-JUN-16	0.754	ppb
51250	51250-2-N-HAL-F01	Fountain By Room 223	Flush180	06-JUN-16	0.736	ppb
51250	51250-2-N-HAL-F01	Fountain By Room 223	Flush180	06-JUN-16	0.765	ppb
51250	51250-2-N-HAL-F01	Fountain By Room 223	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F01	Fountain By Room 223	Flush180	03-MAR-20	1.190	ug/L
51250	51250-2-N-HAL-F01	Fountain By Room 223	Flush180	03-MAR-20	1.000	ug/L
51250	51250-2-N-HAL-F01	Fountain By Room 223	Flush180	03-MAR-20	2.230	ug/L
51250	51250-2-N-HAL-F01	Fountain By Room 223	Initial	06-JUN-16	0.886	ppb
51250	51250-2-N-HAL-F01	Fountain By Room 223	Initial	03-MAR-20	1.710	ug/L
51250	51250-3-N-HAL-F02	Fountain By Room 313	Flush180	06-JUN-16	0.714	ppb
51250	51250-3-N-HAL-F02	Fountain By Room 313	Flush180	06-JUN-16	0.723	ppb
51250	51250-3-N-HAL-F02	Fountain By Room 313	Flush180	06-JUN-16	0.657	ppb
51250	51250-3-N-HAL-F02	Fountain By Room 313	Flush180	06-JUN-16	0.901	ppb
51250	51250-3-N-HAL-F02	Fountain By Room 313	Flush180	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F02	Fountain By Room 313	Flush180	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F02	Fountain By Room 313	Flush180	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F02	Fountain By Room 313	Flush180	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F02	Fountain By Room 313	Initial	06-JUN-16	0.785	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51250	51250-3-N-HAL-F02	Fountain By Room 313	Initial	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F01	Fountain By Room 321	Flush180	06-JUN-16	1.450	ppb
51250	51250-3-N-HAL-F01	Fountain By Room 321	Flush180	06-JUN-16	1.730	ppb
51250	51250-3-N-HAL-F01	Fountain By Room 321	Flush180	06-JUN-16	2.360	ppb
51250	51250-3-N-HAL-F01	Fountain By Room 321	Flush180	06-JUN-16	2.040	ppb
51250	51250-3-N-HAL-F01	Fountain By Room 321	Flush180	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F01	Fountain By Room 321	Flush180	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F01	Fountain By Room 321	Flush180	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F01	Fountain By Room 321	Flush180	03-MAR-20	1.000	ug/L
51250	51250-3-N-HAL-F01	Fountain By Room 321	Initial	06-JUN-16	2.020	ppb
51250	51250-3-N-HAL-F01	Fountain By Room 321	Initial	03-MAR-20	1.000	ug/L
51250	51250-1-101-F01	Fountain in RM 101	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-F01	Fountain in RM 101	Flush180	18-JAN-23	1.130	ug/L
51250	51250-1-101-F01	Fountain in RM 101	Flush180	18-JAN-23	1.040	ug/L
51250	51250-1-101-F01	Fountain in RM 101	Flush180	18-JAN-23	1.070	ug/L
51250	51250-1-101-F01	Fountain in RM 101	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-103-F01	Fountain in RM 103	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-F01	Fountain in RM 103	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-F01	Fountain in RM 103	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-F01	Fountain in RM 103	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-F01	Fountain in RM 103	Initial	18-JAN-23	1.000	ug/L
51250	51250-B-E-KIT-KS03	Middle Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS03	Middle Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS03	Middle Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS03	Middle Sink	Flush180	03-MAR-20	1.000	ug/L
51250	51250-B-E-KIT-KS03	Middle Sink	Initial	03-MAR-20	1.000	ug/L
51250	51250-1-PLYGR-BF01	Outside, West Student Garden, Bottle Filler	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-BF01	Outside, West Student Garden, Bottle Filler	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-BF01	Outside, West Student Garden, Bottle Filler	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-BF01	Outside, West Student Garden, Bottle Filler	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-BF01	Outside, West Student Garden, Bottle Filler	Initial	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F01	Outside, West Student Garden, Left Fountain	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F01	Outside, West Student Garden, Left Fountain	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F01	Outside, West Student Garden, Left Fountain	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F01	Outside, West Student Garden, Left Fountain	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F01	Outside, West Student Garden, Left Fountain	Initial	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F02	Outside, West Student Garden, Right Fountain	Flush	20-OCT-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51250	51250-1-PLYGR-F02	Outside, West Student Garden, Right Fountain	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F02	Outside, West Student Garden, Right Fountain	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F02	Outside, West Student Garden, Right Fountain	Flush	20-OCT-2023	1.000	ug/L
51250	51250-1-PLYGR-F02	Outside, West Student Garden, Right Fountain	Initial	20-OCT-2023	1.000	ug/L
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Flush180	22-JUN-16	5.400	ppb
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Flush180	22-JUN-16	6.570	ppb
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Flush180	22-JUN-16	5.150	ppb
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Flush180	22-JUN-16	3.970	ppb
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Flush180	03-MAR-20	1.960	ug/L
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Flush180	03-MAR-20	1.160	ug/L
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Flush180	03-MAR-20	2.400	ug/L
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Flush180	03-MAR-20	3.480	ug/L
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Initial	22-JUN-16	13.800	ppb
51250	51250-1-S-100-S01	Pre- K Room 100 Sink, South Wall	Initial	03-MAR-20	3.540	ug/L
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Flush180	22-JUN-16	0.541	ppb
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Flush180	22-JUN-16	0.440	ppb
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Flush180	22-JUN-16	0.496	ppb
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Flush180	22-JUN-16	0.507	ppb
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Flush180	03-MAR-20	1.100	ug/L
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Flush180	03-MAR-20	1.770	ug/L
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Initial	22-JUN-16	0.570	ppb
51250	51250-1-W-101-S03	Room 101 Sink, West Wall	Initial	03-MAR-20	1.000	ug/L
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Flush180	22-JUN-16	0.603	ppb
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Flush180	22-JUN-16	1.030	ppb
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Flush180	22-JUN-16	0.610	ppb
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Flush180	22-JUN-16	0.873	ppb
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Initial	22-JUN-16	0.889	ppb
51250	51250-1-S-103-S04	Room 103 Sink, South Wall	Initial	03-MAR-20	1.000	ug/L
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Flush180	22-JUN-16	1.370	ppb
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Flush180	22-JUN-16	2.120	ppb
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Flush180	22-JUN-16	2.030	ppb
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Flush180	22-JUN-16	1.610	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	104-S02					
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Initial	22-JUN-16	2.940	ppb
51250	51250-1-S-104-S02	Room 104 Sink, South Wall	Initial	03-MAR-20	2.310	ug/L
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Flush180	22-JUN-16	9.920	ppb
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Flush180	22-JUN-16	6.430	ppb
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Flush180	22-JUN-16	4.600	ppb
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Flush180	22-JUN-16	8.330	ppb
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Flush180	03-MAR-20	1.160	ug/L
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Flush180	03-MAR-20	1.000	ug/L
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Initial	22-JUN-16	2.240	ppb
51250	51250-1-W-106-S05	Room 106 Sink, West Wall	Initial	03-MAR-20	1.000	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	22-JUN-16	0.530	ppb
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	22-JUN-16	0.646	ppb
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	22-JUN-16	0.580	ppb
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	22-JUN-16	0.569	ppb
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	24-APR-20	1.380	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	24-APR-20	1.000	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	24-APR-20	1.120	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	24-APR-20	1.000	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	03-MAR-20	39.100	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	03-MAR-20	10.000	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	03-MAR-20	12.500	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Flush180	03-MAR-20	17.900	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Initial	22-JUN-16	1.350	ppb
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Initial	24-APR-20	1.620	ug/L
51250	51250-1-E-107-S06	Room 107 Sink, East Wall	Initial	03-MAR-20	11.800	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	22-JUN-16	3.790	ppb
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	22-JUN-16	2.280	ppb
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	22-JUN-16	4.550	ppb
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	22-JUN-16	2.070	ppb
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	24-APR-20	3.080	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	24-APR-20	18.100	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	109-S07					
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	24-APR-20	5.300	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	24-APR-20	2.850	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	14-MAY-20	2.920	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	14-MAY-20	3.220	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	14-MAY-20	3.280	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	14-MAY-20	3.040	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	03-MAR-20	33.300	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	03-MAR-20	1.990	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	03-MAR-20	3.440	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Flush180	03-MAR-20	7.850	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Initial	22-JUN-16	4.770	ppb
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Initial	24-APR-20	3.320	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Initial	14-MAY-20	5.980	ug/L
51250	51250-1-E-109-S07	Room 109 Sink, East Wall	Initial	03-MAR-20	16.900	ug/L
51250	51250-1-101-S01	Sink in RM 101 Left	Flush180	18-JAN-23	1.070	ug/L
51250	51250-1-101-S01	Sink in RM 101 Left	Flush180	18-JAN-23	1.010	ug/L
51250	51250-1-101-S01	Sink in RM 101 Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-S01	Sink in RM 101 Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-S01	Sink in RM 101 Left	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-101-S02	Sink in RM 101 Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-S02	Sink in RM 101 Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-S02	Sink in RM 101 Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-S02	Sink in RM 101 Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-101-S02	Sink in RM 101 Right	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-103-S01	Sink in RM 103 Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-S01	Sink in RM 103 Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-S01	Sink in RM 103 Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-S01	Sink in RM 103 Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-S01	Sink in RM 103 Left	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-103-S02	Sink in RM 103 Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-S02	Sink in RM 103 Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-S02	Sink in RM 103 Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-S02	Sink in RM 103 Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-103-S02	Sink in RM 103 Right	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-109-S01	Sink in RM 109, Left	Flush180	18-JAN-23	1.140	ug/L
51250	51250-1-109-S01	Sink in RM 109, Left	Flush180	18-JAN-23	1.060	ug/L
51250	51250-1-109-S01	Sink in RM 109, Left	Flush180	18-JAN-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51250	51250-1-109-S01	Sink in RM 109, Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-109-S01	Sink in RM 109, Left	Initial	18-JAN-23	1.000	ug/L
51250	51250-1-109-S02	Sink in RM 109, Right	Flush180	18-JAN-23	1.050	ug/L
51250	51250-1-109-S02	Sink in RM 109, Right	Flush180	18-JAN-23	1.070	ug/L
51250	51250-1-109-S02	Sink in RM 109, Right	Flush180	18-JAN-23	1.080	ug/L
51250	51250-1-109-S02	Sink in RM 109, Right	Flush180	18-JAN-23	1.100	ug/L
51250	51250-1-109-S02	Sink in RM 109, Right	Initial	18-JAN-23	1.360	ug/L
51250	51250-1-107-S01	Sink in Rm 107, Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-S01	Sink in Rm 107, Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-S01	Sink in Rm 107, Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-S01	Sink in Rm 107, Left	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-S01	Sink in Rm 107, Left	Initial	18-JAN-23	1.030	ug/L
51250	51250-1-107-S02	Sink in Rm 107, Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-S02	Sink in Rm 107, Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-S02	Sink in Rm 107, Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-S02	Sink in Rm 107, Right	Flush180	18-JAN-23	1.000	ug/L
51250	51250-1-107-S02	Sink in Rm 107, Right	Initial	18-JAN-23	1.000	ug/L