



Sep 10, 2024

SOUTHSIDE HS

2710 S DEARBORN ST, Chicago IL 60616.

Dear **SOUTHSIDE HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

SOUTHSIDE HS

2710 S DEARBORN ST, Chicago IL 60616.

Estimadas familias de **SOUTHSIDE HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	28-JUN-23	1.000	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	28-JUN-23	1.000	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	28-JUN-23	1.840	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	28-JUN-23	1.800	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	01-NOV-16	0.230	ppb
51617	51617-1-108-KS01	Dishwashing RM 108	Flush180	01-NOV-16	0.250	ppb
51617	51617-1-108-KS01	Dishwashing RM 108	Flush180	01-NOV-16	0.700	ppb
51617	51617-1-108-KS01	Dishwashing RM 108	Flush180	01-NOV-16	0.560	ppb
51617	51617-1-108-KS01	Dishwashing RM 108	Flush180	01-NOV-16	0.630	ppb
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	01-NOV-16	0.520	ppb
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	01-NOV-16	14.000	ppb
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	01-NOV-16	0.360	ppb
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	27-APR-23	4.590	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	27-APR-23	3.760	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	27-APR-23	5.420	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Flush180	27-APR-23	5.600	ug/L
51617	51617-1-108-KS01	Dishwashing RM 108	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-108-KS01	Dishwashing RM 108	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-108-KS01	Dishwashing RM 108	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-108-KS01	Dishwashing RM 108	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Initial	28-JUN-23	1.310	ug/L
51617	51617-1-108-KS01	Dishwashing RM 108	Initial	01-NOV-16	5.400	ppb
51617	51617-1-108-KS02	Dishwashing RM 108	Initial	01-NOV-16	2.200	ppb
51617	51617-1-108-KS01	Dishwashing RM 108	Initial	27-APR-23	1.000	ug/L
51617	51617-1-108-KS02	Dishwashing RM 108	Initial	27-APR-23	12.100	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	18-JUL-23	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	18-JUL-23	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	18-JUL-23	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	18-JUL-23	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	01-NOV-16	0.190	ppb
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	01-NOV-16	0.230	ppb
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	01-NOV-16	0.170	ppb
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	01-NOV-16	0.650	ppb
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	18-DEC-20	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	24-FEB-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	24-FEB-21	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	24-FEB-21	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	24-FEB-21	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	27-APR-23	1.420	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Flush180	27-APR-23	1.060	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Initial	18-JUL-23	1.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Initial	01-NOV-16	1.600	ppb
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Initial	18-DEC-20	13.000	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Initial	24-FEB-21	1.320	ug/L
51617	51617-1-109-KS01	Dishwashing RM 109 Left Sink	Initial	27-APR-23	5.200	ug/L
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Flush180	01-NOV-16	0.190	ppb
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Flush180	01-NOV-16	0.100	ppb
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Flush180	01-NOV-16	0.200	ppb
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Initial	01-NOV-16	0.400	ppb
51617	51617-1-109-KS02	Dishwashing RM 109 Right Sink	Initial	27-APR-23	1.000	ug/L
51617	51617-2-HAL-F01	Next to Boys Bathroom	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F01	Next to Boys Bathroom	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F01	Next to Boys Bathroom	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F01	Next to Boys Bathroom	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F01	Next to Boys Bathroom	Flush180	27-APR-23	1.000	ug/L
51617	51617-2-HAL-F01	Next to Boys Bathroom	Flush180	27-APR-23	1.000	ug/L
51617	51617-2-HAL-F01	Next to Boys Bathroom	Flush180	27-APR-23	1.000	ug/L
51617	51617-2-HAL-F01	Next to Boys Bathroom	Flush180	27-APR-23	1.000	ug/L
51617	51617-2-HAL-F01	Next to Boys Bathroom	Initial	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F01	Next to Boys Bathroom	Initial	27-APR-23	1.000	ug/L
51617	51617-2-HAL-F02	Next to Girls Bathroom	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F02	Next to Girls Bathroom	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F02	Next to Girls Bathroom	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F02	Next to Girls Bathroom	Flush180	01-NOV-16	0.068	ppb
51617	51617-2-HAL-F02	Next to Girls Bathroom	Initial	01-NOV-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
51617	51617-2-HAL-F03	Next to Girls Bathroom Bottle Filler	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F03	Next to Girls Bathroom Bottle Filler	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F03	Next to Girls Bathroom Bottle Filler	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F03	Next to Girls Bathroom Bottle Filler	Flush180	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F03	Next to Girls Bathroom Bottle Filler	Flush180	18-DEC-20	1.000	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Flush180	27-APR-23	1.000	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Flush180	27-APR-23	1.000	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Flush180	27-APR-23	1.000	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Flush180	27-APR-23	33.900	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Initial	28-JUN-23	1.000	ug/L
51617	51617-2-HAL-F03	Next to Girls Bathroom Bottle Filler	Initial	01-NOV-16	1.000	ppb
51617	51617-2-HAL-F03	Next to Girls Bathroom Bottle Filler	Initial	18-DEC-20	1.000	ug/L
51617	51617-2-HAL-BF01	Next to Girls Bathroom Bottle Filler	Initial	27-APR-23	1.000	ug/L
51617	51617-1-106-S01	Sink in Office RM 106	Flush180	01-NOV-16	0.370	ppb
51617	51617-1-106-S01	Sink in Office RM 106	Flush180	01-NOV-16	0.650	ppb
51617	51617-1-106-S01	Sink in Office RM 106	Flush180	01-NOV-16	0.370	ppb
51617	51617-1-106-S01	Sink in Office RM 106	Flush180	01-NOV-16	0.400	ppb
51617	51617-1-106-S01	Sink in Office RM 106	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-106-S01	Sink in Office RM 106	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-106-S01	Sink in Office RM 106	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-106-S01	Sink in Office RM 106	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-106-S01	Sink in Office RM 106	Initial	01-NOV-16	3.800	ppb
51617	51617-1-106-S01	Sink in Office RM 106	Initial	27-APR-23	2.690	ug/L
51617	51617-1-107-S01	Staff Break Rm	Flush180	01-NOV-16	0.220	ppb
51617	51617-1-107-S01	Staff Break Rm	Flush180	01-NOV-16	0.098	ppb
51617	51617-1-107-S01	Staff Break Rm	Flush180	01-NOV-16	0.270	ppb
51617	51617-1-107-S01	Staff Break Rm	Flush180	01-NOV-16	0.086	ppb
51617	51617-1-107-S01	Staff Break Rm	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-107-S01	Staff Break Rm	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-107-S01	Staff Break Rm	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-107-S01	Staff Break Rm	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-107-S01	Staff Break Rm	Initial	01-NOV-16	0.610	ppb
51617	51617-1-107-S01	Staff Break Rm	Initial	27-APR-23	1.000	ug/L
51617	51617-1-CAF-	Student Caf Bottle Filler	Flush180	27-APR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
51617	51617-1-CAF-BF01	Student Caf Bottle Filler	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-BF01	Student Caf Bottle Filler	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-BF01	Student Caf Bottle Filler	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-BF01	Student Caf Bottle Filler	Initial	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F01	Student Caf?	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F01	Student Caf?	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F01	Student Caf?	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F01	Student Caf?	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F01	Student Caf?	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F01	Student Caf?	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F01	Student Caf?	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F01	Student Caf?	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F01	Student Caf?	Initial	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F01	Student Caf?	Initial	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F02	Student Caf? Bottle Filler	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F02	Student Caf? Bottle Filler	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F02	Student Caf? Bottle Filler	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F02	Student Caf? Bottle Filler	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F02	Student Caf? Bottle Filler	Initial	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F03	Student Caf? Right	Flush180	01-NOV-16	0.081	ppb
51617	51617-1-CAF-F03	Student Caf? Right	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F03	Student Caf? Right	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F03	Student Caf? Right	Flush180	01-NOV-16	1.000	ppb
51617	51617-1-CAF-F03	Student Caf? Right	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F03	Student Caf? Right	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F03	Student Caf? Right	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F03	Student Caf? Right	Flush180	27-APR-23	1.000	ug/L
51617	51617-1-CAF-F03	Student Caf? Right	Initial	01-NOV-16	0.150	ppb
51617	51617-1-CAF-F03	Student Caf? Right	Initial	27-APR-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-	3-Basin Sink Faucet in rm 310	Flush180	28-JUN-23	1.000	ug/L

Water Quality Assessment Southside Occupational Academy High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS01					
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	01-NOV-16	0.170	ppb
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	01-NOV-16	0.160	ppb
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	01-NOV-16	0.160	ppb
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	01-NOV-16	0.180	ppb
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Flush180	27-APR-23	34.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Initial	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Initial	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Initial	01-NOV-16	0.250	ppb
57161	57161-1-310-KS01	3-Basin Sink Faucet in rm 310	Initial	27-APR-23	1.000	ug/L
57161	57161-1-310-KS02	3-Basin Sink Faucet in rm 310	Initial	27-APR-23	34.700	ug/L
57161	57161-1-HAL-F01	Across RM 311	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F01	Across RM 311	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F01	Across RM 311	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F01	Across RM 311	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F01	Across RM 311	Initial	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F03	Across RM 311 Bottle Filler	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F03	Across RM 311 Bottle Filler	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F03	Across RM 311 Bottle Filler	Flush180	01-NOV-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
57161	57161-1-HAL-F03	Across RM 311 Bottle Filler	Flush180	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	27-APR-23	1.230	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Flush180	27-APR-23	1.020	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Flush180	27-APR-23	34.300	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Initial	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Initial	28-JUN-23	1.000	ug/L
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Initial	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F03	Across RM 311 Bottle Filler	Initial	01-NOV-16	1.000	ppb
57161	57161-1-HAL-F02	Across RM 311 Bottle Filler	Initial	27-APR-23	36.900	ug/L
57161	57161-1-HAL-BF01	Across RM 311 Bottle Filler	Initial	27-APR-23	1.000	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Flush180	27-APR-23	1.370	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Flush180	27-APR-23	1.630	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Flush180	27-APR-23	35.700	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Initial	28-JUN-23	1.000	ug/L
57161	57161-1-310-KS03	Sink Faucet in rm 310 to the right of 3-basin sink	Initial	27-APR-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Flush180	28-JUN-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Flush180	01-NOV-16	0.350	ppb
57161	57161-1-308-S01	Sink in Caf?	Flush180	01-NOV-16	0.580	ppb
57161	57161-1-308-S01	Sink in Caf?	Flush180	01-NOV-16	0.320	ppb
57161	57161-1-308-S01	Sink in Caf?	Flush180	01-NOV-16	0.280	ppb
57161	57161-1-308-S01	Sink in Caf?	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Flush180	27-APR-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Flush180	27-APR-23	1.000	ug/L



Water Quality Assessment
Southside Occupational Academy High School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
57161	57161-1-308-S01	Sink in Caf?	Initial	28-JUN-23	1.000	ug/L
57161	57161-1-308-S01	Sink in Caf?	Initial	01-NOV-16	0.330	ppb
57161	57161-1-308-S01	Sink in Caf?	Initial	27-APR-23	34.500	ug/L